

ARCHIVED

**MUNICIPAL WATER QUALITY
REPORTS**

MOOSE CREEK WATER



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Chesterville Hub
5 Industrial Drive, P.O. Box 460
Chesterville, Ontario K0C 1H0
Tel: (613) 448-3098
Fax: (613) 448-1616
www.ocwa.com

Fax

To MOH MOE

Company _____

Fax Number 933-7930 268-6061

From Dave Markell

Date Oct. 9/02

Number of Pages 4 (including this page)

Subject Moose Creek Adverse Water

- 2 T.C. Treated Water.

- FCl₂ 1.86 T.Cl₂ 2.18 @

Sample site

- Raw Water well 2 ABSENT

well 3 ABSENT



Ontario

Ministry
of the
Environment

Ministère
de
l'Environnement

Notice of Drinking Water Analysis and Remedial Actions for Waterworks as Required under Drinking Water Protection Regulation

In accordance with the Drinking Water Protection Regulation, Laboratories and Water Works Owners must immediately provide oral notification in the MOE Spills Action Centre (SAC) at 1-800-268-6060 or 1-416-325-3000 and the local Medical Officer of Health (MOH) of indicators of adverse drinking water quality and exceedances of standards as outlined in the Regulation and remedial actions taken. Further, within 24 hours of the oral notification, the party shall provide written notification on this completed form by Fax to the Spills Action Centre at 1-800-268-6061 or 1-416-325-3011 and the local Medical Officer of Health. Failure to notify these parties in accordance with the Regulation constitutes an offence under the Act. A copy of this form may be acquired through the Ministry of the Environment (MOE) public web site (www.ene.gov.on.ca) or by contacting any MOE office.

PART 1 - NOTIFICATION BY LABORATORY

Indicators of Adverse Water Quality <input checked="" type="checkbox"/>	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
ORAL NOTIFICATION to SPILLS ACTION CENTRE by LABORATORY		
Date: OCT 9/02	Time: 2:15 P.M.	By: KRYSYNA PIPIN
Laboratory Name: CADUCEON ENV. LABS.	Laboratory Emergency Contact Name: KRYSYNA PIPIN	
Address: 2373 HOLLY LANE OTTAWA	Position: SUPERVISOR	
Email address:	Phone # 613 526-0123 Fax # 613 526-1244	
Waterworks Name: MOOSE CREEK WELL SUPPLY	Waterworks Emergency Contact:	
Works # 220008033	Name: DAVE MARKELL	
Location: 16950 McNeill Rd MOOSE CREEK	Position: PROCESS TECHNICIAN	
Email Address:	Phone # 448-3098 Fax # 613 448-1616	
NOTIFICATION OF WATER WORKS OWNER		NOTIFICATION OF LOCAL MEDICAL OFFICER OF HEALTH
Person Contacted: DAVE MARKELL		Person Contacted: ADALIA
Position: PROCESS TECHNICIAN		Position: SPEC. PROJECTS
Date: OCT 9/02	Time: 1:55 P.M.	Date: OCT 9/02 Time: 2:10 P.M.
Laboratory Written Notification Prepared by: Name (please print) KRYSYNA PIPIN		
Signature: K. PIPIN		Date: OCT 9/02

PART 2 - NOTIFICATION BY WATER WORKS OWNER

Indicators of Adverse Water Quality <input type="checkbox"/>	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
<input type="checkbox"/> This notification is for operational problems identified at the waterworks; there is no Laboratory notification associated with this report		
SPILLS ACTION CENTRE ORAL NOTIFICATION BY OWNER		WATERWORKS EMERGENCY CONTACT
Date: Oct 9/02	Time: 2:50	Name: Dave Markell
Waterworks Name: Moose Creek Wells		Position: Process Tech.
Works # 220008033		Phone # 613-448-3098 Fax # 613-448-1616
Works Person Providing Oral Notification:		
MEDICAL OFFICER OF HEALTH ORAL NOTIFICATION BY OWNER		REMEDIAL ACTIONS TAKEN BY OWNER:
Date: Oct 9/02	Time: 2:50	Resampling Initiated <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Person Contacted: Adalia		Increase Chlorine Dose <input type="checkbox"/> Yes <input type="checkbox"/> No
Position: SPECIAL		Flushing Mains <input type="checkbox"/> Yes <input type="checkbox"/> No
Phone # 500-767-7120	Fax # 933-7930	Other Actions Taken <input type="checkbox"/> Yes <input type="checkbox"/> No
Works Person Providing Oral Notification:		Describe:
Water Works Written Notification Prepared by: Name (please print) Dave Markell		Other information attached <input type="checkbox"/>
Signature: Dave Markell		Date: Oct 9/02
For Ministry Use Only:		Occurrence Report #:



Ministry
of the
Environment

Ministère
de
l'Environnement

PART 3:

ADVERSE ANALYTICAL RESULTS - For Indicators Listed in SCHEDULE 6 -
Drinking Water Protection Regulation

Microbiological Testing

Laboratory Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) (: a.m. p.m.)	Sample Type/ Location	Membrane Filtration Count/100ml			P-A/100ml Presumptive/ Confirmed (If applicable)	HPC/ 1ml	Date of Analysis (M/D/Y)
				Total Coliforms	Back- ground	E.coli/ Fecal C.			
310010590	MC-04	10/07/02	TREATED WATER	2	—	ABSENT	—		10/08/02

ADVERSE ANALYTICAL RESULTS - For Parameters Listed in SCHEDULE 4 and 5 or in a C of A or Order
Drinking Water Protection Regulation

Physical/Chemical/Radiological Testing

Laboratory Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) (: a.m. p.m.)	Sample Type/ Location	Parameter	Result	Unit	MAC/ IMAC	Date of Analysis (M/D/Y)

Laboratory Results Authorized by:

KRYSTINA PIRN

Authorization Date:

Oct. 9 / 02

For Ministry Use Only:

Occurrence Report #:

1402-047 (07/00)

Page 2 of 2

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Report:

220010890

Project:

Moose Creek WTP

Date Sampled:

October 7, 2002

Date Received:

October 8, 2002

Date Printed:

October 09, 2002

Attention: Dave Markell

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05
Sample ID						
Well #2 Raw	absent	absent			absent	
Well #3 Raw	2	absent			absent	
Treated Water		absent	1.86		2	2.18
M.C. Hall		absent	1.12		absent	1.52
Paul Adams Cons.		absent	0.96		absent	1.16

Caduceon Environmental Laboratories
2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada
Tel: (613)526-0123, Fax: (613)526-1244

For 
Michael Ziebell, General Manager

HP OfficeJet K Series K80
Personal Printer/Fax/Copier/Scanner

Log for
OCWA
613 448-1616
Oct 09 2002 3:29pm

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Oct 9	3:26pm	Fax Sent	16139337930	2:54	4	OK

HP OfficeJet K Series K80
Personal Printer/Fax/Copier/Scanner

Log for
OCWA
613 448-1616
Oct 09 2002 3:25pm

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Oct 9	3:24pm	Fax Sent	18002686061	0:56	4	OK



**Ontario Clean Water Agency
Agence Ontarienne Des Eaux**

Chesterville Hub
5 Industrial Drive, P.O. Box 460
Chesterville, Ontario K0C 1H0
Tel: (613) 448-3098
Fax: (613) 448-1616
www.ocwa.com

Fax

To

Mott. MOE

Company

Fax Number

613-933-7930 1-800-267-6061

From

OCWA D. Markell

Date

June 19/02

Number of Pages

4 (including this page)

Subject

Adverse Water.

Moose Creek. Treated Water @ Plant.

- T-coli plate OVERGROWN.

- E-coli absent.

- Raw water Tcoli, Ecoli, Background ABSENT.

- Resampling Initiated.



Ontario

Ministry
of the
Environment

Ministère
de
l'Environnement

Notice of Drinking Water Analysis and Remedial Actions for Waterworks as Required under Drinking Water Protection Regulation

In accordance with the Drinking Water Protection Regulation, Laboratories and Water Works Owners must immediately provide oral notification to the MOE Spills Action Centre (SAC) at 1-800-368-6966 or 1-416-325-3900 and the local Medical Officer of Health (MOH) of indicators of adverse drinking water quality and exceedances of standards as outlined in the Regulation and remedial actions taken. Further, within 24 hours of the oral notification, the party shall provide written notification on this completed form by Fax to the Spills Action Centre at 1-800-368-6966 or 1-416-325-3911 and the local Medical Officer of Health. Failure to notify these parties in accordance with the Regulation constitutes an offence under the Act. A copy of this form may be acquired through the Ministry of the Environment (MOE) public web site (www.moe.gov.on.ca) or by contacting any MOE office.

PART 1 - NOTIFICATION BY LABORATORY

Indicators of Adverse <input checked="" type="checkbox"/> Water Quality	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC Col/A/Order <input type="checkbox"/> Exceeds Limit
ORAL NOTIFICATION to SPILLS ACTION CENTRE by LABORATORY		
Date: JUNE 19 2002 Time: 3:05 PM	By: KRYSYNA PIPIN	
Laboratory Name: CADUCEON ENV LAB	Laboratory Emergency Contact Name: MIKE ZIEBEL	
Address: 2378 HOLLY LAKE OTTAWA	Position: GENERAL MANAGER	
Email address:	Phone # 613 526-0113 Fax # 613 526-1244	
Waterworks Name: MOOSE CREEK WELL SUPPLY	Waterworks Emergency Contact: ONTARIO CLEAN WATER AGENCY	
Works # 220008033	Name:	
Location: MOOSE CREEK	Position:	
Email Address:	Phone # (613) 448-3098 Fax # (613) 448-1616	
NOTIFICATION OF WATER WORKS OWNER		
Person Contacted: DAVE MARKELL	Person Contacted: I RINE MARCHAND	
Position: TECHNICIAN	Position: ADM. ASST.	
Date: June 19/02 Time:	Date: JUNE 19/02 Time: 2:55 P.M.	
Laboratory Written Notification Prepared by: KRYSYNA PIPIN		
(Lab Results must be attached using Part 3 of form)		
Signature: U. Lipin Date: June 19/02		

PART 2 - NOTIFICATION BY WATER WORKS OWNER

Indicators of Adverse <input checked="" type="checkbox"/> Water Quality	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC Col/A/Order <input type="checkbox"/> Exceeds Limit
<input type="checkbox"/> This notification is for operational problems identified at the waterworks; there is no Laboratory notification associated with this report		
SPILLS ACTION CENTRE ORAL NOTIFICATION BY OWNER		
Date: June 19/02 Time: 15:25	Name: Dave Markell	
Waterworks Name: 220008033	Position: Process Tech.	
Works # Moose Creek Water	Phone # 613-448-3098 Fax # 448-1616	
Water Person Providing Oral Notification: Dave Markell	REMEDIAL ACTIONS TAKEN BY OWNER:	
MEDICAL OFFICER OF HEALTH ORAL NOTIFICATION BY OWNER	Resampling Initiated <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Date: June 19/02 Time: 15:30	Increase Chlorine Dose <input type="checkbox"/> Yes <input type="checkbox"/> No	
Person Contacted: Adalia	Flushing Main <input type="checkbox"/> Yes <input type="checkbox"/> No	
Position: Special Projects	Other Actions Taken <input type="checkbox"/> Yes <input type="checkbox"/> No	
Phone # 800-267-7120 Fax # 613-933-7930	Describe:	
Water Person Providing Oral Notification: D. Markell	Other information attached <input checked="" type="checkbox"/>	
Water Works Written Notification Prepared by: Dave Markell	Date: June 19/02	
Signature: Dave Markell Occurrence Report #:		
For Ministry Use Only:		

1402-017 (07/00)

Page 2 of 4



Ontario

Ministry of the Environment and Climate Change

PART 3:

ADVERSE ANALYTICAL RESULTS - For Indicators Listed in SCHEDULE 6 -
Drinking Water Protection Regulation

Microbiological Testing

Laboratory Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y)	Sample Type / Location	Membrane Filtration Count/100ml			P-4/100ml Presumptive/Confirmed (if applicable)	EPC/1ml	Date of Analysis (M/D/Y)
				Total Coliforms	Bact. ground	Esch/Feal C			
320006128	MC-04	06/17/02	Drinking	0	0	ABSENT			06/18/02

ADVERSE ANALYTICAL RESULTS - For Parameters Listed in SCHEDULE 4 and 5 or in a C of A or Order
Drinking Water Protection Regulation

Physical/Chemical/Radiological Testing

Laboratory Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y)	Sample Type / Location	Parameter	Result	Unit	MAC/IMAC	Date of Analysis (M/D/Y)

Laboratory Results Authorized by:

KATHYUNA PIPIN

Authorization Date:

06/19/02

For Ministry Use Only:

Occurrence Report #:

1402-047 (07/00)

Page 3 of 4

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

PARTIAL

Attention: Dave Markell

Report:

220006128

Project:

Moose Creek WTP

Date Sampled:

June 17, 2002

Date Received:

June 18, 2002

Date Printed:

June 19, 2002

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC
Unit	/100mL	/100mL	mg/L	/mL	/100mL
MDL	1	1	0.05	2	1

Sample ID

Well #2 Raw	absent	absent			absent
Well #3 Raw	absent	absent			absent
Treated Water		absent	1.60		OG
Dist. Sewage Pumping Station		absent	0.70		absent
Dist. Moose Creek Mall		absent	0.90		absent

Page 4 of 4

OG - OVERGROWN

Caduceon Environmental Laboratories
2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada
Tel: (613)526-0123, Fax: (613)526-1244

Page 1 of 1

E. P. J.
Michael Ziebell, General Manager

HP OfficeJet K Series K80
Personal Printer/Fax/Copier/Scanner

Log for
OCWA
613 448-1616
Jun 19 2002 3:51pm

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Jun 19	3:47pm	Fax Sent	16139337930	3:03	4	OK

HP OfficeJet K Series K80
Personal Printer/Fax/Copier/Scanner

Log for
OCWA
613 448-1616
Jun 19 2002 3:47pm

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Jun 19	3:46pm	Fax Sent	18002686061	1:00	4	OK

ETRL

Division of Caduceon Enterprises Inc.

133 Dutton Ave. Kingston, ON K7K 6G2 Tel: (613) 544-2001 Fax: (613) 544-2770 email: etrl@kingston.net

05 March 2002

re: HPC reporting

To all drinking water clients:

You have probably already noticed the recent change we have made in reporting HPC results. Samples with no detection of HPC will now be reported as <10 cfu/mL. We recently changed our analysis protocol to incorporate 100 uL of sample instead of 1000 uL. This will allow us to more clearly identify and count plates at and above the objective of 500 cfu/mL. The ODWS objective for HPC is 500 cfu/mL so a results reported as <10 cfu/mL will be acceptable by the Ministry of the Environment.

I hope we have not caused any confusion with this recent change.

If you have any questions please do not hesitate to contact me at (613)544-2001.

Regards

Steve Garrett
Lab MangerAttn: Blain H.
Dave M.

Corporate Office

Caduceon Enterprises Inc 40 Camelot Dr. Nepean, ON K2G 5X8 Tel: (613) 228-1145 Fax: (613) 228-1148

Branch Offices

Arco Canada 40 Camelot Dr. Nepean, ON K2G 5X8 Tel: (613) 228-1145 Fax: (613) 228-1148

Caduceon Enterprises Inc Environmental Laboratory 2378 Holy Lane Ottawa, ON K1V 7P1 Tel: (613) 628-0123 Fax: (613) 628-1244



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Chesterville Hub
5 Industrial Drive, P.O. Box 460
Chesterville, Ontario K0C 1H0
Tel: (613) 448-3098
Fax: (613) 448-1616
www.ocwa.com

Fax

To IRENE
Company MOH
Fax Number 1-613-~~261-7130~~ 7930 933-7930
From Dave
Date FEB 21
Number of Pages 5 (including this page)
Subject Please find attached

lab sheets from Moose Creek,
Finch, Chesterville and Winchester
Wells # 1, 5 & 6.

These are as a required follow-up
to notifications of adverse water
(Sodium over 20 mg/l) FEB 7/02.

any questions please call Dave



**Ontario Clean Water Agency
Agence Ontarienne Des Eaux**

Chesterville Hub
5 Industrial Drive,
Chesterville, Ontario K0C 1H0
Tel: (613) 448-3098
Fax: (613) 448-1616
bhenderson@ocwa.com

Fax

To Rheal Delaquis
Company Ministry of Environment
Fax Number (613) 933-6402
From Blair Henderson
Date February 21, 2002
Number of Pages 1 (including this page)
Subject Finch Water and Moose Creek Water - Sodium Exceedance

As a follow up to notification of sodium exceedance dated February 7, 2002, as per ODWR, all sites have been resampled and the results are as follows.

Finch Treated Water - 77.0 mg/Litre
Moose Creek Treated Water - 27 mg/Litre

These results have been forwarded to the Ministry of Health.

These results are consistent with historic sodium results.

Caution: This fax is private property intended solely for the information and use of the addressee. The contents are confidential and may be privileged. Any unauthorized use of this fax is strictly prohibited. If you are not the addressee, please notify sender immediately by telephone and either return or destroy this fax.

ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number: 2201834
Date: 2002-02-20
Date Submitted: 2002-02-14

ATT: Mr Blair Henderson

Project: Mocse Creek Wells

P.O. Number:

Matrix: Supply Water

LAB ID: 169945			Matrix:		Supply Water	
Sample Date: 2002-02-13						
Sample ID: MCW-04						
PARAMETER	UNITS	MDL	TREATED WATER			
Na	mg/L	2	27			

MDL = Method Detection Limit
Comment:

INC = Incomplete

APPROVAL:

8-146 Colonnade Road, Ottawa, ON, K2E 7Y1

608 Norris Court, Kingston, ON, K7P 2R9

TRANSMISSION VERIFICATION REPORT

TIME : 02/21/2002 13:47

DATE, TIME
FAX NO./NAME
DURATION
PAGE(S)
RESULT
MODE

02/21 13:45
16139337930
00:02:05
05
OK
STANDARD

Accutest Laboratories Ltd.

146 Colonnade Rd., Unit 8, Nepean, Ontario, K2E 7Y1

www.accutestlabs.com



ACCUTEST FAX

Date: February 7, 2002Number of pages including cover sheet: 15

To:

Blair Henderson
OCWA Chesterville

Phone: 613-448-3098Fax phone: 613-448-1616

CC: _____

From:

Kristina Hay
QA/QC Coordinator

Phone: 613-727-5692Fax phone: 613-727-5222e-mail: khay@accutestlabs.com

REMARKS

☐

Urgent

☐

For your review

☐

Reply ASAP

☐

Please comment

Originals to follow:

☐

YES

☐

NO

VIA:

☐

Mail

☐

Courier

Your Reference: Na ODWS Exceedances

Our Reference: _____

Mr. Henderson,

This is a notice of adverse Na results for the Winchester, Finch, Moose Creek and Chesterville Well Supplies. I have attached a preliminary copy of the reports as well as Part 1 and 3 of the MOE Notice of Drinking Water Analysis form.

Please contact me if you have any questions.

Best regards,

Kristina Hay
Kristina Hay

Ottawa • Kingston



Ministry
of the
Environment

Ministère
de
l'Environnement

Notice of Drinking Water Analysis and Remedial Actions for Waterworks as Required under Drinking Water Protection Regulation

In accordance with the Drinking Water Protection Regulation, Laboratories and Water Works Owners must immediately provide oral notification to the MOE Spills Action Centre (SAC) at 1-800-368-6868 or 1-416-325-3009 and the local Medical Officer of Health (MOH) of indicators of adverse drinking water quality and exceedances of standards as outlined in the Regulation and remedial actions taken. Further, within 24 hours of the oral notification, the party shall provide written notification on this completed form by Fax to the Spills Action Centre at 1-800-368-6868 or 1-416-325-3011 and the local Medical Officer of Health. Failure to notify does not exempt the party from the Regulation or the Act. A copy of this form may be acquired through the Ministry of the Environment (MOE) public web site (www.moe.gov.on.ca) or by contacting any MOE office.

PART 1 - NOTIFICATION BY LABORATORY

Indicators of Adverse Water Quality <input checked="" type="checkbox"/>	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
ORAL NOTIFICATION to SPILLS ACTION CENTRE by LABORATORY		
Date: Feb 7, 2002	Time: 4:10 pm	By: Kristina Hay
Laboratory Name: Accutest Laboratories Ltd.	Laboratory Emergency Contact Name: Peter Heulena	
Address: 148 Colonnade Rd., Unit 8, Nepean, ON K2E 7Y1	Position: Analytical Services Manager	
Email Address: info@accutestlabs.com	Phone #: (613) 727-5692	Fax #: (613) 727-5222
Waterworks Name: Moose Creek Well Supply	Waterworks Emergency Contact:	
Works #: 220008033	Name: Blair Henderson	
Location:	Position: Operator	
Email Address:	Phone #: (613) 448-3098	Fax #: (613) 448-1616
NOTIFICATION OF WATER WORKS OWNER		NOTIFICATION OF LOCAL MEDICAL OFFICER OF HEALTH
Person Contacted: Blair Henderson	Person Contacted: Irene Marchand	
Position: Operator	Position: Admin	
Date: Feb 7, 2002	Time: 3:15 pm	Date: Feb 7, 2002 Time: 4:06 pm
Laboratory Written Notification Prepared by: Name (please print) Kristina Hay		
Signature: Kristina Hay		Date: Feb 7, 2002

PART 2 - NOTIFICATION BY WATER WORKS OWNER

Indicators of Adverse Water Quality <input checked="" type="checkbox"/>	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
<input type="checkbox"/> This notification is for operational problems identified at the waterworks; there is no Laboratory notification associated with this report		
SPILLS ACTION CENTRE ORAL NOTIFICATION BY OWNER		WATERWORKS EMERGENCY CONTACT
Date: FEB 7/02	Time: 16:16	Name: Blair Henderson
Waterworks Name: 220008033		Position: Ops Manager
Works #: Moose Creek wells		Phone #: 448-3098 Fax #: 613-448-1616
Works Person Providing Oral Notification: BLAIR HENDERSON		
MEDICAL OFFICER OF HEALTH ORAL NOTIFICATION BY OWNER		REMEDIAL ACTIONS TAKEN BY OWNER:
Date: FEB 7/02	Time: 16:25	Resampling Initiated <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Person Contacted: Claudette		Increase Chlorine Dose <input type="checkbox"/> Yes <input type="checkbox"/> No
Position: Receptionist		Flushing Mains <input type="checkbox"/> Yes <input type="checkbox"/> No
Phone #: 613-933-1375	Fax #: 613-933-7930	Other Actions Taken <input type="checkbox"/> Yes <input type="checkbox"/> No
Works Person Providing Oral Notification: Dave Markell		Describe:
Water Works Written Notification Prepared by: Name (please print) Dave Markell		Other information attached <input checked="" type="checkbox"/>
Signature: Dave Markell		Date: FEB 7/02
For Ministry Use Only:		Occurrence Report #:

**ACCUTEST LABORATORIES LTD.****Report of Analysis**

Client: MOOSE CREEK WELL SUPPLY
5 Industrial Drive
Chesterville, ON
K0C 1H0

Report Number: 2201009
Date Reported:
Date Submitted: 2002-01-29
Date Collected: 2002-01-28
Project: Moose Creek Wells
Quarterly Chemicals

Attention: Mr. Blair Henderson

P.O. Number:
Matrix: Supply Water

PARAMETER	UNITS	MDL	167759
			Treated MCW-04
Al	mg/L	0.05	<0.05
Alkalinity as CaCO ₃	mg/L	5	205
Ca	mg/L	1	86
Cl	mg/L	1	29
Colour	TCU	2	2
Conductivity	uS/cm	5	707
Cu	mg/L	0.001	<0.001
DOC	mg/L	0.5	1.9
F	mg/L	0.10	0.23
Fe	mg/L	0.01	0.45
Hardness as CaCO ₃	mg/L	1	326
Mg	mg/L	1	27
Mn	mg/L	0.01	0.04
N-NH ₃	mg/L	0.02	<0.02
N-NH ₃ (unionized)	mg/L	0.02	<0.02
Na	mg/L	2	28
pH			7.84
SO ₄	mg/L	1	137
TOC	mg/L	0.5	2.1
Total Kjeldahl Nitrogen	mg/L	0.05	0.70

MDL = METHOD DETECTION LIMIT

Comment:

APPROVAL: 



Ministry of the Environment
Ministère de l'Environnement

PART 3:

ADVERSE ANALYTICAL RESULTS - For Indicators Listed in SCHEDULE 6 -
Drinking Water Protection Regulation

Microbiological Testing

Laboratory Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) (a.m. : p.m.)	Sample Type / Location	Membrane Filtration Count/100ml			P-A/100ml Presumptive/ Confirmed (if applicable)	IIPCV tml	Date of Analysis (M/D/Y)
				Total Coliforms	Back-ground	E.coli/ Fecal C.			

ADVERSE ANALYTICAL RESULTS - For Parameters Listed in SCHEDULE 4 and 5 or in a C of A or Order
Drinking Water Protection Regulation

Physical/Chemical/Radiological Testing

Laboratory Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) (a.m. : p.m.)	Sample Type/ Location	Parameter	Result	Unit	MAC/ IMAC (Per Sched 6)	Date of Analysis (M/D/Y)
167759		01/28/02 9:20	Treated MCN-04	Na	26	mg/L	20	02/07/02.

Laboratory Results Authorized by:

Christina Hay

For Ministry Use Only:

Occurrence Report #:

Authorization Date:

Feb 4, 2002

TRANSMISSION VERIFICATION REPORT

TIME : 02/07/2002 17:24

DATE, TIME
FAX NO./NAME
DURATION
PAGE(S)
RESULT
MODE

02/07 17:21
16139337930
00:02:27
04
OK
STANDARD

TRANSMISSION VERIFICATION REPORT

TIME : 02/07/2002 17:30

DATE, TIME
FAX NO./NAME
DURATION
PAGE(S)
RESULT
MODE

02/07 17:25
18002686061
00:04:48
09
OK
STANDARD
ECM

QUARTERLY REPORT ON DRINKING WATER QUALITY

January - March 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Moose Creek Drinking Water Quality

Ontario Drinking Water Protection Regulations

The Ontario Clean Water Agency, as the contract operator of the Moose Creek Water Treatment Facility on behalf of the Township of North Stormont, is pleased to present the 2002 First Quarter Report on drinking water quality. This report has been prepared in response to legislative changes brought about by "Operation Clean Water", an initiative of Ontario's Ministry of the Environment to ensure high quality drinking water for the residents of Ontario. The new regulations put into law what was formerly the Ontario Drinking Water Objectives (ODWO), and sets requirements for public waterworks with regard to sampling and testing, levels of treatment, licensing of staff, and notification of authorities and the public about water quality.

Further information on the Ontario Drinking Water Regulations can be found on the Ministry of the Environment web site at www.ene.gov.on.ca

Where to contact us for information



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Web site at www.ocwa.com

Client Services Representative: John Kingsbury Operations Manager: Blair Henderson

Phone : (613) 774-3663

Phone: (613) 448-3098

E-mail Address: jkingsbury@ocwa.com

E-mail Address: bhenderson@ocwa.com

You may also contact the Township of North Stormont directly by contacting Rheal Charbonneau, Clerk-Treasurer, Tel. (613) 984-2821 or e-mail address: norstor@cnwl.igs.net

Free copies of this report are available at the Township office or their website @ www.cnwl.igs.net/~northstormont



INSIDE THIS REPORT

Drinking Water Regulations	1
Where To Contact Us	1
Plant Description & Treatment Processes	2
Quality Control and Compliance with Provincial Regulations	3

QUARTERLY REPORT ON DRINKING WATER QUALITY

January - March 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Definitions & Terms	4
Required Testing	4
Water Quality Test Results	5
Questions & Answers	7

Introduction

We are proud to report that for the period January to March 2002, your water conformed to the Ontario Drinking Water Standards as set out in Ontario Regulation 459/00. The Ontario Clean Water Agency (OCWA) is dedicated to maximizing public health and safety through efficient and reliable operation of your water facility and distribution system.

Plant Description and Treatment Processes

Facility Name:	Moose Creek WTP & Distribution System
Total Design Capacity	896 cubic meters/day
Raw Water Source	Groundwater
Disinfection Method	Sodium Hypochlorite
Municipal Location	Municipal Office, 2 Victoria Street, Berwick, Ontario
Service Area	Village of Moose Creek
Service Population	400

Operational Description:

Raw water source: Three drilled wells located southwest of the water pumping station.

Low Lift Pumps: Three low lift pumps lift the water from the wells to the main pumping station. There is one header that directs the water to the Chlorine Contact Chamber. At this point, Sodium Hypochlorite is added to the raw water for disinfection.

Reservoir: From the Chlorine Contact Chamber the treated water enters a 75 cubic meter underground reservoir.

High Lift Pumps: Two high lift pumps, one duty and one standby, move the treated water from the reservoir into the distribution system and elevated tank.

Elevated Tank: There is approximately 622 cubic meters of water in the elevated water tower located on County Road 15.

Distribution System: There are approximately 400 persons supplied with water from the Moose Creek Water Treatment System.

QUARTERLY REPORT ON DRINKING WATER QUALITY

January - March 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Quality Control & Compliance With Provincial Regulations

This plant provides multiple barriers against bacteriological contamination. Bacteriological testing is carried out on raw water, treated water and distribution samples on a regular frequency. On-line analysers for chlorine residuals and turbidity ensures daily monitoring of water leaving the plant. Chlorine levels in the distribution system are also checked on a regular basis. More specialized testing occurs monthly and quarterly and includes Volatile Organics, Inorganics, Pesticides and PCB's.

OCWA uses internal compliance auditing techniques by teams from within the organization. OCWA operates the Moose Creek Water Treatment Facility in accordance with provincial regulations. Here is how we do it:

- **Use of Accredited Labs.** Analytical tests to monitor your water quality are conducted by a laboratory audited by the Canadian Association for Environmental Analytical Laboratories (CAEAL) and accredited by the Standards Council of Canada (SCC). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods.
- **Operation by Licensed Operators.** Your water treatment plant is operated and maintained by the Ontario Clean Water Agency's competent and licensed staff. The mandatory licensing program for operators of drinking water facilities is regulated under the *Ontario Water Resources Act (OWRA)* Regulation 435/93. Licensing means that an individual meets the education and experience requirements and has successfully passed the certificate exam.
- **Sampling and Analytical requirements.** OCWA follows a sampling and analysis schedule required by *OWRA* Regulation 459/00, the Ontario Drinking Water Standards. More information on sampling and analysis including results are available in this report and from your municipal office.
- **Adherence to Ministry Guidelines and Procedures.** To ensure the protection of the health and operational excellence, the OCWA adheres to the guidelines and procedures developed by the Ministry of the Environment and the Ministry of Health.

Did We Exceed the Standards?

During this quarter, there were no micro biological parameters that exceeded the MAC/IMAC limits. In respect to Operational Parameters, 16 turbidity exceedences were reported as per Regulation 459/00. These samples are taken continuously in-house by online equipment and these spikes are believed to be caused from the starting and stopping of pumps, equipment maintenance/calibration and/or air and a buildup of iron sediment in the sample lines. During these spikes, the system was being adequately disinfected; therefore, reducing any risks that may be associated with the high turbidity.

QUARTERLY REPORT ON DRINKING WATER QUALITY

January - March 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

During the First Quarter, Sodium was found to exceed the Ontario Drinking Water Standards concentration of 20 mg/L as set out in Ontario Regulation 459/00. The sodium concentrations of the treated water at Moose Creek Well Water System in the first quarter were 26 mg/L and 27 mg/L. The local Medical Officer of Health must be notified when the sodium concentration exceeds 20 mg/L so that this information may be communicated to the local physicians for their use with patients on sodium restricted diets. The aesthetic objective for sodium in drinking water is 200 mg/L at which it can be detected by a salty taste.

As a result we actively undertook the following remedial actions:

Immediately notified the Ministry of Environment and the Ministry of Health as per the Ontario Drinking Water Standards. The result of the first sample was 26 mg/L and as per Reg. 459 re-sampling was initiated and the results were 27 mg/L.

Definitions & Terms

m³ - Cubic Meter, 1m³ = 1000 litres

TCU - True Colour Units

CaCO₃ - Calcium Carbonate

mg - milligram

mg/L - milligrams per litre

ug/L - micrograms per litre

ng/L - nanograms per litre

NTU - Nephelometric Turbidity Units

MAC - Maximum Acceptable Concentration

IMAC - Interim Maximum Acceptable Concentration

Coliform Bacteria - a group of commonly occurring rod shaped bacteria. Their presence in a water sample is indicative of inadequate filtration and/or disinfection.

Fecal Coliform Bacteria - refers to a subgroup of coliform bacteria present in the digestive system of warm blooded animals and humans.

Heterotrophic Plate Count - a method of measuring bacterial content in water samples. Also known as Standard Plate Count.

Organic Parameter - a group of chemical compounds containing carbon.

Inorganic Parameter - a group of chemical compounds not containing carbon.

Raw Water - Surface or ground water available as a source of drinking water that has not received any treatment.

Required Testing

The Ontario Drinking Water Regulations and Certificates of Approval (C of A) set sampling requirements for the plant. All other sampling conforms to the Drinking Water Protection Regulation schedule for sampling and analysis. As water travels over the surface of the land or through the ground,

QUARTERLY REPORT ON DRINKING WATER QUALITY

January - March 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

it dissolves naturally occurring minerals and, in some cases can pick up substances resulting from the presence of animals or from human activity. Your water is extensively tested for the presence of dozens of compounds. The results of all analytical tests are available at your municipal office. The following table lists all compounds analyzed.

Moose Creek Water Quality Test Results

Microbiological Parameters	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence?	Typical Source of Contaminant
Total Coliform (counts/100ml)	0	39	0	01/01-03/31	n/a	no	Indicate possible presence of coliform
Escherichia Coliform (counts/100ml)	0	39	0	01/01-03/31	n/a	no	Definite indicator of fecal contamination
Fecal Coliform (counts/100ml)	0	39	0	01/01-03/31	n/a	no	Indicator of sewage contamination
Heterotrophic Plate Count (counts/100ml)	500	39	2	01/01-03/31	4-40	no	Indicator of deteriorating water quality if greater than 500
Parameters related to Microbiological Quality	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence?	Typical Source of Contaminant
Turbidity (NTU)	1	Continuous	Continuous	01/01-03/31	0.40->5.0	yes	Turbidity is a measure of particles in water
Free Chlorine -- Plant Effluent (mg/l)	-	Continuous	Continuous	01/01-03/31	1.67-2.80	no	Chlorine added for Disinfection
Free Chlorine-Distribution (mg/l min 0.05 & max. 4.0)	-	Grab samples weekly	Weekly	01/01-03/31	0.70-2.20	no	Objective is 0.20 mg/l in the Distribution System (min. 0.05 mg/l required)
Inorganic Parameters (mg/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Lead - Distribution	0.01	1	1	01/21/02	<0.001	no	Leached from lead solder or brass plumbing fixtures
Nitrate	10	1	1	01/21/02	<0.1	no	Natural component of water
Nitrite	1	1	1	01/21/02	<0.1	no	
Arsenic	IMAC= 0.025	1	1	09/19/00	<0.001	no	
Barium	1	1	1	09/19/00	0.24	no	
Boron	IMAC= 5.0	1	1	09/19/00	0.06	no	
Cadmium	0.005	1	1	09/19/00	<0.0001	no	
Chromium (Total)	0.05	1	1	09/19/00	<0.01	no	
Copper	1	1	1	01/21/02	<0.001	no	
Iron	0.3	1	1	01/21/02	0.45	yes	Comments below
Lead	0.01	1	1	09/19/00	<0.001	no	
Manganese	0.05	1	1	01/21/02	0.04	no	
Mercury	0.001	1	1	09/19/00	<0.0001	no	
Selenium	0.01	1	1	09/19/00	<0.001	no	
Uranium	0.1	1	1	09/19/00	<0.001	no	
Sodium	200	1	1	01/28/02-02/13/02	26-27	no	

QUARTERLY REPORT ON DRINKING WATER QUALITY

January - March 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Fluoride	2.4	3	3	01/28/02	0.23	no	
----------	-----	---	---	----------	------	----	--

Comment: Iron may be present in groundwater as a result of mineral deposits and chemically reducing underground conditions. The aesthetic objective for Iron, set by appearance effects in drinking water is 0.3 mg/L. Excessive Iron levels in drinking water supplies may impart a brownish color to laundered goods, plumbing fixtures and the water itself; it may produce a bitter, astringent taste in water and beverages; the precipitation of iron can also promote growth of iron bacteria in water mains and service pipes. The Moose Creek Water Pumping Station has no design features for the removal of Iron.

Volatile Organics (ug/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedance?	Typical Source of Contaminant
Trihalomethanes - Plant	100	2	2	01/21	74.7	no	
Trihalomethanes - Dist.	100	2	2	01/21	52.1	no	
Benzene	5	1	1	01/21	<0.5	no	
Carbon Tetrachloride	5	1	1	01/21	<0.9	no	
Dichloromethane	50	1	1	01/21	<4	no	
1,2 - Dichlorobenzene	200	1	1	01/21	<0.4	no	
1, 4 - Dichlorobenzene	5	1	1	01/21	<0.4	no	
1,2 - Dichloroethane	IMAC=5	1	1	01/21	<0.7	no	
1,1 - Dichloroethylene	14	1	1	01/21	<0.5	no	
Ethylbenzene	24	1	1	01/21	<0.5	no	
Monochlorobenzene	80	1	1	01/21	<0.2	no	
Tetrachloroethylene	30	1	1	01/21	<0.3	no	
Toluene	24	1	1	01/21	<0.5	no	
Trichloroethylene	50	1	1	01/21	<0.3	no	
Vinyl chloride	2	1	1	01/21	<0.5	no	
Xylene	300	2	2	01/21	<2.0	no	
Bromodichloromethane	n/a	1	1	01/21	17.5	no	
Bromoform	n/a	1	1	01/21	<0.4	no	
Chloroform	n/a	1	1	01/21	47.6	no	
Dibromochloromethane	n/a	1	1	01/21	9.6	no	
Pesticides & PCB (ug/L)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedance?	Typical Source of Contaminant
Alachlor	IMAC=5	1	1	01/21	<0.5	no	
Aldicarb	9	1	1	01/21	<5.0	no	
Aldrin+Dieldrin	0.7	1	1	01/21	<0.7	no	
Atrazine	IMAC=5	1	1	01/21	<1.0	no	
Azinphos-methyl	20	1	1	01/21	<2.0	no	
Bendiocarb	40	1	1	01/21	<2.0	no	
Bromoxynil	IMAC=5	1	1	01/21	<0.5	no	
Carbaryl	90	1	1	01/21	<5.0	no	
Carbofuran	90	1	1	01/21	<5.0	no	
Chlordane	7	1	1	01/21	<0.7	no	
Chorpyrifus	90	1	1	01/21	<1.0	no	
Cyanazine	IMAC=10	1	1	01/21	<1.0	no	
Diazon	20	1	1	01/21	<1.0	no	
Dicamba	120	1	1	01/21	<1.0	no	
2,4 Dichlorophenol	900	1	1	01/21	<0.5	no	
DDT + Metapolites	30	1	1	01/21	<3.0	no	

QUARTERLY REPORT ON DRINKING WATER QUALITY

January - March 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

2,4 - Dichlorophenexy acid (2,4 -D)	IMAC=10 0	1	1	01/21	<1.0	no	
Diclofop-methyl	9	1	1	01/21	<0.9	no	
Dimethoate	IMAC=20	1	1	01/21	<2.5	no	
Dinoseb	10	1	1	01/21	<1.0	no	
Diquat	70	1	1	01/21	<7.0	no	
Diuron	150	1	1	01/21	<10.0	no	
Glyphosate	IMAC=28 0	1	1	01/21	<10.0	no	
Heprachlor + Heptachlor epoxide	3	1	1	01/21	<0.3	no	
Lindane	4	1	1	01/21	<0.4	no	
Malathion	190	1	1	01/21	<5.0	no	
Pesticides & PCB (ug/L)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence?	Typical Source of Contaminant
Methoxychlor	900	1	1	01/21	<90.0	no	
Metolachlor	IMAC=50	1	1	01/21	<0.5	no	
Metribuzin	80	1	1	01/21	<5.0	no	
Paraquat	IMAC=10	1	1	01/21	<1.0	no	
Parathion	50	1	1	01/21	<1.0	no	
Pentachlorophenol	60	1	1	01/21	<0.5	no	
Phorate	IMAC=2	1	1	01/21	<0.5	no	
Picloram	IMAC=19 0	1	1	01/21	<5.0	no	
Polychlorinated Biphenyls	IMAC=3	1	1	01/21	<0.3	no	
Prometryne	IMAC=1	1	1	01/21	<0.25	no	
Simazine	IMAC=10	1	1	01/21	<1.0	no	
Temephos	IMAC=28 0	1	1	01/21	<10	no	
Terbufos	IMAC=1	1	1	01/21	<0.7	no	
2,3,4,6 Tetrachlorophenol	100	1	1	01/21	<0.5	no	
Triallate	230	1	1	01/21	<1.0	no	
2,4,6-Trichlorophenol	5	1	1	01/21	<0.5	no	
2,4,5 - trichlorophenoxy acedic acid	IMAC=28 0	1	1	01/21	<1.0	no	
Trifluralin	45	1	1	01/21	<1.0	no	
Additional Parameters Non-Health Related (mg/L)	AO or OG	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence?	Typical Source of Contaminant
Colour	5	1	1	01/28	2	no	
pH	6.8-8.5	1	1	01/28	7.84	no	
Alkalinity	30-500	1	1	01/28	205	no	
Total Hardness	80-100	1	1	01/28	326	yes	Limits are set as an operational guideline
Sulphate	500	1	1	01/28	137	no	
Conductivity	---	1	1	01/28	707	no	
Chloride	250	1	1	01/28	29	no	
Free Ammonia	---	1	1	01/28	<0.02	no	
Total Kjeldahl Nitrogen	---	1	1	01/28	0.1	no	
Dissolved Organic Carbon	5	1	1	01/28	1.9	no	
Sodium	200	1	1	01/28	26	no	

QUARTERLY REPORT ON DRINKING WATER QUALITY

January - March 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Iron	0.3	1	1	01/28	0.45	yes	
Aluminium	0.1	1	1	01/28	<0.05	no	
Manganese	0.05	1	1	01/28	0.04	no	
Ammonia + Ammonium N		1	1	01/28	<0.02	no	
Total Organic Carbon		1	1	01/28	2.1	no	
Copper	1	1	1	01/28	<0.001	no	
Calcium	---	1	1	01/28	86	no	
Magnesium	---	1	1	01/28	27	no	

Questions & Answers

Q. What is an Accredited Laboratory?

A. Accredited labs must have undergone an on-site assessment and performance review of their methods by the Canadian Association of Environmental and Analytical Laboratories. The Standards Council of Canada grants accreditation to the lab based on the recommendation of the CAEAL. The accreditation requirements are repeated every two years.

Q. What had to be done to meet the new regulations?

A. The Moose Creek Water Treatment Plant was following the Ontario Drinking Water Objectives (ODWO) before they became law, so little change was required to meet the new regulations. Our chlorine residual in the water leaving the plant was raised to slightly to achieve the (0.20 mg/L free chlorine) required level in the distribution system, and some changes were required in the way results are reported. This report to the public is also the result of the new regulations.

Q. What parameters did you test for?

A. Microbiological parameters, volatile organic, inorganic and pesticides & PCBs have been tested. The results are included in this report.

Q. Sometimes my water looks rusty or coloured. Why is that, and what should I do about it?

A. This is quite often caused when the tanks in older water heaters start to decay. If the colour is seen only in your hot water, this may be the problem. If the colour is also noticed in your cold water it could be coming from the water main. Various maintenance procedures in the distribution system - such as fire hydrant and valve maintenance, or main break repairs - require flushing of the water mains. Flushing can cause small particles of sediment to break off adding colour to the water. Please note that there is no health risk associated with this problem. This is usually only temporary, and opening your taps for a while to flush out your service line (the pipe from the water main to your house) should take care of the problem. Let the water run until the colour disappears.

Caduceon Enterprises Inc.
Environmental Laboratory

Certificate of Analysis

Client:
Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report: 220000057
Project: Moose Creek WTP
Date Sampled: January 2, 2002
Date Received: January 3, 2002
Date Printed: January 07, 2002
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification					
			Well #1 Raw	Well #2 Raw	Well #3 Raw	Treated Water	Dist. Paul Adams	Dist. SPS
Total Chlorine	mg/L	0.05				2.50	0.80	0.90
Free Chlorine	mg/L	0.05				2.30	0.70	0.80
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent
HPC	/mL	2	absent	absent	absent	absent	4	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent

Caduceon Enterprises Inc.
Environmental Laboratory

Certificate of Analysis

Client:
Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report: 220000172
Project: Moose Creek WTP
Date Sampled: January 7, 2002
Date Received: January 8, 2002
Date Printed: January 10, 2002
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification					
			Well #1 Raw	Well #2 Raw	Well #3 Raw	Treated Water	Dist. Tower	Dist. Mall
Total Chlorine	mg/L	0.05				2.50	1.30	1.40
Free Chlorine	mg/L	0.05				2.30	1.20	1.30
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent
HPC	/mL	2	absent	4	absent	absent	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent

Caduceon Enterprises Inc.
Environmental Laboratory

Certificate of Analysis

Client:
Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: **Dave Markell**

Report: **220000388**
Project: Moose creek WTP
Date Sampled: January 14, 2002
Date Received: January 15, 2002
Date Printed: January 17, 2002
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification					
			Well #1 Raw	Well #2 Raw	Well #3 Raw	Treated Water	Dist. Blair Const.	Dist. 2041 Valley
Total Chlorine	mg/L	0.05				2.50	2.00	1.00
Free Chlorine	mg/L	0.05				2.30	1.80	0.90
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent
HPC	/mL	2	20	absent	2	absent	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent

Caduceon Enterprises Inc.
Environmental Laboratory

Certificate of Analysis

Client:
Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report: 220000613
Project: Moose Creek WTP
Date Sampled: January 21, 2002
Date Received: January 22, 2002
Date Printed: January 25, 2002
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification					
			Well #1 Raw	Well #2 Raw	Well #3 Raw	Treated Water	Dist. SPS	Dist. Mall
Total Chlorine	mg/L	0.05				2.20	1.60	2.10
Free Chlorine	mg/L	0.05				2.00	1.40	2.00
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent
HPC	/mL	2	absent	absent	2	absent	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent

Caduceon Enterprises Inc.
Environmental Laboratory

Certificate of Analysis

Client:
Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report: 220000787
Project: Moose Creek WTP
Date Sampled: January 28, 2002
Date Received: January 29, 2002
Date Printed: January 31, 2002
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification					
			Well #1 Raw	Well #2 Raw	Well #3 Raw	Treated Water	Dist. Paul Adam	Dist. 2041 Valley
Total Chlorine	mg/L	0.05				2.50	1.80	1.20
Free Chlorine	mg/L	0.05				2.30	1.70	1.20
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent
HPC	/mL	2	absent	absent	10	absent	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent

ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number: 2200719
Date: 2002-01-25
Date Submitted: 2002-01-22

ATT: Mr. Blair Henderson

Project: Moose Creek Wells
Quarterly Chemicals

P.O. Number:
Matrix: Supply Water

LAB ID:			167007				
Sample Date:			2002-01-21				
Sample ID:			Treated MCW 04				
PARAMETER	UNITS	MDL					
BTEX / 624 / PURGEABLE HYDROCARBONS							
Benzene	ug/L	0.5	<0.5 ✓	<i>One</i>			
Toluene	ug/L	0.5	<0.5 ✓				
Ethylbenzene	ug/L	0.5	<0.5 ✓				
m/p-xylene	ug/L	1.0	<1.0 ✓				
o-xylene	ug/L	0.5	<0.5 ✓				
Bromodichloromethane	ug/L	0.3	17.5 ✓				
Bromoform	ug/L	0.4	<0.4 ✓				
Carbon Tetrachloride	ug/L	0.9	<0.9 ✓				
Monochlorobenzene	ug/L	0.2	<0.2 ✓				
Chloroform	ug/L	0.5	47.6 ✓				
Dibromochloromethane	ug/L	0.3	9.6 ✓				
1,2-dichlorobenzene	ug/L	0.4	<0.4 ✓				
1,4-dichlorobenzene	ug/L	0.4	<0.4 ✓				
1,2-dichloroethane	ug/L	0.7	<0.7 ✓				
1,1-dichloroethylene	ug/L	0.5	<0.5 ✓				
Dichloromethane	ug/L	4.0	<4.0 ✓				
Tetrachloroethylene	ug/L	0.3	<0.3 ✓				
Trichloroethylene	ug/L	0.3	<0.3 ✓				
Vinyl Chloride	ug/L	0.5	<0.5 ✓				
TOTALS							
Trihalomethanes (total)	ug/L	2.0	74.7 ✓				
Xylene; total	ug/L	2.0	<2.0 ✓				
BTEX / 624 Surrogate Recoveries							
Toluene-d8	%		96				
1,2-dichloroethane-d4	%		106				
4-bromofluorobenzene	%		110				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL:

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

ATT: Mr. Blair Henderson

Report Number:

2200719

Date:

2002-01-29

Date Submitted:

2002-01-22

Project:

Moose Creek Wells - Qrtly

P.O. Number:

Matrix:

Supply Water


LAB ID: Sample Date: Sample ID:				167007				
				2002-01-21				
				Treated MCW-04				
PARAMETER		UNITS	MDL	TREATEDWATER				
N-NO2		mg/L	0.10	<0.10 ✓	Dave			
N-NO3		mg/L	0.10	<0.10 ✓				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL:



ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: Moose Creek Well Supply

Report Number:

2200719

Date:

2002-03-12

Date Submitted:

2002-01-22

ATT: Mr. Blair Henderson

Project:

Moose Creek Wells
Quarterly Chemicals
Supply Water

Sample Matrix:


LAB ID:			167007				
Sample Date:			2002-01-21				
Sample ID:			Treated MCW 04				
PARAMETER	UNITS	MDL					
PESTICIDES & PCB's							
Alachlor	mg/L	0.0005	<0.0005				
Aldicarb	mg/L	0.0050	<0.0050				
Aldrin + Dieldrin	mg/L	0.00007	<0.00007				
Atrazine	mg/L	0.001	<0.001				
Azinphos-methyl	mg/L	0.002	<0.002				
Bendiocarb	mg/L	0.0020	<0.0020				
Bromoxynil	mg/L	0.0005	<0.0005				
Carbaryl	mg/L	0.0050	<0.0050				
Carbofuran	mg/L	0.0050	<0.0050				
Chlordane (Total)	mg/L	0.0007	<0.0007				
Chlorpyrifos	mg/L	0.0010	<0.0010				
Cyanazine	mg/L	0.0010	<0.0010				
Diazinon	mg/L	0.0010	<0.0010				
Dicamba	mg/L	0.0010	<0.0010				
Diquat	mg/L	0.0070	<0.0070				
2,4-Dichlorophenol	mg/L	0.0005	<0.0005				
DDT	mg/L	0.0030	<0.0030				
2,4-D	mg/L	0.0010	<0.0010				
Diclofop-methyl	mg/L	0.0009	<0.0009				
Dimethoate	mg/L	0.0025	<0.0025				
Dinoseb	mg/L	0.0010	<0.0010				
Diuron	mg/L	0.010	<0.010				
Glyphosate	mg/L	0.010	<0.010				
Heptachlor + Hept. Epoxide	mg/L	0.0003	<0.0003				
Lindane (Total)	mg/L	0.0004	<0.0004				
Malathion	mg/L	0.0050	<0.0050				
Methoxychlor	mg/L	0.0900	<0.0900				
Metolachlor	mg/L	0.0005	<0.0005				

ND = Not Detected (< MDL)

MDL = Method Detection Limit

Comment:

APPROVAL:



ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: Moose Creek Well Supply

Report Number:

2200719

Date:

2002-03-12

Date Submitted:

2002-01-22

ATT: Mr. Blair Henderson

Project:

Moose Creek Wells
Quarterly Chemicals

Sample Matrix:

Supply Water

LAB ID: 167007
Sample Date: 2002-01-21
Sample ID: Treated MCW
04


PARAMETER	UNITS	MDL				
Metribuzin	mg/L	0.005	<0.005			
Paraquat	mg/L	0.0010	<0.0010			
Parathion	mg/L	0.0010	<0.0010			
Pentachlorophenol	mg/L	0.0005	<0.0005			
Phorate	mg/L	0.0005	<0.0005			
Picloram	mg/L	0.0050	<0.0050			
PCB's (total)	mg/L	0.0003	<0.0003			
Prometryne	mg/L	0.00025	<0.00025			
Simazine	mg/L	0.0010	<0.0010			
Chlorpyrifos	mg/L	0.010	<0.010			
Alachlor	mg/L	0.0007	<0.0007			
2,3,4,6-Tetrachlorophenol	mg/L	0.0005	<0.0005			
Triallate	mg/L	0.0010	<0.0010			
2,4,6-Trichlorophenol	mg/L	0.0005	<0.0005			
Trifluralin	mg/L	0.0010	<0.0010			
2,4,5-T	mg/L	0.0010	<0.0010			

ND = Not Detected (< MDL)

MDL = Method Detection Limit

Comment:

APPROVAL:



ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

ATT: Mr. Blair Henderson

Report Number:

2201011

Date:

2002-02-07

Date Submitted:

2002-01-29

Project:

Moose Creek Wells Qtly

P.O. Number:

Matrix:

Supply Water

			LAB ID:	167761	167762	167763		
			Sample Date:	2002-01-28	2002-01-28	2002-01-28		
			Sample ID:	Raw MCW-01	Raw MCW-02	Raw MCW-03		
PARAMETER	UNITS	MDL	RAW WATER	RAW WATER	RAW WATER			
Alkalinity as CaCO ₃	mg/L	5	226	212	201			
Al	mg/L	0.05	0.06	<0.05	<0.05			
Ca	mg/L	1	109	98	83			
Cl	mg/L	1	23	14	32			
Conductivity	uS/cm	5	721	672	724			
Colour	TCU	2	6	4	4			
Cu	mg/L	0.001	<0.001	<0.001	<0.001			
DOC	mg/L	0.5	2.6	1.7	1.4			
Fe	mg/L	0.01	0.49	0.26	0.27			
Hardness as CaCO ₃	mg/L	1	367	352	347			
	mg/L	1	23	26	34			
Mn	mg/L	0.01	0.09	0.04	0.03			
N-NH ₃	mg/L	0.02	0.10	0.27	0.38			
N-NH ₃ (unionized)	mg/L	0.02	<0.02	<0.02	<0.02			
N-NO ₂	mg/L	0.10	<0.10	<0.10	<0.10			
N-NO ₃	mg/L	0.10	<0.10	<0.10	<0.10			
pH			7.88	8.08	7.98			
Na	mg/L	2	16	14	25			
SO ₄	mg/L	1	133	141	148			
Total Kjeldahl Nitrogen	mg/L	0.05	0.36	0.53	0.65			
TOC	mg/L	0.5	3.6	2.0	1.8			

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL:



ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number:

2201009

Date:

2002-02-08

Date Submitted:

2002-01-29

ATT: Mr. Blair Henderson

Project:

Moose Creek Wells Qtly

P.O. Number:

Matrix:

Supply Water

LAB ID:			167759				
Sample Date:			2002-01-28				
Sample ID:			Treated MCW-04				
PARAMETER	UNITS	MDL	TREATEDWATER				
Alkalinity as CaCO ₃	mg/L	5	205 ✓	<i>Done</i>			
Al	mg/L	0.05	<0.05 ✓				
Ca	mg/L	1	86 ✓				
Cl	mg/L	1	29 ✓				
Conductivity	uS/cm	5	707 ✓				
Colour	TCU	2	2 ✓				
Cu	mg/L	0.001	<0.001 ✓				
DOC	mg/L	0.5	1.9 ✓				
F	mg/L	0.10	0.23 ✓				
Fe	mg/L	0.01	0.45 ✓				
H ₂ O ₂ as CaCO ₃	mg/L	1	326 ✓				
Mg	mg/L	1	27 ✓				
Mn	mg/L	0.01	0.04 ✓				
N-NH ₃	mg/L	0.02	<0.02 ✓				
N-NH ₃ (unionized)	mg/L	0.02	<0.02 ✓				
pH			7.84 ✓				
Na	mg/L	2	26 ✓				
SO ₄	mg/L	1	137 ✓				
Total Kjeldahl Nitrogen	mg/L	0.05	0.10 ✓				
TOC	mg/L	0.5	2.1 ✓				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL:



ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number: 2200721
Date: 2002-01-25
Date Submitted: 2002-01-22

ATT: Mr. Blair Henderson

Project: Moose Creek System

P.O. Number:

Matrix: Supply Water

LAB ID:			167009				
Sample Date:			2002-01-21				
Sample ID:			MCW-System SPS#1				
PARAMETER	UNITS	MDL					
BTEX / 624 / PURGEABLE HYDROCARBONS							
Bromodichloromethane	ug/L	0.3	13.7				
Bromoform	ug/L	0.4	<0.4				
Chloroform	ug/L	0.5	33.9				
Dibromochloromethane	ug/L	0.3	4.5				
TOTALS							
Trihalomethanes (total)	ug/L	2.0	52.1 ✓	<i>Done</i>			
BTEX / 624 Surrogate Recoveries							
Toluene-d8	%		101				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL:

ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

ATT: Mr. Blair Henderson

Report Number:

2200721

Date:

2002-01-29

Date Submitted:

2002-01-22

Project:

Moose Creek System

P.O. Number:

Matrix:

Supply Water


LAB ID:			167009				
Sample Date:			2002-01-21				
Sample ID:			MCW-System SPS#1				
PARAMETER	UNITS	MDL	TREATEDWATER				
Pb	mg/L	0.001	<0.001	✓ <i>Done</i>			

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL: _____



Caduceon Enterprises Inc.
Environmental Laboratory

Certificate of Analysis

Client:
Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report: 220000966
Project: Mosse Creek WTP
Date Sampled: February 4, 2002
Date Received: February 5, 2002
Date Printed: February 07, 2002
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification					
			Well #1 Raw	Well #2 Raw	Well #3 Raw	Treated Water	Dist. SPS	Dist. Mail
Total Chlorine	mg/L	0.05				2.30	1.60	2.00
Free Chlorine	mg/L	0.05				2.00	1.50	1.80
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent
HPC	/mL	2	absent	absent	absent	absent	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent

Caduceon Enterprises Inc.
Environmental Laboratory

Certificate of Analysis

Client:
Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report: 220001204
Project: Moose Creek WTP
Date Sampled: February 11, 2002
Date Received: February 12, 2002
Date Printed: February 14, 2002
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification					
			Well #1 Raw	Well #2 Raw	Well #3 Raw	Treated Water	Dist. Blair Const.	Dist. 2041 Valley
Total Chlorine	mg/L	0.05				2.50	2.30	1.30
Free Chlorine	mg/L	0.05				2.20	2.20	1.20
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent
HPC	/mL	2	absent	absent	absent	absent	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: Dave Markell

Report:

220001421

Project:

Moose Creek WTP

Date Sampled:

February 18, 2002

Date Received:

February 19, 2002

Date Printed:

February 21, 2002

Matrix:

Drinking Water

Parameter	Unit	MDL	Sample Identification					
			Well #1 Raw	Well #2 Raw	Well #3 Raw	Treated Water	Dist. Water Tower	Dist. Paul Adam
Total Chlorine	mg/L	0.05				2.30	1.80	1.50
Free Chlorine	mg/L	0.05				1.90	1.70	1.20
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent
HPC	/mL	2	absent	absent	2	absent	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: Dave Markell

Report:

220001626

Project:

Moose Creek WTP

Date Sampled:

February 25, 2002

Date Received:

February 26, 2002

Date Printed:

February 28, 2002

Matrix:

Drinking Water

Parameter	Unit	MDL	Sample Identification					
			Well #1 Raw	Well #2 Raw	Well #3 Raw	Treated Water	Dist. Post Office	Dist. 35 Sineor Lane
Total Chlorine	mg/L	0.05				2.50	1.70	1.10
Free Chlorine	mg/L	0.05				2.30	1.40	1.00
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent
HPC	/mL	2	absent	absent	absent	absent	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent

REPORT OF ANALYSIS

Report Number: 2201834
Date: 2002-02-20
Date Submitted: 2002-02-14

Project: Moose Creek Wells

P.O. Number:
Matrix: Supply Water

MDL = Method Detection Limit
Comment:

APPROVAL:

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report:

220001903

Project:

Moose Creek WTP

Date Sampled:

March 4, 2002

Date Received:

March 5, 2002

Date Printed:

March 07, 2002

Matrix:

Drinking Water

Parameter	Unit	MDL	Sample Identification					
			Well #1 Raw	Well #2 Raw	Well #3 Raw	Treated Water	Dist. 2041 Valley	Dist. Mall
Total Chlorine	mg/L	0.05				2.50	1.50	1.30
Free Chlorine	mg/L	0.05				1.80	1.50	1.20
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent
HPC	/mL	2	absent	absent	absent	absent	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: Dave Markell

Report:

220002209

Project:

Moose Creek WTP

Date Sampled:

March 11, 2002

Date Received:

March 12, 2002

Date Printed:

March 14, 2002

Matrix:

Drinking Water

Parameter	Unit	MDL	Sample Identification						
-----------	------	-----	-----------------------	--	--	--	--	--	--

			Well #1 Raw	Well #2 Raw	Well #3 Raw	Treated Water	Dist. SPS	Dist. Water Tower
Total Chlorine	mg/L	0.05				2.30	1.60	1.60
Free Chlorine	mg/L	0.05				2.00	1.50	1.40
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent
HPC	/mL	2	absent	absent	absent	absent	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent

Client:

Ontario Clean Water Agency
 5 Industrial Dr.
 Chesterville, ON
 K0C 1H0

Report:

220002451

Project:

Moose Creek WTP

Date Sampled:

March 18, 2002

Date Received:

March 19, 2002

Date Printed:

March 21, 2002

Matrix:

Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification				Treated Water	Dist. Mall	Dist. 10241 Valley N
			Well #1 Raw	Well #2 Raw	Well #3 Raw				
Total Chlorine	mg/L	0.05					2.60	1.60	1.50
Free Chlorine	mg/L	0.05					2.30	1.40	1.20
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent	absent
HPC	/mL	2	absent	absent	absent	absent	absent	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.


Certificate of Analysis

Client:
Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report: 220002712
Project: Moose Creek WTP
Date Sampled: March 25, 2002
Date Received: March 26, 2002
Date Printed: April 01, 2002
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification					
			Well #1 Raw	Well #2 Raw	Well #3 Raw	Treated Water	Dist. Tower	Dist. 2041 Valley
Total Chlorine	mg/L	0.05				2.20	1.50	1.30
Free Chlorine	mg/L	0.05				1.90	1.30	1.10
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent
HPC	/mL	2	absent	absent	absent	40	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent


Michael Ziebell, General Manager

QUARTERLY REPORT ON DRINKING WATER QUALITY

April - June 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Moose Creek Drinking Water Quality

Ontario Drinking Water Protection Regulations

The Ontario Clean Water Agency, as the contract operator of the Moose Creek Water Treatment Facility on behalf of the Township of North Stormont, is pleased to present the 2002 Second Quarter Report on drinking water quality. This report has been prepared in response to legislative changes brought about by "Operation Clean Water", an initiative of Ontario's Ministry of the Environment to ensure high quality drinking water for the residents of Ontario. The new regulations put into law what was formerly the Ontario Drinking Water Objectives (ODWO), and sets requirements for public waterworks with regard to sampling and testing, levels of treatment, licensing of staff, and notification of authorities and the public about water quality.

Further information on the Ontario Drinking Water Regulations can be found on the Ministry of the Environment web site at www.ene.gov.on.ca

Where to contact us for information



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Web site at www.ocwa.com

Client Services Representative: John Kingsbury Operations Manager: Blair Henderson

Phone : (613) 774-3663

Phone: (613) 448-3098

E-mail Address: jkingsbury@ocwa.com

E-mail Address: bhenderson@ocwa.com

You may also contact the Township of North Stormont directly by contacting Rheal Charbonneau, Clerk-Treasurer, Tel. (613) 984-2821 or e-mail address: admin@northstormont.on.ca

Free copies of this report are available at the Township office or their website @ www.townshipofnorthstormont.on.ca



INSIDE THIS REPORT

Drinking Water Regulations	1
Where To Contact Us	1
Plant Description & Treatment Processes	2
Quality Control and Compliance with Provincial Regulations	3
Definitions & Terms	4
Required Testing	4
Water Quality Test Results	5
Questions & Answers	8

QUARTERLY REPORT ON DRINKING WATER QUALITY

April - June 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Introduction

We are proud to report that for the period April to June 2002, your water conformed to the Ontario Drinking Water Standards as set out in Ontario Regulation 459/00. The Ontario Clean Water Agency (OCWA) is dedicated to maximizing public health and safety through efficient and reliable operation of your water facility and distribution system.

Plant Description and Treatment Processes

Facility Name:	Moose Creek WTP & Distribution System
Total Design Capacity	896 cubic meters/day
Raw Water Source	Groundwater
Disinfection Method	Sodium Hypochlorite
Municipal Location	Municipal Office, 2 Victoria Street, Berwick, Ontario
Service Area	Village of Moose Creek
Service Population	400

Operational Description:

Raw water source: Three drilled wells located southwest of the water pumping station.

Low Lift Pumps: Three low lift pumps lift the water from the wells to the main pumping station. There is one header that directs the water to the Chlorine Contact Chamber. At this point, Sodium Hypochlorite is added to the raw water for disinfection.

Reservoir: From the Chlorine Contact Chamber the treated water enters a 75 cubic meter underground reservoir.

High Lift Pumps: Two high lift pumps, one duty and one standby, move the treated water from the reservoir into the distribution system and elevated tank.

Elevated Tank: There is approximately 622 cubic meters of water in the elevated water tower located on County Road 15.

Distribution System: There are approximately 400 persons supplied with water from the Moose Creek Water Treatment System.

QUARTERLY REPORT ON DRINKING WATER QUALITY

April - June 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Quality Control & Compliance With Provincial Regulations

This plant provides multiple barriers against bacteriological contamination. Bacteriological testing is carried out on raw water, treated water and distribution samples on a regular frequency. On-line analysers for chlorine residuals and turbidity ensures daily monitoring of water leaving the plant. Chlorine levels in the distribution system are also checked on a regular basis. More specialized testing occurs monthly and quarterly and includes Volatile Organics, Inorganics, Pesticides and PCB's.

OCWA uses internal compliance auditing techniques by teams from within the organization. OCWA operates the Moose Creek Water Treatment Facility in accordance with provincial regulations. Here is how we do it:

- **Use of Accredited Labs.** Analytical tests to monitor your water quality are conducted by a laboratory audited by the Canadian Association for Environmental Analytical Laboratories (CAEAL) and accredited by the Standards Council of Canada (SCC). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods.
- **Operation by Licensed Operators.** Your water treatment plant is operated and maintained by the Ontario Clean Water Agency's competent and licensed staff. The mandatory licensing program for operators of drinking water facilities is regulated under the *Ontario Water Resources Act (OWRA)* Regulation 435/93. Licensing means that an individual meets the education and experience requirements and has successfully passed the certificate exam.
- **Sampling and Analytical requirements.** OCWA follows a sampling and analysis schedule required by *OWRA* Regulation 459/00, the Ontario Drinking Water Standards. More information on sampling and analysis including results are available in this report and from your municipal office.
- **Adherence to Ministry Guidelines and Procedures.** To ensure the protection of the health and operational excellence, the OCWA adheres to the guidelines and procedures developed by the Ministry of the Environment and the Ministry of Health.

Did We Exceed the Standards?

During the second quarter, 1 sample from the plant treated water was found to exceed the Ontario Drinking Water Standards as set out in Ontario Regulation 459/00. On June 17, 2002 the plant treated water Total Coliform result was overgrown. As a result we actively undertook the following remedial actions:

Immediately notified the Ministry of Environment and the Ministry of Health as per the Ontario Drinking Water Standards. Ensured a minimum chlorine residual in the distribution of greater than 0.2 mg/L. Subsequent re-sampling indicated no adverse results.

QUARTERLY REPORT ON DRINKING WATER QUALITY

April - June 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

With respect to Operational Parameters, turbidity exceedances were reported as per Regulation 459/00 on 45 separate occasions. These samples are taken continuously in-house by online equipment and the turbidity exceedance spikes are believed to be caused primarily by air entrained in the water during start-up of vertical turbine hi-lift pumps, and/or a buildup of iron sediment in the sample lines. During these spikes, the system was being adequately disinfected; therefore, reducing any risks that may be associated with the high turbidity.

Definitions & Terms

m³ - Cubic Meter, 1m³ = 1000 litres

TCU - True Colour Units

CaCO₃ - Calcium Carbonate

mg - milligram

mg/L - milligrams per litre

ug/L - micrograms per litre

ng/L - nanograms per litre

NTU - Nephelometric Turbidity Units

MAC - Maximum Acceptable Concentration

IMAC - Interim Maximum Acceptable Concentration

Coliform Bacteria - a group of commonly occurring rod shaped bacteria. Their presence in a water sample is indicative of inadequate filtration and/or disinfection.

Fecal Coliform Bacteria - refers to a subgroup of coliform bacteria present in the digestive system of warm blooded animals and humans.

Heterotrophic Plate Count - a method of measuring bacterial content in water samples. Also known as Standard Plate Count.

Organic Parameter - a group of chemical compounds containing carbon.

Inorganic Parameter - a group of chemical compounds not containing carbon.

Raw Water - Surface or ground water available as a source of drinking water that has not received any treatment.

Required Testing

The Ontario Drinking Water Regulations and Certificates of Approval (C of A) set sampling requirements for the plant. All other sampling conforms to the Drinking Water Protection Regulation schedule for sampling and analysis. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases can pick up substances resulting from the presence of animals or from human activity. Your water is extensively tested for the presence of dozens of compounds. The results of all analytical tests are available at your municipal office. The following table lists all compounds analyzed.

QUARTERLY REPORT ON DRINKING WATER QUALITY

April - June 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Moose Creek Water Quality Test Results

Microbiological Parameters	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence?	Typical Source of Contaminant
Total Coliform (counts/100ml)	0	45	1	04/01-06/30	overgrown	yes	Indicate possible presence of coliform
Escherichia Coliform (counts/100ml)	0	45	0	04/01-06/30	n/a	no	Definite indicator of fecal contamination
Fecal Coliform (counts/100ml)	0	45	0	04/01-06/30	n/a	no	Indicator of sewage contamination
Heterotrophic Plate Count (counts/100ml)	500	34	6	04/01-06/30	2-80	no	Indicator of deteriorating water quality if greater than 500
Parameters related to Microbiological Quality	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence?	Typical Source of Contaminant
Turbidity (NTU)	1	Continuous	Continuous	04/01-06/30	0.44->5.0	yes	Turbidity is a measure of particles in water
Free Chlorine - Plant Effluent (mg/l)	-	Continuous	Continuous	04/01-06/30	0.7-2.65	no	Chlorine added for Disinfection
Free Chlorine-Distribution (mg/l min 0.05 & max. 4.0)	-	Grab samples weekly	Weekly	04/01-06/30	0.8-2.2	no	Objective is 0.20 mg/l in the Distribution System (min. 0.05 mg/l required)
Inorganic Parameters (mg/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Lead - Distribution	0.01	1	1	01/21/02	<0.001	no	Leached from lead solder or brass plumbing fixtures
Nitrate	10	1	1	04/11/02	<0.1	no	Natural component of water
Nitrite	1	1	1	04/11/02	<0.1	no	
Arsenic	IMAC= 0.025	1	1	09/19/00	<0.001	no	
Barium	1	1	1	09/19/00	0.24	no	
Boron	IMAC= 5.0	1	1	09/19/00	0.06	no	
Cadmium	0.005	1	1	09/19/00	<0.0001	no	
Chromium (Total)	0.05	1	1	09/19/00	<0.01	no	
Copper	1	1	1	01/21/02	<0.001	no	
Iron	0.3	1	1	01/21/02	0.45	yes	Comments below
Lead	0.01	1	1	09/19/00	<0.001	no	
Manganese	0.05	1	1	01/21/02	0.04	no	
Mercury	0.001	1	1	09/19/00	<0.0001	no	
Selenium	0.01	1	1	09/19/00	<0.001	no	
Uranium	0.1	1	1	09/19/00	<0.001	no	
Sodium	200	1	1	01/28/02-02/13/02	26-27	no	
Fluoride	2.4	3	3	01/28/02	0.23	no	

Comment: Iron may be present in groundwater as a result of mineral deposits and chemically reducing underground conditions. The aesthetic objective for Iron, set by appearance effects in drinking water is 0.3 mg/L. Excessive Iron levels in drinking water supplies may impart a brownish color to laundered goods, plumbing fixtures and the water

QUARTERLY REPORT ON DRINKING WATER QUALITY

April - June 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

itself; it may produce a bitter, astringent taste in water and beverages; the precipitation of iron can also promote growth of iron bacteria in water mains and service pipes. The Moose Creek Water Pumping Station has no design features for the removal of Iron.

Volatile Organics (ug/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Trihalomethanes - Plant	100	2	2	04/11/02	53.6	no	
Trihalomethanes - Dist.	100	2	2	04/11/02	62.7	no	
Benzene	5	1	1	04/11/02	<0.5	no	
Carbon Tetrachloride	5	1	1	04/11/02	<0.9	no	
Dichloromethane	50	1	1	04/11/02	<4	no	
1,2 - Dichlorobenzene	200	1	1	04/11/02	<0.4	no	
1,4 - Dichlorobenzene	5	1	1	04/11/02	<0.4	no	
1,2 - Dichloroethane	IMAC=5	1	1	04/11/02	<0.7	no	
1,1 - Dichloroethylene	14	1	1	04/11/02	<0.5	no	
Ethylbenzene	24	1	1	04/11/02	<0.5	no	
Monochlorobenzene	80	1	1	04/11/02	<0.2	no	
Tetrachloroethylene	30	1	1	04/11/02	<0.3	no	
Toluene	24	1	1	04/11/02	<0.5	no	
Trichloroethylene	50	1	1	04/11/02	<0.3	no	
Vinyl chloride	2	1	1	04/11/02	<0.5	no	
Xylene	300	2	2	04/11/02	<2.0	no	
Bromodichloromethane	n/a	1	1	04/11/02	15.2	no	
Bromoform	n/a	1	1	04/11/02	<0.4	no	
Chloroform	n/a	1	1	04/11/02	34.3	no	
Dibromochloromethane	n/a	1	1	04/11/02	4.1	no	
Pesticides & PCB (ug/L)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Alachlor	IMAC=5	1	1	04/11/02	<0.5	no	
Aldicarb	9	1	1	04/11/02	<5.0	no	
Aldrin+Dieldrin	0.7	1	1	04/11/02	<0.7	no	
Atrazine	IMAC=5	1	1	04/11/02	<1.0	no	
Azinphos-methyl	20	1	1	04/11/02	<2.0	no	
Bendiocarb	40	1	1	04/11/02	<2.0	no	
Bromoxynil	IMAC=5	1	1	04/11/02	<0.5	no	
Carbaryl	90	1	1	04/11/02	<5.0	no	
Carbofuran	90	1	1	04/11/02	<5.0	no	
Chlordane	7	1	1	04/11/02	<0.7	no	
Chorpyrifus	90	1	1	04/11/02	<1.0	no	
Cyanazine	IMAC=10	1	1	04/11/02	<1.0	no	
Diaznon	20	1	1	04/11/02	<1.0	no	
Dicamba	120	1	1	04/11/02	<1.0	no	
2,4 Dichlorophenol	900	1	1	04/11/02	<0.5	no	
DDT + Metapolites	30	1	1	04/11/02	<3.0	no	
2,4 - Dichlorophenexy acid (2,4 -D)	IMAC=10 0	1	1	04/11/02	<1.0	no	
Diclofop-methyl	9	1	1	04/11/02	<0.9	no	
Dimethoate	IMAC=20	1	1	04/11/02	<2.5	no	
Dinoseb	10	1	1	04/11/02	<1.0	no	
Diquat	70	1	1	04/11/02	<7.0	no	

QUARTERLY REPORT ON DRINKING WATER QUALITY

April - June 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Diuron	150	1	1	04/11/02	<10.0	no	
Glyphosate	IMAC=28 0	1	1	04/11/02	<10.0	no	
Heprachlor + Heptachlor epoxide	3	1	1	04/11/02	<0.3	no	
Pesticides & PCB (ug/L)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Lindane	4	1	1	04/11/02	<0.4	no	
Malathion	190	1	1	04/11/02	<5.0	no	
Methoxychlor	900	1	1	04/11/02	<90.0	no	
Metolachlor	IMAC=50	1	1	04/11/02	<0.5	no	
Metribuzin	80	1	1	04/11/02	<5.0	no	
Paraquat	IMAC=10	1	1	04/11/02	<1.0	no	
Parathion	50	1	1	04/11/02	<1.0	no	
Pentachlorophenol	60	1	1	04/11/02	<0.5	no	
Phorate	IMAC=2	1	1	04/11/02	<0.5	no	
Picloram	IMAC=19 0	1	1	04/11/02	<5.0	no	
Polychlorinated Biphenyls	IMAC=3	1	1	04/11/02	<0.3	no	
Prometryne	IMAC=1	1	1	04/11/02	<0.25	no	
Simazine	IMAC=10	1	1	04/11/02	<1.0	no	
Temephos	IMAC=28 0	1	1	04/11/02	<10	no	
Terbufos	IMAC=1	1	1	04/11/02	<0.7	no	
2,3,4,6 Tetrachlorophenol	100	1	1	04/11/02	<0.5	no	
Triallate	230	1	1	04/11/02	<1.0	no	
2,4,6-Trichlorophenol	5	1	1	04/11/02	<0.5	no	
2,4,5 - trichlorophenoxy acetic acid	IMAC=28 0	1	1	04/11/02	<1.0	no	
Trifluralin	45	1	1	04/11/02	<1.0	no	
Additional Parameters Non-Health Related (mg/L)	AO or OG	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Colour	5	1	1	01/28/02	2	no	
pH	6.8-8.5	1	1	01/28/02	7.84	no	
Alkalinity	30-500	1	1	01/28/02	205	no	
Total Hardness	80-100	1	1	01/28/02	326	yes	Limits are set as an operational guideline
Sulphate	500	1	1	01/28/02	137	no	
Conductivity	---	1	1	01/28/02	707	no	
Chloride	250	1	1	01/28/02	29	no	
Free Ammonia	---	1	1	01/28/02	<0.02	no	
Total Kjeldahl Nitrogen	---	1	1	01/28/02	0.1	no	
Dissolved Organic Carbon	5	1	1	01/28/02	1.9	no	
Sodium	200	1	1	01/28/02	26	no	
Iron	0.3	1	1	01/28/02	0.45	yes	
Aluminium	0.1	1	1	01/28/02	<0.05	no	
Manganese	0.05	1	1	01/28/02	0.04	no	
Ammonia + Ammonium N		1	1	01/28/02	<0.02	no	
Total Organic Carbon		1	1	01/28/02	2.1	no	
Copper	1	1	1	01/28/02	<0.001	no	
Calcium	---	1	1	01/28/02	86	no	
Magnesium	---	1	1	01/28/02	27	no	

QUARTERLY REPORT ON DRINKING WATER QUALITY

April - June 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Questions & Answers

Q. What is an Accredited Laboratory?

A. Accredited labs must have undergone an on-site assessment and performance review of their methods by the Canadian Association of Environmental and Analytical Laboratories. The Standards Council of Canada grants accreditation to the lab based on the recommendation of the CAEAL. The accreditation requirements are repeated every two years.

Q. What had to be done to meet the new regulations?

A. The Moose Creek Water Treatment Plant was following the Ontario Drinking Water Objectives (ODWO) before they became law, so little change was required to meet the new regulations. Our chlorine residual in the water leaving the plant was raised to slightly to achieve the (0.20 mg/L free chlorine) required level in the distribution system, and some changes were required in the way results are reported. This report to the public is also the result of the new regulations.

Q. What parameters did you test for?

A. Microbiological parameters, volatile organic, inorganic and pesticides & PCBs have been tested. The results are included in this report.

Q. Sometimes my water looks rusty or coloured. Why is that, and what should I do about it?

A. This is quite often caused when the tanks in older water heaters start to decay. If the colour is seen only in your hot water, this may be the problem. If the colour is also noticed in your cold water it could be coming from the water main. Various maintenance procedures in the distribution system - such as fire hydrant and valve maintenance, or main break repairs - require flushing of the water mains. Flushing can cause small particles of sediment to break off adding colour to the water. Please note that there is no health risk associated with this problem. This is usually only temporary, and opening your taps for a while to flush out your service line (the pipe from the water main to your house) should take care of the problem. Let the water run until the colour disappears.

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: **Dave Markell**

Report:

220002970

Project:

Moose Creek WTP

Date Sampled:

April 2, 2002

Date Received:

April 3, 2002

Date Printed:

April 05, 2002

Matrix:

Drinking Water

Parameter	Unit	MDL	Sample Identification					
			Well #1 Raw	Well #2 Raw	Well #3 Raw	Treated Water	Dist. Paul Adam	Dist. Water Tower
Total Chlorine	mg/L	0.05				2.30	1.00	1.40
Free Chlorine	mg/L	0.05				2.10	0.80	1.30
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent
HPC	/mL	2	absent	4	absent	absent	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: Dave Markell

Report:

220003202

Project:

Moose Creek WTP

Date Sampled:

April 8, 2002

Date Received:

April 9, 2002

Date Printed:

April 11, 2002

Matrix:

Drinking Water

Parameter	Unit	MDL	Sample Identification					
-----------	------	-----	-----------------------	--	--	--	--	--

			Well #1 Raw	Well #2 Raw	Well #3 Raw	Treated Water	Dist. Simeon Lane	Dist. Post Office
Total Chlorine	mg/L	0.05				1.90	1.20	1.00
Free Chlorine	mg/L	0.05				1.60	1.00	0.80
E. coli	/100mL	1	absent	absent	absent	absent	absent	absent
Fecal Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent
HPC	/mL	2	absent	absent	2	absent	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
Industrial Dr.
Chesterville, ON
K0C 1H0

Report:

220003481

Project:

Moose Creek WTP

Date Sampled:

April 15, 2002

Date Received:

April 16, 2002

Date Printed:

April 18, 2002

Attention: Dave Markell

Matrix:

Drinking Water

Parameter	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	0.05	2	1	0.05
Sample ID					
Well #1 Raw	absent		absent	absent	
Well #2 Raw	absent		absent	absent	
Well #3 Raw	absent		absent	absent	
Treated Water	absent	1.80	10	absent	2.00
Dist. 2041 Valley	absent	0.80	absent	absent	0.90
Dist. Fire Hall	absent	1.40	8	absent	1.70

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:
Municipality of Kawartha
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report: 220003771
Project: Moose Creek WTP
Date Sampled: April 22, 2002
Date Received: April 23, 2002
Date Printed: April 25, 2002
Matrix: Drinking Water

Parameter	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	0.05	2	1	0.05

Sample ID

Well #1 Raw	absent		absent	absent	
Well #2 Raw	absent		absent	absent	
Well #3 Raw	absent		absent	absent	
Treated Water	absent	1.90	absent	absent	2.20
Dist. Water Tower	absent	0.90	80	absent	1.10
Dist. SPS	absent	0.90	absent	absent	1.10

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Report:

220004026

Project:

Moose Creek WTP

Date Sampled:

April 29, 2002

Date Received:

April 30, 2002

Date Printed:

May 02, 2002

Attention: Dave Markell

Matrix:

Drinking Water

Parameter	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	0.05	2	1	0.05
Sample ID					
Well #1 Raw	absent			absent	
Well #2 Raw	absent			absent	
Well #3 Raw	absent			absent	
Treated Water	absent	1.60	absent	absent	1.90
Dist. Sewage Plant	absent	0.80	absent	absent	1.00
Dist. Post Office	absent	1.10		absent	1.40

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number: 2204305
Date: 2002-04-17
Date Submitted: 2002-04-12

ATT: Mr. Blair Henderson

Project: Moose Creek - Quarterly Chem

P.O. Number:
Matrix: Supply Water

LAB ID:			176594				
Sample Date:			2002-04-11				
Sample ID:			MCW-04				
PARAMETER	UNITS	MDL					
BTEX / 624 / PURGEABLE HYDROCARBONS							
Bromodichloromethane	ug/L	0.3	16.7				
Bromoform	ug/L	0.4	<0.4				
Chloroform	ug/L	0.5	40.8				
Dibromochloromethane	ug/L	0.3	5.2				
TOTALS							
Trihalomethanes (total)	ug/L	2.0	62.7 ✓				
BTEX / 624 Surrogate Recoveries							
ene-d8	%		98				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL: 

ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

ATT: Mr. Blair Henderson

Report Number:

2204292

Date:

2002-04-19

Date Submitted:

2002-04-12

Project:

Moose Creek-Quarterly

P.O. Number:

Matrix:

Supply Water

LAB ID: Sample Date: Sample ID:			176577				
			2002-04-11				
			MCW-04 Treated				
PARAMETER	UNITS	MDL	TREATEDWATER				
N-NO2	mg/L	0.10	<0.10				
N-NO3	mg/L	0.10	<0.10				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL:



ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number: 2204292
Date: 2002-04-17
Date Submitted: 2002-04-12

ATT: Mr. Blair Henderson

Project: Moose Creek - Quarterly Chem

P.O. Number:
Matrix: Supply Water

LAB ID:			176577				
Sample Date:			2002-04-11				
Sample ID:			MCW-04 Treated				
PARAMETER	UNITS	MDL					
BTEX / 624 / PURGEABLE HYDROCARBONS							
Benzene	ug/L	0.5	<0.5				
Toluene	ug/L	0.5	<0.5				
Ethylbenzene	ug/L	0.5	<0.5				
m/p-xylene	ug/L	1.0	<1.0				
o-xylene	ug/L	0.5	<0.5				
Bromodichloromethane	ug/L	0.3	15.2				
Bromoform	ug/L	0.4	<0.4				
Carbon Tetrachloride	ug/L	0.9	<0.9				
Monochlorobenzene	ug/L	0.2	<0.2				
Chloroform	ug/L	0.5	34.3				
Dibromochloromethane	ug/L	0.3	4.1				
1,2-dichlorobenzene	ug/L	0.4	<0.4				
1,4-dichlorobenzene	ug/L	0.4	<0.4				
1,2-dichloroethane	ug/L	0.7	<0.7				
1,1-dichloroethylene	ug/L	0.5	<0.5				
Dichloromethane	ug/L	4.0	<4.0				
Tetrachloroethylene	ug/L	0.3	<0.3				
Trichloroethylene	ug/L	0.3	<0.3				
Vinyl Chloride	ug/L	0.5	<0.5				
TOTALS							
Trihalomethanes (total)	ug/L	2.0	53.6				
Xylene; total	ug/L	2.0	<2.0				
BTEX / 624 Surrogate Recoveries							
Toluene-d8	%		98				
1,2-dichloroethane-d4	%		85				
4-bromofluorobenzene	%		102				

MDL = Method Detection Limit
Comment:

INC = Incomplete

APPROVAL: 

ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: Moose Creek Well Supply

Report Number: 2204292
Date: 2002-06-10
Date Submitted: 2002-04-12

ATT: Mr. Blair Henderson

Project: Moose Creek - Quarterly

Sample Matrix: Supply Water

LAB ID: 176577						
Sample Date: 2002-04-11						
Sample ID: MCW-04 Treated						
PARAMETER	UNITS	MDL				
PESTICIDES & PCB's						
Alachlor	mg/L	0.0005	<0.0005			
Aldicarb	mg/L	0.0050	<0.0050			
Aldrin + Dieldrin	mg/L	0.00007	<0.00007			
Atrazine	mg/L	0.001	<0.001			
Azinphos-methyl	mg/L	0.002	<0.002			
Bendiocarb	mg/L	0.0020	<0.0020			
Bromoxynil	mg/L	0.0005	<0.0005			
Carbaryl	mg/L	0.0050	<0.0050			
Carbofuran	mg/L	0.0050	<0.0050			
Chlordane (Total)	mg/L	0.0007	<0.0007			
Chlorpyrifos	mg/L	0.0010	<0.0010			
Cyanazine	mg/L	0.0010	<0.0010			
Diazinon	mg/L	0.0010	<0.0010			
Dicamba	mg/L	0.0010	<0.0010			
Diquat	mg/L	0.0070	<0.0070			
2,4-Dichlorophenol	mg/L	0.0005	<0.0005			
DDT	mg/L	0.0030	<0.0030			
2,4-D	mg/L	0.0010	<0.0010			
Diclofop-methyl	mg/L	0.0009	<0.0009			
Dimethoate	mg/L	0.0025	<0.0025			
Dinoseb	mg/L	0.0010	<0.0010			
Diuron	mg/L	0.010	<0.010			
Glyphosate	mg/L	0.010	<0.010			
Heptachlor + Hept. Epoxide	mg/L	0.0003	<0.0003			
Lindane (Total)	mg/L	0.0004	<0.0004			
Malathion	mg/L	0.0050	<0.0050			
Methoxychlor	mg/L	0.0900	<0.0900			
Metolachlor	mg/L	0.0005	<0.0005			

ND = Not Detected (< MDL)

MDL = Method Detection Limit

Comment:

APPROVAL: 

ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: Moose Creek Well Supply

Report Number: 2204292
Date: 2002-06-10
Date Submitted: 2002-04-12

ATT: Mr. Blair Henderson

Project: Moose Creek - Quarterly

Sample Matrix: Supply Water

LAB ID:			176577				
Sample Date:			2002-04-11				
Sample ID:			MCW-04 Treated				
PARAMETER	UNITS	MDL					
Metribuzin	mg/L	0.005	<0.005				
Paraquat	mg/L	0.0010	<0.0010				
Parathion	mg/L	0.0010	<0.0010				
Pentachlorophenol	mg/L	0.0005	<0.0005				
Phorate	mg/L	0.0005	<0.0005				
Picloram	mg/L	0.0050	<0.0050				
PCB's (total)	mg/L	0.0003	<0.0003				
Prometryne	mg/L	0.00025	<0.00025				
Simazine	mg/L	0.0010	<0.0010				
Chlorpyrifos	mg/L	0.010	<0.010				
Terbufos	mg/L	0.0007	<0.0007				
2,3,4,6-Tetrachlorophenol	mg/L	0.0005	<0.0005				
Triallate	mg/L	0.0010	<0.0010				
2,4,6-Trichlorophenol	mg/L	0.0005	<0.0005				
Trifluralin	mg/L	0.0010	<0.0010				
2,4,5-T	mg/L	0.0010	<0.0010				

ND = Not Detected (< MDL)

MDL = Method Detection Limit

Comment:

APPROVAL: 

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Report:

220004301

Project:

Moose Creek WTP

Date Sampled:

May 6, 2002

Date Received:

May 7, 2002

Date Printed:

May 09, 2002

Attention: Dave Markell

Matrix:

Drinking Water

Parameter	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	0.05	2	1	0.05
Sample ID					
Well #1 Raw	absent			absent	
Well #2 Raw	absent			absent	
Well #3 Raw	absent			absent	
Treated Water	absent	2.00	absent	absent	2.30
Dist. Sewage Pumping Station	absent	1.20	absent	absent	1.50
Dist. Moose Creek Mall	absent	1.60		absent	2.10

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

K. P. J.
For Michael Ziebell, General Manager

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report:

220004587

Project:

Moose Creek WTP

Date Sampled:

May 13, 2002

Date Received:

May 13, 2002

Date Printed:

May 15, 2002

Matrix:

Drinking Water

Parameter	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	0.05	2	1	0.05

Sample ID

Well #1 Raw	absent			absent	
Well #2 Raw	absent			absent	
Well #3 Raw	absent			absent	
Treated Water	absent	2.00	absent	absent	2.30
Dist. Post Office	absent	1.20	absent	absent	1.60
Dist. 2041 Valley	absent	1.10		absent	1.40

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ottario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: **Dave Markell**

Report:

220004902

Project:

Moose Creek WTP

Date Sampled:

May 21, 2002

Date Received:

May 22, 2002

Date Printed:

July 11, 2002

Matrix:

Drinking Water

Parameter	E. coli	Free Cl2	HPC	TC
Unit	/100mL	mg/L	/mL	/100mL
MDL	1	0.05	2	1
Sample ID				
Well #2 Raw	absent			absent
Well #3 Raw	absent			absent
Treated Water	absent	2.20	2	absent
Dist. SPS	absent	1.00		absent
Dist. Moose Creek Mall	absent	2.00	absent	absent

This is a correction certificate and supercedes all previous reports of this number.

Caduceon Environmental Laboratories
2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada
Tel: (613)526-0123, Fax: (613)526-1244


Michael Ziebell, General Manager

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: **Dave Markell**

Report:

220005178

Project:

Moose Creek WTP

Date Sampled:

May 27, 2002

Date Received:

May 28, 2002

Date Printed:

May 30, 2002

Matrix:

Drinking Water

Parameter	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	0.05	2	1	0.05
Sample ID					
Well #2 Raw	absent			absent	
Well #3 Raw	absent			absent	
Treated Water	absent	2.10	2	absent	2.40
Dist. Medical Center	absent	1.20	absent	absent	1.50
Dist. Post Office	absent	1.80		absent	2.20

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

K. P. J.
FOR Michael Ziebell, General Manager

Caduce Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis**Client:****Ontario Clean Water Agency**

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: Dave Markell**Report:****220005454****Project:****Moose Creek WTP****Date Sampled:****June 3, 2002****Date Received:****June 4, 2002****Date Printed:****June 06, 2002****Matrix:****Drinking Water**

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05

Sample ID

Well #2 Raw	1	absent			absent	
Well #3 Raw	1	absent			1	
Treated Water		absent	1.90	absent	absent	2.30
Dist. Water Tower		absent	1.00	absent	absent	1.40
Dist. 2041 Valley St. (N)		absent	1.20		absent	1.50

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:
Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report: 220005915
Project: Moose Creek WTP
Date Sampled: June 11, 2002
Date Received: June 12, 2002
Date Printed: June 14, 2002
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification				
			Well #2 Raw	Well #3 Raw	Treated Water	Dist. Medical Center	Dist. Post Office
Total Chlorine	mg/L	0.05			2.00	1.10	1.60
Free Chlorine	mg/L	0.05			1.60	0.90	1.30
E. coli	/100mL	1	absent	absent	absent	absent	absent
HPC	/mL	2			absent	absent	
Background bacteria	/100mL	1	absent	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report:

220006128

Project:

Moose Creek WTP

Date Sampled:

June 17, 2002

Date Received:

June 18, 2002

Date Printed:

June 20, 2002

Matrix:

Drinking Water


Parameter	Unit	MDL	Sample Identification				
			Well #2 Raw	Well #3 Raw	Treated Water	Dist. Sewage Pumping Station	Dist. Moose Creek Mall
Total Chlorine	mg/L	0.05			2.00	0.90	1.10
Free Chlorine	mg/L	0.05			1.60	0.70	0.90
E. coli	/100mL	1	absent	absent	absent	absent	absent
HPC	/mL	2			absent	absent	
Background bacteria	/100mL	1	absent	absent			
Total Coliforms	/100mL	1	absent	absent	OG	absent	absent

OG - Overgrown

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244


FOR Micheal Ziebell, General Manager

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:
Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report: **220006292**
Project: Moose Creek WTP
Date Sampled: June 19, 2002
Date Received: June 20, 2002
Date Printed: June 24, 2002
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification		
			Treated Water Special	Post Office Special	M C Mall Special
Total Chlorine	mg/L	0.05	2.30	1.90	1.40
Free Chlorine	mg/L	0.05	2.00	1.70	1.10
E. coli	/100mL	1	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	absent	
Total Coliforms	/100mL	1	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244


Michael Ziebell, General Manager

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
8 Industrial Dr.
Chesterville, ON
K0C 1H0

Report:

220006349

Project:

Moose Creek WTP

Date Sampled:

June 20, 2002

Date Received:

June 21, 2002

Date Printed:

June 24, 2002

Attention: Dave Markell

Matrix:

Drinking Water

Parameter	Unit	MDL	Sample Identification		
			Treated Water Special	Post Office Special	M C Mall Special
Total Chlorine	mg/L	0.05	2.10	1.60	1.40
Free Chlorine	mg/L	0.05	1.80	1.30	1.10
E. coli	/100mL	1	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	absent	
Total Coliforms	/100mL	1	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244


Michael Ziebell, General Manager

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis**Client:**

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell**Report:****220006429****Project:**

Moose Creek WTP

Date Sampled:

June 24, 2002

Date Received:

June 25, 2002

Date Printed:

June 27, 2002

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05
Sample ID						
Well #2	4	absent			absent	
Well #3	absent	absent			absent	
Treated Water		absent	1.70	absent	absent	2.20
Dist. Sewage Pumping Station		absent	0.80	2	absent	1.00
Dist. 2041 Valley St. North		absent	0.80		absent	0.90

QUARTERLY REPORT ON DRINKING WATER QUALITY

July-September 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Moose Creek Drinking Water Quality

Ontario Drinking Water Protection Regulations

The Ontario Clean Water Agency, as the contract operator of the Moose Creek Water Treatment Facility on behalf of the Township of North Stormont, is pleased to present the 2002 Third Quarter Report on drinking water quality. This report has been prepared in response to legislative changes brought about by "Operation Clean Water", an initiative of Ontario's Ministry of the Environment to ensure high quality drinking water for the residents of Ontario. The new regulations put into law what was formerly the Ontario Drinking Water Objectives (ODWO), and sets requirements for public waterworks with regard to sampling and testing, levels of treatment, licensing of staff, and notification of authorities and the public about water quality.

Further information on the Ontario Drinking Water Regulations can be found on the Ministry of the Environment web site at www.ene.gov.on.ca

Where to contact us for information



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

Web site at www.ocwa.com

Client Services Representative: John Kingsbury
Phone : (613) 774-3663
E-mail Address: jkingsbury@ocwa.com

Operations Manager: Blair Henderson
Phone: (613) 448-3098
E-mail Address: bhenderson@ocwa.com

You may also contact the Township of North Stormont directly by contacting Rheal Charbonneau, Clerk-Treasurer, Tel. (613) 984-2821 or
e-mail address: admin@northstormont.on.ca

Free copies of this report are available at the
Township office or their website @
www.townshipofnorthstormont.on.ca



INSIDE THIS REPORT

Drinking Water Regulations	1
Where To Contact Us	1
Plant Description & Treatment Processes	2
Quality Control and Compliance with Provincial Regulations	3
Definitions & Terms	4
Required Testing	4
Water Quality Test Results	4
Questions & Answers	7

QUARTERLY REPORT ON DRINKING WATER QUALITY

July-September 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Introduction

We are proud to report that for the period July to September 2002, your water conformed to the Ontario Drinking Water Standards as set out in Ontario Regulation 459/00. The Ontario Clean Water Agency (OCWA) is dedicated to maximizing public health and safety through efficient and reliable operation of your water facility and distribution system.

Plant Description and Treatment Processes

Facility Name:	Moose Creek WTP & Distribution System
Total Design Capacity	896 cubic meters/day
Raw Water Source	Groundwater
Disinfection Method	Sodium Hypochlorite
Municipal Location	Municipal Office, 2 Victoria Street, Berwick, Ontario
Service Area	Village of Moose Creek
Service Population	400

Operational Description:

Raw water source: Three drilled wells located southwest of the water pumping station.

Low Lift Pumps: Three low lift pumps lift the water from the wells to the main pumping station. There is one header that directs the water to the Chlorine Contact Chamber. At this point, Sodium Hypochlorite is added to the raw water for disinfection.

Reservoir: From the Chlorine Contact Chamber the treated water enters a 75 cubic meter underground reservoir.

High Lift Pumps: Two high lift pumps, one duty and one standby, move the treated water from the reservoir into the distribution system and elevated tank.

Elevated Tank: There is approximately 622 cubic meters of water in the elevated water tower located on County Road 15.

Distribution System: There are approximately 400 persons supplied with water from the Moose Creek Water Treatment System.

QUARTERLY REPORT ON DRINKING WATER QUALITY

July-September 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Quality Control & Compliance With Provincial Regulations

This plant provides multiple barriers against bacteriological contamination. Bacteriological testing is carried out on raw water, treated water and distribution samples on a regular frequency. On-line analysers for chlorine residuals and turbidity ensures daily monitoring of water leaving the plant. Chlorine levels in the distribution system are also checked on a regular basis. More specialized testing occurs monthly and quarterly and includes Volatile Organics, Inorganics, Pesticides and PCB's.

OCWA uses internal compliance auditing techniques by teams from within the organization. OCWA operates the Moose Creek Water Treatment Facility in accordance with provincial regulations. Here is how we do it:

- Use of Accredited Labs. Analytical tests to monitor your water quality are conducted by a laboratory audited by the Canadian Association for Environmental Analytical Laboratories (CAEAL) and accredited by the Standards Council of Canada (SCC). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods.
- Operation by Licensed Operators. Your water treatment plant is operated and maintained by the Ontario Clean Water Agency's competent and licensed staff. The mandatory licensing program for operators of drinking water facilities is regulated under the *Ontario Water Resources Act (OWRA)* Regulation 435/93. Licensing means that an individual meets the education and experience requirements and has successfully passed the certificate exam.
- Sampling and Analytical requirements. OCWA follows a sampling and analysis schedule required by *OWRA* Regulation 459/00, the Ontario Drinking Water Standards. More information on sampling and analysis including results are available in this report and from your municipal office.
- Adherence to Ministry Guidelines and Procedures. To ensure the protection of the health and operational excellence, the OCWA adheres to the guidelines and procedures developed by the Ministry of the Environment and the Ministry of Health.

Did We Exceed the Standards?

With respect to Operational Parameters, turbidity exceedences were reported as per Regulation 459/00 on 11 separate occasions. These samples are taken continuously in-house by online equipment and the spikes are believed to be caused primarily by air entrained in the water during start-up of vertical turbine hi-lift pumps, and/or a buildup of iron sediment in the sample lines. During these spikes, the system was being adequately disinfected; therefore, reducing any risks that may be associated with the high turbidity.

QUARTERLY REPORT ON DRINKING WATER QUALITY

July-September 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Definitions & Terms

m³ - Cubic Meter, 1m³ = 1000 litres

TCU - True Colour Units

CaCO₃ - Calcium Carbonate

mg - milligram

mg/L - milligrams per litre

ug/L - micrograms per litre

ng/L - nanograms per litre

NTU - Nephelometric Turbidity Units

MAC - Maximum Acceptable Concentration

IMAC - Interim Maximum Acceptable Concentration

Coliform Bacteria - a group of commonly occurring rod shaped bacteria. Their presence in a water sample is indicative of inadequate filtration and/or disinfection.

Fecal Coliform Bacteria - refers to a subgroup of coliform bacteria present in the digestive system of warm blooded animals and humans.

Heterotrophic Plate Count - a method of measuring bacterial content in water samples. Also known as Standard Plate Count.

Organic Parameter - a group of chemical compounds containing carbon.

Inorganic Parameter - a group of chemical compounds not containing carbon.

Raw Water - Surface or ground water available as a source of drinking water that has not received any treatment.

Required Testing

The Ontario Drinking Water Regulations and Certificates of Approval (C of A) set sampling requirements for the plant. All other sampling conforms to the Drinking Water Protection Regulation schedule for sampling and analysis. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases can pick up substances resulting from the presence of animals or from human activity. Your water is extensively tested for the presence of dozens of compounds. The results of all analytical tests are available at your municipal office. The following table lists all compounds analyzed.

Moose Creek Water Quality Test Results

Microbiological Parameters	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence?	Typical Source of Contaminant
Total Coliform (counts/100ml)	0	42	0	07/01-09/30	n/a	no	Indicate possible presence of coliform
Escherichia Coliform (counts/100ml)	0	42	0	07/01-09/30	n/a	no	Definite indicator of fecal contamination
Heterotrophic Plate Count (counts/100ml)	500	28	10	07/01-09/30	2-30	no	Indicator of deteriorating water quality if greater than 500

QUARTERLY REPORT ON DRINKING WATER QUALITY

July-September 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Parameters related to Microbiological Quality	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Turbidity (NTU)	1	Continuous	Continuous	07/01-09/30	0.42- >5.0	yes	Turbidity is a measure of particles in water
Free Chlorine – Plant Effluent (mg/l)	-	Continuous	Continuous	07/01-09/30	1.3-2.5	no	Chlorine added for Disinfection
Free Chlorine- Distribution (mg/l min 0.05 & max. 4.0)	-	Grab samples weekly	Weekly	07/01-09/30	0.5-2.1	no	Objective is 0.20 mg/l in the Distribution System (min. 0.05 mg/l required)
Inorganic Parameters (mg/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Lead - Distribution	0.01	1	1	01/21/02	<0.001	no	Leached from lead solder or brass plumbing fixtures
Nitrate	10	1	1	08/08/02	<0.1	no	Natural component of water
Nitrite	1	1	1	08/08/02	<0.1	no	
Arsenic	IMAC= 0.025	1	1	09/19/00	<0.001	no	
Barium	1	1	1	09/19/00	0.24	no	
Boron	IMAC= 5.0	1	1	09/19/00	0.06	no	
Cadmium	0.005	1	1	09/19/00	<0.0001	no	
Chromium (Total)	0.05	1	1	09/19/00	<0.01	no	
Copper	1	1	1	01/21/02	<0.001	no	
Iron	0.3	1	1	01/21/02	0.45	yes	Comments below
Lead	0.01	1	1	09/19/00	<0.001	no	
Manganese	0.05	1	1	01/21/02	0.04	no	
Mercury	0.001	1	1	09/19/00	<0.0001	no	
Selenium	0.01	1	1	09/19/00	<0.001	no	
Uranium	0.1	1	1	09/19/00	<0.001	no	
Sodium	200	1	1	01/28/02-02/13/02	26-27	no	
Fluoride	2.4	3	3	08/08/02	0.15	no	

Comment: Iron may be present in groundwater as a result of mineral deposits and chemically reducing underground conditions. The aesthetic objective for Iron, set by appearance effects in drinking water is 0.3 mg/L. Excessive Iron levels in drinking water supplies may impart a brownish color to laundered goods, plumbing fixtures and the water itself; it may produce a bitter, astringent taste in water and beverages; the precipitation of iron can also promote growth of iron bacteria in water mains and service pipes. The Moose Creek Water Pumping Station has no design features for the removal of Iron.

Volatile Organics (ug/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Trihalomethanes - Plant	100	2	2	08/08/02	38.1	no	
Trihalomethanes - Dist.	100	2	2	08/08/02	55.5	no	
Benzene	5	1	1	08/08/02	<0.5	no	
Carbon Tetrachloride	5	1	1	08/08/02	<0.9	no	
Dichloromethane	50	1	1	08/08/02	<4	no	
1,2 - Dichlorobenzene	200	1	1	08/08/02	<0.4	no	
1,4 - Dichlorobenzene	5	1	1	08/08/02	<0.4	no	
1,2 - Dichloroethane	IMAC= 5	1	1	08/08/02	<0.7	no	
1,1 - Dichloroethylene	14	1	1	08/08/02	<0.5	no	
Ethylbenzene	24	1	1	08/08/02	<0.5	no	

QUARTERLY REPORT ON DRINKING WATER QUALITY

July-September 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Volatile Organics (ug/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Monochlorobenzene	80	1	1	08/08/02	<0.2	no	
Tetrachloroethylene	30	1	1	08/08/02	<0.3	no	
Toluene	24	1	1	08/08/02	<0.5	no	
Trichloroethylene	50	1	1	08/08/02	<0.3	no	
Vinyl chloride	2	1	1	08/08/02	<0.5	no	
Xylene	300	2	2	08/08/02	<2.0	no	
Bromodichloromethane	n/a	1	1	08/08/02	10.2	no	
Bromoform	n/a	1	1	08/08/02	<0.4	no	
Chloroform	n/a	1	1	08/08/02	24.9	no	
Dibromochloromethane	n/a	1	1	08/08/02	3.0	no	
Pesticides & PCB (ug/L)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Alachlor	IMAC=5	1	1	08/08/02	<0.5	no	
Aldicarb	9	1	1	08/08/02	<5.0	no	
Aldrin+Dieldrin	0.7	1	1	08/08/02	<0.012	no	
Atrazine	IMAC=5	1	1	08/08/02	<0.5	no	
Azinphos-methyl	20	1	1	08/08/02	<2.0	no	
Bendiocarb	40	1	1	08/08/02	<2.0	no	
Bromoxynil	IMAC=5	1	1	08/08/02	<0.5	no	
Carbaryl	90	1	1	08/08/02	<5.0	no	
Carbofuran	90	1	1	08/08/02	<5.0	no	
Chlordane	7	1	1	08/08/02	<0.012	no	
Chorpyrifus	90	1	1	08/08/02	<1.0	no	
Cyanazine	IMAC=10	1	1	08/08/02	<1.0	no	
Diaznon	20	1	1	08/08/02	<1.0	no	
Dicamba	120	1	1	08/08/02	<1.0	no	
2,4 Dichlorophenol	900	1	1	08/08/02	<0.5	no	
DDT + Metabolites	30	1	1	08/08/02	<3.0	no	
2,4 - Dichlorophenexy acid (2,4 -D)	IMAC=100	1	1	08/08/02	<1.0	no	
Diclofop-methyl	9	1	1	08/08/02	<0.9	no	
Dimethoate	IMAC=20	1	1	08/08/02	<2.5	no	
Dinoseb	10	1	1	08/08/02	<1.0	no	
Diquat	70	1	1	08/08/02	<7.0	no	
Diuron	150	1	1	08/08/02	<10.0	no	
Glyphosate	IMAC=280	1	1	08/08/02	<10.0	no	
Heprachlor + Heptachlor epoxide	3	1	1	08/08/02	<0.012	no	
Lindane	4	1	1	08/08/02	<0.006	no	
Malathion	190	1	1	08/08/02	<5.0	no	
Methoxychlor	900	1	1	08/08/02	<0.024	no	
Metolachlor	IMAC=50	1	1	08/08/02	<0.5	no	
Metribuzin	80	1	1	08/08/02	<5.0	no	
Paraquat	IMAC=10	1	1	08/08/02	<1.0	no	
Parathion	50	1	1	08/08/02	<1.0	no	
Pentachlorophenol	60	1	1	08/08/02	<0.5	no	
Phorate	IMAC=2	1	1	08/08/02	<0.5	no	
Picloram	IMAC=190	1	1	08/08/02	<5.0	no	
Polychlorinated Biphenyls	IMAC=3	1	1	08/08/02	<0.05	no	
Prometryne	IMAC=1	1	1	08/08/02	<0.25	no	

QUARTERLY REPORT ON DRINKING WATER QUALITY

July-September 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Pesticides & PCB (mg/L)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Simazine	IMAC=10	1	1	08/08/02	<1.0	no	
Temephos	IMAC=280	1	1	08/08/02	<10	no	
Terbufos	IMAC=1	1	1	08/08/02	<0.7	no	
2,3,4,6 Tetrachlorophenol	100	1	1	08/08/02	<0.5	no	
Triallate	230	1	1	08/08/02	<1.0	no	
2,4,6-Trichlorophenol	5	1	1	08/08/02	<0.5	no	
2,4,5 - trichlorophenoxy acetic acid	IMAC=280	1	1	08/08/02	<1.0	no	
Trifluralin	45	1	1	08/08/02	<1.0	no	
Additional Parameters Non-Health Related (mg/L)	AO or OG	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Colour	5	1	1	01/28/02	2	no	
pH	6.8-8.5	1	1	01/28/02	7.84	no	
Alkalinity	30-500	1	1	01/28/02	205	no	
Total Hardness	80-100	1	1	01/28/02	326	yes	Limits are set as an operational guideline
Sulphate	500	1	1	01/28/02	137	no	
Conductivity	---	1	1	01/28/02	707	no	
Chloride	250	1	1	01/28/02	29	no	
Free Ammonia	---	1	1	01/28/02	<0.02	no	
Total Kjeldahl Nitrogen	---	1	1	01/28/02	0.1	no	
Dissolved Organic Carbon	5	1	1	01/28/02	1.9	no	
Sodium	200	1	1	01/28/02	26	no	
Iron	0.3	1	1	01/28/02	0.45	yes	
Aluminium	0.1	1	1	01/28/02	<0.05	no	
Manganese	0.05	1	1	01/28/02	0.04	no	
Ammonia + Ammonium N		1	1	01/28/02	<0.02	no	
Total Organic Carbon		1	1	01/28/02	2.1	no	
Copper	1	1	1	01/28/02	<0.001	no	
Calcium	---	1	1	01/28/02	86	no	
Magnesium	---	1	1	01/28/02	27	no	

Questions & Answers

Q. What is an Accredited Laboratory?

A. Accredited labs must have undergone an on-site assessment and performance review of their methods by the Canadian Association of Environmental and Analytical Laboratories. The Standards Council of Canada grants accreditation to the lab based on the recommendation of the CAEAL. The accreditation requirements are repeated every two years.

Q. What had to be done to meet the new regulations?

A. The Moose Creek Water Treatment Plant was following the Ontario Drinking Water Objectives (ODWO) before they became law, so little change was required to meet the new regulations. Our chlorine residual in the water leaving the plant was raised to slightly to achieve the (0.20 mg/L free chlorine) required level in the distribution system, and some changes were required in the way results are reported. This report to the public is also the result of the new regulations.

QUARTERLY REPORT ON DRINKING WATER QUALITY

July-September 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Q. What parameters did you test for?

A. Microbiological parameters, volatile organic, inorganic and pesticides & PCBs have been tested. The results are included in this report.

Q. Sometimes my water looks rusty or coloured. Why is that, and what should I do about it?

A. This is quite often caused when the tanks in older water heaters start to decay. If the colour is seen only in your hot water, this may be the problem. If the colour is also noticed in your cold water it could be coming from the water main. Various maintenance procedures in the distribution system - such as fire hydrant and valve maintenance, or main break repairs - require flushing of the water mains. Flushing can cause small particles of sediment to break off adding colour to the water. Please note that there is no health risk associated with this problem. This is usually only temporary, and opening your taps for a while to flush out your service line (the pipe from the water main to your house) should take care of the problem. Let the water run until the colour disappears.

REQUIRED SAMPLES

JULY, AUGUST, SEPTEMBER 2002

Chemical Parameters

Table B & D
NO2&NO3

Treated
Treated

55

System THM

annual

Treated
Treated

\ \

Date Samples Collected	Date Results Received	
	Initials	Initials

Bacti Parameters

Raw	Treated
Weil#1 Weil#2 Weil#3	E.Coli
Total Coli.	HPC
Background	
E.Coli	
Total Coli.	
Background	
E.Coli	
Total Coli.	
Background	

JULY 1	Bactis	✓
JULY 8	Bactis	✓
JULY 15	Bactis	✓
JULY 22	Bactis	✓
JULY 29	Bactis	✓

AUG. 5	Bacit's	✓
AUG. 12	Bacit's	✓
AUG. 19	Bacit's	✓
AUG. 26	Bacit's	✓

DATE	DESCRIPTION	AMOUNT	CHECK NO.	BANK	INITIALS
1900					
1901					
1902					
1903					
1904					
1905					
1906					
1907					
1908					
1909					
1910					
1911					
1912					
1913					
1914					
1915					
1916					
1917					
1918					
1919					
1920					
1921					
1922					
1923					
1924					
1925					
1926					
1927					
1928					
1929					
1930					
1931					
1932					
1933					
1934					
1935					
1936					
1937					
1938					
1939					
1940					
1941					
1942					
1943					
1944					
1945					
1946					
1947					
1948					
1949					
1950					
1951					
1952					
1953					
1954					
1955					
1956					
1957					
1958					
1959					
1960					
1961					
1962					
1963					
1964					
1965					
1966					
1967					
1968					
1969					
1970					
1971					
1972					
1973					
1974					
1975					
1976					
1977					
1978					
1979					
1980					
1981					
1982					
1983					
1984					
1985					
1986					
1987					
1988					
1989					
1990					
1991					
1992					
1993					
1994					
1995					

SEPT. 2	Bacis	✓
SEPT. 9	Bacis	✓
SEPT. 16	Bacis	✓
SEPT. 23	Bacis	✓
SEPT. 30	Bacis	

[illegible]

Flouride Treated Water (Annual)
Lead Distribution System (Annual)
Table C Treated Water (Jan. 2003)
Sodium Treated Water (Jan. 2007)

[illegible]

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis**Client:**

Ontario Clean Water Agency

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: **Dave Markell****Report:****220006763****Project:**

Moose Creek WTP

Date Sampled:

July 2, 2002

Date Received:

July 3, 2002

Date Printed:

July 05, 2002

Matrix:

Drinking Water

Parameter	Unit	MDL	Sample Identification				
			Well #2 Raw	Well #3 Raw	Treated Water	Dist. Water Tower	Dist. Mall
Total Chlorine	mg/L	0.05			2.00	0.90	1.20
Free Chlorine	mg/L	0.05			1.60	0.60	1.00
E. coli	/100mL	1	absent	absent	absent	absent	absent
HPC	/mL	2			absent	absent	
Background bacteria	/100mL	1	3	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: Dave Markell

Report:

220007058

Project:

Moose Creek WTP

Date Sampled:

July 8, 2002

Date Received:

July 9, 2002

Date Printed:

July 11, 2002

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05
Sample ID						
Well #2 Raw	>200	1			absent	
Well #3 Raw	absent	absent			absent	
Treated Water		absent	1.80	absent	absent	2.20
Dist. SPS		absent	0.60	absent	absent	0.80
Dist. Post Office		absent	1.20		absent	1.50

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Report:

220007320

Project:

Moose Creek WTP

Date Sampled:

July 15, 2002

Date Received:

July 16, 2002

Date Printed:

July 18, 2002

Attention: Dave Markell

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05

Sample ID

Well #2 Raw	3	absent			absent	
Well #3 Raw	absent	absent			absent	
Treated Water		absent	1.90	absent	absent	2.30
Dist. Moose Creek Mall		absent	1.40	absent	absent	1.80
Dist. Paul Adams House		absent	0.90		absent	1.00

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis**Client:****Ontario Clean Water Agency**

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: Dave Markell**Report:****220007579****Project:**

Moose Creek WTP

Date Sampled:

July 22, 2002

Date Received:

July 23, 2002

Date Printed:

July 25, 2002

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl ₂	HPC	TC	Total Cl ₂
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05


Sample ID

Well #2 Raw	14	absent			absent	
Well #3 Raw	41	absent			40	
Treated Water		absent	1.78	absent	absent	2.18
Dist. Tower		absent	1.50	absent	absent	1.90
Dist. 2041 Valley St. N		absent	0.72		absent	0.95

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244


For Michael Ziebell, General Manager

Caduce Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis**Client:**

Ontario Clean Water Agency

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: **Dave Markell****Report:****220007816****Project:**

Moose Creek WTP

Date Sampled:

July 29, 2002

Date Received:

July 30, 2002

Date Printed:

August 01, 2002

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05

Sample ID

Well #2 Raw	71	absent			absent	
Well #3 Raw	5	absent			4	
Treated Water		absent	1.70	absent	absent	2.20
Dist. SPS		absent	0.80	absent	absent	1.10
Dist. Moose Creek Mall		absent	0.90		absent	1.20

REPORT OF ANALYSIS

Report Number: 2210850
Date: 2002-08-19
Date Submitted: 2002-08-09

Project: Moose Creek Wells

P.O. Number:
Matrix: Supply Water

MDL = Method Detection Limit
Comment:

608 Norris Court, Kingston, ON, K7P 2R9

ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number: 2210850
Date: 2002-08-16
Date Submitted: 2002-08-09

ATT: Mr. Blair Henderson

Project: Moose Creek Wells

P.O. Number:

Matrix: Supply Water


LAB ID:			198038				
Sample Date:			2002-08-08				
Sample ID:			MCW-04				
PARAMETER	UNITS	MDL					
BTEX / 624 / PURGEABLE HYDROCARBONS							
Benzene	ug/L	0.5	<0.5	✓			
Toluene	ug/L	0.5	<0.5	✓			
Ethylbenzene	ug/L	0.5	<0.5	✓			
m/p-xylene	ug/L	1.0	<1.0	✓			
o-xylene	ug/L	0.5	<0.5	✓			
Bromodichloromethane	ug/L	0.3	10.2	✓			
Bromoform	ug/L	0.4	<0.4	✓			
Carbon Tetrachloride	ug/L	0.9	<0.9	✓			
Monochlorobenzene	ug/L	0.2	<0.2	✓			
Chloroform	ug/L	0.5	24.9	✓			
Dibromochloromethane	ug/L	0.3	3.0	✓			
1,2-dichlorobenzene	ug/L	0.4	<0.4	✓			
1,4-dichlorobenzene	ug/L	0.4	<0.4	✓			
1,2-dichloroethane	ug/L	0.7	<0.7	✓			
1,1-dichloroethylene	ug/L	0.5	<0.5	✓			
Dichloromethane	ug/L	4.0	<4.0	✓			
Tetrachloroethylene	ug/L	0.3	<0.3	✓			
Trichloroethylene	ug/L	0.3	<0.3	✓			
Vinyl Chloride	ug/L	0.5	<0.5	✓			
TOTALS							
Trihalomethanes (total)	ug/L	2.0	38.1	✓			
Xylene; total	ug/L	2.0	<2.0	✓			
BTEX / 624 Surrogate Recoveries							
Toluene-d8	%		97				
1,2-dichloroethane-d4	%		101				
4-bromofluorobenzene	%		101				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL:



ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number:

2210850

Date:

2002-08-29

Date Submitted:

2002-08-09

ATT: Mr. Blair Henderson

Project:

Moose Creek Wells

Sample Matrix:

Supply Water

LAB ID:			198038				
Sample Date:			8/8/02				
Sample ID:			MCW-04				
PARAMETER	UNITS	MDL					
PESTICIDES & PCB's							
Alachlor	ug/L	0.5	<0.5 ✓				
Aldicarb	ug/L	5	<5 ✓				
Aldrin	ug/L	0.006	<0.006 ✓				
Aldrin + Dieldrin	ug/L	0.012	<0.012 ✓				
Atrazine	ug/L	0.5	<0.5 ✓				
Desethyl-atrazine	ug/L	0.5	<0.5 ✓				
Atrazine+Desethyl-atrazine	ug/L	1	<1 ✓				
Azinphos-methyl	ug/L	2	<2 ✓				
Bendiocarb	ug/L	2	<2 ✓				
Dimoxynil	ug/L	0.5	<0.5 ✓				
Carbaryl	ug/L	5	<5 ✓				
Carbofuran	ug/L	5	<5 ✓				
Chlordane (Total)	ug/L	0.012	<0.012 ✓				
α-Chlorodane	ug/L	0.006	<0.006 ✓				
γ-Chlorodane	ug/L	0.006	<0.006 ✓				
Oxychlorodane	ug/L	0.006	<0.006 ✓				
Chloropyrifos	ug/L	1	<1 ✓				
Cyanazine	ug/L	1	<1 ✓				
Diazinon	ug/L	1	<1 ✓				
Dicamba	ug/L	1	<1 ✓				
Dieldrin	ug/L	0.006	<0.006 ✓				
Diquat	ug/L	7	<7 ✓				
2,4-Dichlorophenol	ug/L	0.5	<0.5 ✓				
DDT + Metabolites	ug/L	0.024	<0.024 ✓				
o,p'-DDT	ug/L	0.006	<0.006 ✓				
p,p'-DDT	ug/L	0.006	<0.006 ✓				
2,4-D	ug/L	1	<1 ✓				
p,p'-DDE	ug/L	0.006	<0.006 ✓				

NOTE: mg/L=1000xug/L

MDL = Method Detection Limit

Comment:

APPROVAL:

146 Colonnade Road, Unit 8, Nepean, Ontario K2E 7Y1 Tel: (613) 727-5692 Fax: (613) 727-5222

ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number:

2210850

Date:

2002-08-29

Date Submitted:

2002-08-09

ATT: Mr. Blair Henderson

Project:

Moose Creek Wells

Sample Matrix:

Supply Water


LAB ID:			198038				
Sample Date:			8/8/02				
Sample ID:			MCW-04				
PARAMETER	UNITS	MDL					
p,p'-DDD	ug/L	0.006	<0.006				
Diclofop-methyl	ug/L	0.9	<0.9 ✓				
Dimethoate	ug/L	2.5	<2.5 ✓				
Dinoseb	ug/L	1	<1 ✓				
Diuron	ug/L	10	<10 ✓				
Glyphosate	ug/L	10	<10 ✓				
Heptachlor	ug/L	0.006	<0.006				
Heptachlor epoxide	ug/L	0.006	<0.006				
Heptachlor + Hept. Epoxide	ug/L	0.012	<0.012 ✓				
Malathion	ug/L	0.006	<0.006 ✓				
Marathon	ug/L	5	<5 ✓				
Methoxychlor	ug/L	0.024	<0.024 ✓				
Metolachlor	ug/L	0.5	<0.5 ✓				
Metribuzin	ug/L	5	<5 ✓				
Paraquat	ug/L	1	<1 ✓				
Parathion	ug/L	1	<1 ✓				
Pentachlorophenol	ug/L	0.5	<0.5 ✓				
Phorate	ug/L	0.5	<0.5 ✓				
Picloram	ug/L	5	<5 ✓				
PCB's (total)	ug/L	0.05	<0.05 ✓				
Prometryne	ug/L	0.25	<0.25 ✓				
Simazine	ug/L	1	<1 ✓				
Temephos	ug/L	10	<10 ✓				
Terbufos	ug/L	0.7	<0.7 ✓				
2,3,4,6-Tetrachlorophenol	ug/L	0.5	<0.5 ✓				
Triallate	ug/L	1	<1 ✓				
2,4,6-Trichlorophenol	ug/L	0.5	<0.5 ✓				
Trifluralin	ug/L	1	<1 ✓				
2,4,5-T	ug/L	1	<1 ✓				

NOTE: mg/L=1000xug/L

MDL = Method Detection Limit

Comment:

APPROVAL:



ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number:

2210857

Date:

2002-08-16

Date Submitted:

2002-08-09

ATT: Mr. Blair Henderson

Project:

P.O. Number:

Matrix:

Supply Water


LAB ID:			198045				
Sample Date:			2002-08-08				
Sample ID:			MCW System				
PARAMETER	UNITS	MDL					
BTEX / 624 / PURGEABLE HYDROCARBONS							
Bromodichloromethane	ug/L	0.3	11.9				
Bromoform	ug/L	0.4	<0.4				
Chloroform	ug/L	0.5	40.0				
Dibromochloromethane	ug/L	0.3	3.6				
TOTALS							
Trihalomethanes (total)	ug/L	2.0	55.5				
BTEX / 624 Surrogate Recoveries							
Toluene-d8	%		97				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL:



Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Report:

220008067

Project:

Moose Creek WTP

Date Sampled:

August 6, 2002

Date Received:

August 7, 2002

Date Printed:

August 09, 2002

Attention: Dave Markell

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05

Sample ID

Well #2 Raw	58	absent			absent	
Well #3 Raw	178	absent			absent	
Treated Water		absent	1.30	2	absent	1.60
Dist. Water Tower		absent	1.20	4	absent	1.20
Dist. SPS		absent	1.00		absent	1.20

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:
Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report: 220008349
Project: Moose Creek WTP
Date Sampled: August 12, 2002
Date Received: August 13, 2002
Date Printed: August 15, 2002
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification				
			Well #2 Raw	Well #3 Raw	Treated Water	Dist. 2041 Valley North	Dist. Moose Creek all
Total Chlorine	mg/L	0.05			2.00	0.70	1.40
Free Chlorine	mg/L	0.05			1.70	0.50	1.20
E. coli	/100mL	1	absent	absent	absent	absent	absent
HPC	/mL	2			absent	30	
Background bacteria	/100mL	1	4	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: **Dave Markell**

Report:

220008617

Project:

Moose Creek WTP

Date Sampled:

August 19, 2002

Date Received:

August 20, 2002

Date Printed:

August 22, 2002

Matrix:

Drinking Water

Parameter	Unit	MDL	Sample Identification				
			Well #2 Raw	Well #3 Raw	Treated Water	Dist. M.C. Mall	Dist. Paul Adams
Total Chlorine	mg/L	0.05			2.20	1.60	1.20
Free Chlorine	mg/L	0.05			1.60	1.30	0.90
E. coli	/100mL	1	absent	absent	absent	absent	absent
HPC	/mL	2			2	2	
Background bacteria	/100mL	1	180	17			
Total Coliforms	/100mL	1	absent	15	absent	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client: **Ontario Clean Water Agency**
Industrial Dr.
Chesterville, ON
K0C 1H0
Attention: **Dave Markell**

Report: **220008931**
Project: **Moose Creek WTP**
Date Sampled: **August 26, 2002**
Date Received: **August 27, 2002**
Date Printed: **August 29, 2002**
Matrix: **Drinking Water**

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05

Sample ID

Well #2 Raw	2	absent			absent	
Well #3 Raw	absent	absent			absent	
Treated Water		absent	1.70	absent	absent	2.10
Dist. Post Office		absent	1.20	absent	absent	1.50
Dist. 2041 Valley St. (N)		absent	1.00		absent	1.50

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report:

220008931

Project:

Moose Creek WTP

Date Sampled:

August 26, 2002

Date Received:

August 27, 2002

Date Printed:

August 29, 2002

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05
Sample ID						
Well #2 Raw	2	absent			absent	
Well #3 Raw	absent	absent			absent	
Treated Water		absent	1.70	absent	absent	2.10
Dist. Post Office		absent	1.20	absent	absent	1.50
Dist. 2041 Valley St. (N)		absent	1.00		absent	1.50

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:
ario Clean Water Agency

5 Industrial Dr.
Chesterville, ON
K0C 1H0

Report: **220009260**
Project: **Moose Creek WTP**
Date Sampled: **September 3, 2002**
Date Received: **September 4, 2002**
Date Printed: **September 06, 2002**

Attention: **Dave Markell**

Matrix: **Drinking Water**

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05
Sample ID						
Well #2 Raw	55	absent			1	
Well #3 Raw	2	absent			2	
Treated Water WTP		absent	1.63	absent	absent	1.97
M.C. Tower		absent	1.06	2	absent	1.48
S.P.S.		absent	0.88		absent	1.25

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report:

220009538

Project:

Moose Creek WTP

Date Sampled:

September 9, 2002

Date Received:

September 10, 2002

Date Printed:

September 12, 2002

Matrix:

Drinking Water

Parameter	Unit	MDL	Sample Identification				
			Well #2 Raw	Well #3 Raw	Treated Water	Dist. Moose Creek Mall	Dist. Valley St. N 2041
Total Chlorine	mg/L	0.05			1.86	1.35	1.14
Free Chlorine	mg/L	0.05			1.51	1.03	0.87
E. coli	/100mL	1	absent	absent	absent	absent	absent
HPC	/mL	2			absent	absent	
Background bacteria	/100mL	1	1	absent			
Total Coliforms	/100mL	1	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: **Dave Markell**

Report:

220009886

Project:

Moose Creek WTP

Date Sampled:

September 16, 2002

Date Received:

September 17, 2002

Date Printed:

September 19, 2002

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05
Sample ID						
Well #2 Raw	118	absent			2	
Well #3 Raw	absent	absent			absent	
Treated Water		absent	2.05	2	absent	2.35
Dist. Post Office		absent	1.36	2	absent	1.76
Dist. Paul Adams		absent	0.73		absent	0.93

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: **Dave Markell**

Report:

220010231

Project:

Moose Creek WTP

Date Sampled:

September 23, 2002

Date Received:

September 24, 2002

Date Printed:

September 26, 2002

Matrix:

Drinking Water

Parameter	Unit	MDL	Sample Identification				
			Well #2 Raw	Well #3 Raw	Treated Water	Dist. Water Tower	Dist. M.C. Mall
Total Chlorine	mg/L	0.05			1.80	1.44	1.22
Free Chlorine	mg/L	0.05			1.53	1.12	0.96
E. coli	/100mL	1	absent	absent	absent	absent	absent
HPC	/mL	2			absent	absent	
Background bacteria	/100mL	1	absent	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:
Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report: 220010463
Project: Moose Creek WTP
Date Sampled: September 30, 2002
Date Received: October 1, 2002
Date Printed: October 03, 2002
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification				
			Well #2 Raw	Well #3 Raw	Treated Water	Dist. Water Tower	Dist. SPS
Total Chlorine	mg/L	0.05			2.20	1.50	1.24
Free Chlorine	mg/L	0.05			1.83	1.25	1.01
E. coli	/100mL	1	absent	absent	absent	absent	absent
HPC	/mL	2			absent	absent	
Background bacteria	/100mL	1	3	1			
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent

QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Moose Creek Drinking Water Quality

Ontario Drinking Water Protection Regulations

The Ontario Clean Water Agency, as the contract operator of the Moose Creek Water Treatment Facility on behalf of the Township of North Stormont, is pleased to present the 2002 Fourth Quarter Report on drinking water quality. This report has been prepared in response to legislative changes brought about by "Operation Clean Water", an initiative of Ontario's Ministry of the Environment to ensure high quality drinking water for the residents of Ontario. The new regulations put into law what was formerly the Ontario Drinking Water Objectives (ODWO), and sets requirements for public waterworks with regard to sampling and testing, levels of treatment, licensing of staff, and notification of authorities and the public about water quality.

Further information on the Ontario Drinking Water Regulations can be found on the Ministry of the Environment web site at www.ene.gov.on.ca

Where to contact us for information



**Ontario Clean Water Agency
Agence Ontarienne Des Eaux**

Web site at www.ocwa.com

Client Services Representative:

John Kingsbury

Phone : (613) 774-3663

E-mail Address: jkingsbury@ocwa.com

Operations Manager:

Blair Henderson

Phone: (613) 448-3098

E-mail Address: bhenderson@ocwa.com

You may also contact the Township of North Stormont directly.

Rheal Charbonneau, Clerk - Treasurer

Phone: (613) 984-2821

E-mail Address: admin@townshipofnorthstormont.on.ca



Free copies of this report are available at the Township office at 2 Victoria St., Berwick, or their website @ www.townshipofnorthstormont.on.ca

INSIDE THIS REPORT

Drinking Water Regulations	1
Where To Contact Us	1
Plant Description & Treatment Processes	2
Quality Control and Compliance with Provincial Regulations	3
Definitions & Terms	5
Required Testing	5
Water Quality Test Results	6
Questions & Answers	10

QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Introduction

We are proud to report that for the period October to December 2002, your water conformed to the Ontario Drinking Water Standards as set out in Ontario Regulation 459/00. The Ontario Clean Water Agency (OCWA) is dedicated to maximizing public health and safety through efficient and reliable operation of your water facility and distribution system.

Plant Description and Treatment Processes

Facility Name:	Moose Creek WTP & Distribution System
Total Design Capacity	896 cubic meters/day
Raw Water Source	Groundwater
Disinfection Method	Sodium Hypochlorite
Municipal Location	Municipal office, 2 Victoria Street, Berwick
Service Area	Village of Moose Creek
Service Population	400
Operational Description:	
<u>Raw Water Source:</u> Three drilled wells located southwest of the water pumping station.	
<u>Low Lift Pumps:</u> Three low lift pumps lift the water from the wells to the main pumping station. There is one header that directs the water to the Chlorine Contact Chamber. At this point, Sodium Hypochlorite is added to the raw water for disinfection.	
<u>Reservoir:</u> From the Chlorine Contact Chamber the treated water enters a 75 cubic meter underground reservoir.	
<u>High Lift Pumps:</u> Two high lift pumps, one duty and one standby, move the treated water from the reservoir into the distribution system and elevated tank.	
<u>Elevated Tank:</u> There is approximately 622 cubic meters of water in the elevated water tower located on County Road 15.	
<u>Distribution System:</u> There are approximately 400 persons supplied with water from the Moose Creek Water Treatment System.	

QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Quality Control & Compliance With Provincial Regulations

This plant provides multiple barriers against bacteriological contamination. Bacteriological testing is carried out on raw water, treated water and distribution samples on a regular frequency. On-line analysers for chlorine residuals and turbidity ensure daily monitoring of water leaving the plant. Chlorine levels in the distribution system are also checked on a regular basis. More specialized testing occurs monthly and quarterly and includes Volatile Organics, Inorganics, Pesticides and PCB's.

OCWA uses internal compliance auditing techniques by teams from within the organization. OCWA operates the Moose Creek Water Treatment Facility in accordance with provincial regulations. Here is how we do it:

- **Use of Accredited Labs.** Analytical tests to monitor your water quality are conducted by a laboratory audited by the Canadian Association for Environmental Analytical Laboratories (CAEAL) and accredited by the Standards Council of Canada (SCC). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods.
- **Operation by Licensed Operators.** Your water treatment plant is operated and maintained by the Ontario Clean Water Agency's competent and licensed staff. The mandatory licensing program for operators of drinking water facilities is regulated under the *Ontario Water Resources Act (OWRA)* Regulation 435/93. Licensing means that an individual meets the education and experience requirements and has successfully passed the certificate exam.
- **Sampling and Analytical requirements.** OCWA follows a sampling and analysis schedule required by *OWRA* Regulation 459/00, the Ontario Drinking Water Standards. More information on sampling and analysis including results are available in this report and from your municipal office.
- **Adherence to Ministry Guidelines and Procedures.** To ensure the protection of the health and operational excellence, the OCWA adheres to the guidelines and procedures developed by the Ministry of the Environment and the Ministry of Health.

Annual Compliance Report

The Annual Compliance Report covers the period from January 1, 2002 to December 31, 2002. Copies of the report will be made available for inspection by any member of the public during normal business hours without charge at the Township Office. The Annual Compliance Report for 2002 will be completed and made available not later than March 31, 2003.

QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

The Compliance Report will include, at a minimum, the following:

- A statement as to compliance with all of the terms and conditions of the certificate and a detailed description of all of the measures taken to ensure compliance with the certificate, including and supporting data or other information;
- In the event of any non-compliance during the reporting period, details of the non-compliance as well as details of how and when any non-compliance was corrected;
- A summary and discussion of the quantity of water supplied during the reporting period compared to the rated capacity specified in the Certificate of Approval, including monthly average and maximum daily flows;
- A summary of records related to flow rate exceedences, and a summary of analytical results of sampling required by the certificate, including raw water and in-process parameters as specified in the operations manual in accordance with the Certificate of Approval;
- A summary listing treatment chemicals used, including average dosage rates with special reference to any abnormal usages

Did We Exceed the Standards?

During the fourth quarter of 2002, in the month of October, a treated water sample was found to exceed the Ontario Drinking Water Standards as set out in Ontario Regulation 459/00. On October 7, 2002, treated water exceeded MAC for Total Coliform with a result of 2 per 100/ml. The Ministry of Environment and the Ministry of Health were immediately notified as per the Ontario Drinking Water Standards. Free chlorine residual of the sample at the time of collection was 1.86 mg/L. Subsequent re-sampling as per O. Reg. 459 indicated no adverse results.

QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Definitions & Terms

m³ -	Cubic Meter, 1 m ³ = 1000 litres
TCU -	True Colour Units
CaCO₃ -	Calcium Carbonate
mg -	milligram
mg/L -	milligrams per litre.
ug/L -	micrograms per litre.
ng/L -	nanograms per litre.
NTU -	Nephelometric Turbidity Units.
MAC -	Maximum Acceptable Concentration
IMAC -	Interim Maximum Acceptable Concentration

Coliform Bacteria - a group of commonly occurring rod shaped bacteria. Their presence in a water sample is indicative of inadequate filtration and/or disinfection.

Fecal Coliform Bacteria - refers to a subgroup of coliform bacteria present in the digestive system of warm blooded animals and humans

Background Count - a method of measuring bacterial content in water samples

Heterotrophic Plate Count - a method of measuring bacterial content in water samples. Also known as Standard Plate Count.

Organic Parameter - a group of chemical compounds containing carbon

Inorganic Parameter - a group of chemical compounds not containing carbon

Raw Water - Surface or ground water available as a source of drinking water that has not received any treatment.

Required Testing

The Ontario Drinking Water Regulations and Certificates of Approval (C of A) set sampling requirements for the plant. All other sampling conforms to the Drinking Water Protection Regulation schedule for sampling and analysis. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases can pick up substances resulting from the presence of animals or from human activity. Your water is extensively tested for the presence of dozens of compounds. The results of all analytical tests are available at your municipal office. The following table lists all compounds analyzed.

QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Moose Creek Water Quality Test Results

Microbiological Parameters	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates	Range	Exceedence	Typical Source of Contaminant
Total Coliform, Raw (CFU/100mL)	n/a	30	6	10/07 - 12/30 weekly	1-15	n/a	Indicate possible presence of fecal matter
E. Coli, Raw (CFU/100 mL)	n/a	30	0	10/07 - 12/30 weekly	n/a	n/a	Definite indicator of fecal contamination
Background Count, Raw (CFU/100 mL)	n/a	30	12	10/07 - 12/30 weekly	1-85	n/a	Indicator of adverse water quality
Total Coliform, Treated (CFU/100mL)	0	15	1	10/07 - 12/30 weekly	2	no	Indicate possible presence of fecal matter
E. coli, Treated (CFU/100 mL)	0	15	0	10/07 - 12/30 weekly	n/a	no	Definite indicator of fecal contamination
Hetrotrophic Plate Count, Treated (CFU/1 mL)	500	15	4	10/07 - 12/30 weekly	2-20	no	Indicator of adverse water quality
Total Coliform, Dist. (CFU/100mL)	0	28	0	10/07 - 12/30 weekly	n/a	no	Indicate possible presence of fecal matter
E. Coli, Dist. (CFU/100 mL)	0	28	0	10/07 - 12/30 weekly	n/a	no	Definite indicator of fecal contamination
Hetrotrophic Plate Count, Dist. (CFU/1 mL)	500	15	2	10/07 - 12/30 weekly	2	no	Indicator of adverse water quality

Parameters related to Microbiological Quality	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence	Typical Source of Contaminant
Turbidity (NTU)	1	Continuous	Continuous	10/01-12/31	0.29-0.94	no	Turbidity is a measure of particles in water
Free Chlorine – Plant Effluent (mg/l)	-	Continuous	Continuous	10/01-12/31	1.2-2.3	no	Chlorine added for Disinfection
Free Chlorine-Distribution (mg/l min 0.05 & max. 4.0)	-	Grab samples weekly	Weekly	10/07-12/30	0.52-1.53	no	Objective is 0.20 mg/l in the Distribution System (min. 0.05 mg/l required)

Comments: MAC/IMAC values do not apply to Raw Water results. MOE recommend a level of at least 0.2 mg/l free chlorine residual in system to maintain microbiological quality in system. Adverse water quality occurs when the free chlorine residual is less than 0.05mg/l.

QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Inorganic Parameters (mg/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence	Typical Source of Contaminant
Lead - Distribution	0.01	1	1	01/21/02	<0.001	no	Leached from lead solder or brass plumbing fixtures
Nitrate	10	1	1	10/21/02	<0.1	no	Natural component of water
Nitrite	1	1	1	10/21/02	<0.1	no	
Arsenic	IMAC= 0.025	1	1	09/19/00	<0.001	no	
Barium	1	1	1	09/19/00	0.24	no	
Boron	IMAC= 5.0	1	1	09/19/00	0.06	no	
Cadmium	0.005	1	1	09/19/00	<0.0001	no	
Chromium (Total)	0.05	1	1	09/19/00	<0.01	no	
Copper	1	1	1	01/21/02	<0.001	no	
Iron	0.3	1	1	01/21/02	0.45	yes	Comments below
Lead	0.01	1	1	09/19/00	<0.001	no	
Manganese	0.05	1	1	01/21/02	0.04	no	
Mercury	0.001	1	1	09/19/00	<0.0001	no	
Selenium	0.01	1	1	09/19/00	<0.001	no	
Uranium	0.1	1	1	09/19/00	<0.001	no	
Sodium	200	1	1	01/28/02-02/13/02	26-27	no	
Fluoride	2.4	3	3	08/08/02	0.15	no	

Comment: Iron may be present in groundwater as a result of mineral deposits and chemically reducing underground conditions. The aesthetic objective for Iron, set by appearance effects in drinking water is 0.3 mg/L. Excessive Iron levels in drinking water supplies may impart a brownish color to laundered goods, plumbing fixtures and the water itself; it may produce a bitter, astringent taste in water and beverages; the precipitation of iron can also promote growth of iron bacteria in water mains and service pipes. The Moose Creek Water Pumping Station has no design features for the removal of Iron.

Volatile Organics (ug/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence	Typical Source of Contaminant
Trihalomethanes - Plant	100	1	1	10/21/02	51.3	no	
Trihalomethanes - Dist.	100	1	1	10/21/02	73.1	no	
Benzene	5	1	1	10/21/02	<0.5	no	
Carbon Tetrachloride	5	1	1	10/21/02	<0.9	no	
Dichloromethane	50	1	1	10/21/02	<4.0	no	
1,2 - Dichlorobenzene	200	1	1	10/21/02	<0.4	no	
1,4 - Dichlorobenzene	5	1	1	10/21/02	<0.4	no	
1,2 - Dichloroethane	IMAC= 5	1	1	10/21/02	<0.7	no	
1,1 - Dichloroethylene	14	1	1	10/21/02	<0.5	no	
Ethylbenzene	24	1	1	10/21/02	<0.5	no	
Monochlorobenzene	80	1	1	10/21/02	<0.2	no	
Tetrachloroethylene	30	1	1	10/21/02	<0.3	no	
Toluene	24	1	1	10/21/02	<0.5	no	
Trichloroethylene	50	1	1	10/21/02	<0.3	no	
Vinyl chloride	2	1	1	10/21/02	<0.5	no	
Xylene	300	1	1	10/21/02	<2.0	no	
Bromodichloromethane	n/a	1	1	10/21/02	15.2	no	

QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Volatile Organics (ug/l) (cont'd)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence	Typical Source of Contaminant
Bromoform	n/a	1	1	10/21/02	0.5	no	
Chloroform	n/a	1	1	10/21/02	28.3	no	
Dibromochloromethane	n/a	1	1	10/21/02	7.3	no	

Pesticides & PCB (ug/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence	Typical Source of Contaminant
Alachlor	IMAC=5	1	1	10/21/02	<0.5	no	
Aldicarb	9	1	1	10/21/02	<5.0	no	
Aldrin+Dieldrin	0.7	1	1	10/21/02	<0.012	no	
Atrazine	IMAC=5	1	1	10/21/02	<0.5	no	
Azinphos-methyl	20	1	1	10/21/02	<2.0	no	
Bendiocarb	40	1	1	10/21/02	<2.0	no	
Bromoxynil	IMAC=5	1	1	10/21/02	<0.5	no	
Carbaryl	90	1	1	10/21/02	<5.0	no	
Carbofuran	90	1	1	10/21/02	<5.0	no	
Chlordane	7	1	1	10/21/02	<0.012	no	
Chlorpyrifus	90	1	1	10/21/02	<1.0	no	
Cyanazine	IMAC=10	1	1	10/21/02	<1.0	no	
Diazinon	20	1	1	10/21/02	<1.0	no	
Dicamba	120	1	1	10/21/02	<1.0	no	
2,4 Dichlorophenol	900	1	1	10/21/02	<0.5	no	
DDT + Metabolites	30	1	1	10/21/02	<0.024	no	
2,4 - Dichlorophenoxy acid (2,4 -D)	IMAC=100	1	1	10/21/02	<1.0	no	
Dielfop-methyl	9	1	1	10/21/02	<0.9	no	
Dimethoate	IMAC=20	1	1	10/21/02	<2.5	no	
Dinoseb	10	1	1	10/21/02	<1.0	no	
Diquat	70	1	1	10/21/02	<7.0	no	
Diuron	150	1	1	10/21/02	<10.0	no	
Glyphosate	IMAC=280	1	1	10/21/02	<10.0	no	
Heptachlor + Heptachlor epoxide	3	1	1	10/21/02	<0.012	no	
Lindane	4	1	1	10/21/02	<0.006	no	
Malathion	190	1	1	10/21/02	<5.0	no	
Methoxychlor	900	1	1	10/21/02	<0.024	no	
Metolachlor	IMAC=50	1	1	10/21/02	<0.5	no	
Metribuzin	80	1	1	10/21/02	<5.0	no	
Paraquat	IMAC=10	1	1	10/21/02	<1.0	no	
Parathion	50	1	1	10/21/02	<1.0	no	
Pentachlorophenol	60	1	1	10/21/02	<0.5	no	
Phorate	IMAC=2	1	1	10/21/02	<0.5	no	
Picloram	IMAC=190	1	1	10/21/02	<5.0	no	
Polychlorinated Biphenyls	IMAC=3	1	1	10/21/02	<0.05	no	
Prometryne	IMAC=1	1	1	10/21/02	<0.25	no	
Simazine	IMAC=10	1	1	10/21/02	<1.0	no	
Temephos	IMAC=280	1	1	10/21/02	<10	no	
Terbufos	IMAC=1	1	1	10/21/02	<0.7	no	
2,3,4,6 Tetrachlorophenol	100	1	1	10/21/02	<0.5	no	
Triallate	230	1	1	10/21/02	<1.0	no	
2,4,6-Trichlorophenol	5	1	1	10/21/02	<0.5	no	
2,4,5 - trichlorophenoxy acetic acid	IMAC=280	1	1	10/21/02	<1.0	no	
Trifluralin	45	1	1	10/21/02	<1.0	no	

QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Additional Parameters Non-Health Related (mg/L)	AO or DO	# of Samples	Detachable Results	Sampling Dates (m/d/y)	Range	Exceedence	Typical Source of Contaminant
Colour	5	1	1	01/28/02	2	no	
pH	6.8-8.5	1	1	01/28/02	7.84	no	
Alkalinity	30-500	1	1	01/28/02	205	no	
Total Hardness	80-100	1	1	01/28/02	326	yes	Limits are set as an operational guideline
Sulphate	500	1	1	01/28/02	137	no	
Conductivity	---	1	1	01/28/02	707	no	
Chloride	250	1	1	01/28/02	29	no	
Free Ammonia	---	1	1	01/28/02	<0.02	no	
Total Kjeldahl Nitrogen	---	1	1	01/28/02	0.1	no	
Dissolved Organic Carbon	5	1	1	01/28/02	1.9	no	
Sodium	200	1	1	01/28/02	26	no	
Iron	0.3	1	1	01/28/02	0.45	yes	
Aluminium	0.1	1	1	01/28/02	<0.05	no	
Manganese	0.05	1	1	01/28/02	0.04	no	
Ammonia + Ammonium N		1	1	01/28/02	<0.02	no	
Total Organic Carbon		1	1	01/28/02	2.1	no	
Copper	1	1	1	01/28/02	<0.001	no	
Calcium	---	1	1	01/28/02	86	no	
Magnesium	---	1	1	01/28/02	27	no	

QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Moose Creek Water Plant - Serving the Village of Moose Creek

Questions & Answers

Q. What is an Accredited Laboratory?

A. Accredited labs must have undergone an on-site assessment and performance review of their methods by the Canadian Association of Environmental and Analytical Laboratories. The Standards Council of Canada grants accreditation to the lab based on the recommendation of the CAEAL. The accreditation requirements are repeated every two years.

Q. What had to be done to meet the new regulations?

A. The Moose Creek Water Treatment Plant was following the Ontario Drinking Water Objectives (ODWO) before they became law, so little change was required to meet the new regulations. Our chlorine residual in the water leaving the plant was raised to slightly to achieve the (0.20 mg/L free chlorine) required level in the distribution system, and some changes were required in the way results are reported. This report to the public is also the result of the new regulations.

Q. What parameters did you test for?

A. Microbiological parameters, volatile organic, inorganic and pesticides & PCBs have been tested. The results are included in this report.

Q. Sometimes my water looks rusty or coloured. Why is that, and what should I do about it?

A. This is quite often caused when the tanks in older water heaters start to decay. If the colour is seen only in your hot water, this may be the problem. If the colour is also noticed in your cold water it could be coming from the water main. Various maintenance procedures in the distribution system - such as fire hydrant and valve maintenance, or main break repairs - require flushing of the water mains. Flushing can cause small particles of sediment to break off adding colour to the water. Please note that there is no health risk associated with this problem. This is usually only temporary, and opening your taps for a while to flush out your service line (the pipe from the water main to your house) should take care of the problem. Let the water run until the colour disappears.

MOOSE CREEK WATER REQUIRED SAMPLES

OCTOBER, NOVEMBER, DECEMBER 2002

Chemical Parameters

Table B & D	Well #1	Treated	✓
NO2&NO3	Well #1	Treated	✓
Table B & D	Well #2	Treated	✓
NO2&NO3	Well #2	Treated	✓
System THM		Treated	✓

Date Samples Collected	Initials	Date Results Received	Initials
			Dave

Bacti Parameters

Raw			
Well#1	E.Coli	Total Coli.	Background
Well#2	E.Coli	Total Coli.	Background
Well#3	E.Coli	Total Coli.	Background
Treated			
	E.Coli	Total Coli.	HPC
System			
2 Sites	E.Coli	Total Coli.	HPC 25%

Oct.6	Bacti's	✓
Oct.13	Bacti's	✓
Oct.20	Bacti's	✓
Oct.27	Bacti's	✓

Nov.3	Bacti's	
Nov.10	Bacti's	
Nov.17	Bacti's	
Nov.24	Bacti's	

Dec.1	Bacti's	
Dec.8	Bacti's	
Dec.15	Bacti's	
Dec.22	Bacti's	
Dec.29	Bacti's	

Flouride Treated Water (Annual) ✓
 Lead Distribution System (Annual) ✓
 Table C Treated Water (Jan. 2003)
 Sodium Treated Water (Jan. 2007)

			Dave

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:
Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report: 220010890
Project: Moose Creek WTP
Date Sampled: October 7, 2002
Date Received: October 8, 2002
Date Printed: October 10, 2002
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification				
			Well #2 Raw	Well #3 Raw	Treated Water	M.C. Hall	Paul Adams Cons.
Total Chlorine	mg/L	0.05			2.18	1.52	1.16
Free Chlorine	mg/L	0.05			1.86	1.12	0.96
E. coli	/100mL	1	absent	absent	absent	absent	absent
HPC	/mL	2			absent	absent	
Background bacteria	/100mL	1	absent	2			
Total Coliforms	/100mL	1	absent	absent	2	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:
Ontario Clean Water Agency
Industrial Dr.
Chesterville, ON
K0C 1H0

Report: 220010996
Project: Moose Creek WTP
Date Sampled: October 9, 2002
Date Received: October 10, 2002
Date Printed: October 15, 2002
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well #2 Raw	Well #3 Raw	Treated Water	Elevated Tank
Total Chlorine	mg/L	0.05			2.60	1.83
Free Chlorine	mg/L	0.05			2.20	1.53
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2			absent	absent
Background bacteria	/100mL	1	absent	absent		
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:
Ontario Clean Water Agency
Industrial Dr.
Chesterville, ON
K0C 1H0

Report: **220010997**
Project: Moose Creek WTP
Date Sampled: October 10, 2002
Date Received: October 10, 2002
Date Printed: October 15, 2002
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well #2 Raw	Well #3 Raw	Treated Water	Elevated Tank
Total Chlorine	mg/L	0.05			2.40	1.67
Free Chlorine	mg/L	0.05			2.17	1.40
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2			absent	absent
Background bacteria	/100mL	1	3	2		
Total Coliforms	/100mL	1	absent	2	absent	absent

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
Industrial Dr.
Chesterville, ON
K0C 1H0

Report:

220011203

Project:

Moose Creek WTP

Date Sampled:

October 15, 2002

Date Received:

October 16, 2002

Date Printed:

October 18, 2002

Attention: Dave Markell

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05

Sample ID

Well #2 Raw	1	absent			absent	
Well #3 Raw	absent	absent			absent	
Treated Water		absent	1.99	20	absent	2.35
Dist. SPS		absent	0.56	2	absent	0.68
Dist. Post Office		absent	1.46		absent	1.79

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: **Dave Markell**

Report:

Project:

Date Sampled:

Date Received:

Date Printed:

Matrix:

220011478

Moose Creek WTP

October 21, 2002

October 22, 2002

October 24, 2002

Drinking Water

Sample ID	Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
	Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
	MDL	1	1	0.05	2	1	0.05
Well #2 Raw		2	absent			absent	
Well #3 Raw		85	absent			1	
Treated Water			absent	1.81	2	absent	2.19
Dist. SPS			absent	0.72	absent	absent	0.76
Dist. 2041 Valley St. N			absent	0.64		absent	0.80

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency

Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: **Dave Markell**

Report:

Project:

Date Sampled:

Date Received:

Date Printed:

Matrix:

220011851

Moose Creek WTP

October 28, 2002

October 29, 2002

October 31, 2002

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05
Sample ID						
Well #2 Raw	absent	absent			absent	
Well #3 Raw	20	absent			9	
Treated Water		absent	1.95	2	absent	2.40
Dist. Elevated Tank		absent	0.98	absent	absent	1.22
Dist. M.C. Mall		absent	1.09		absent	1.41

REPORT OF ANALYSIS

Report Number: 2214702
Date: 2002-10-29
Date Submitted: 2002-10-22

Project: Quarterly Chemicals

Matrix: Supply Water

MDL = Method Detection Limit
Comment:

APPROVAL:

[Signature]

ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number: 2214702
Date: 2002-10-25
Date Submitted: 2002-10-22

ATT: Mr. Blair Henderson

Project: Quarterly Chemicals

P.O. Number:
Matrix: Supply Water

LAB ID:			212543				
Sample Date:			2002-10-21				
Sample ID:			MCW-01				
PARAMETER	UNITS	MDL					
BTEX / 624 / PURGEABLE HYDROCARBONS							
Benzene	ug/L	0.5	✓ <0.5				
Toluene	ug/L	0.5	✓ <0.5				
Ethylbenzene	ug/L	0.5	✓ <0.5				
m/p-xylene	ug/L	1.0	<1.0				
o-xylene	ug/L	0.5	<0.5				
Bromodichloromethane	ug/L	0.3	✓ 15.2				
Bromoform	ug/L	0.4	✓ 0.5				
Carbon Tetrachloride	ug/L	0.9	✓ <0.9				
Monochlorobenzene	ug/L	0.2	✓ <0.2				
Chloroform	ug/L	0.5	✓ 28.3				
Dibromochloromethane	ug/L	0.3	✓ 7.3				
1,2-dichlorobenzene	ug/L	0.4	✓ <0.4				
1,4-dichlorobenzene	ug/L	0.4	✓ <0.4				
1,2-dichloroethane	ug/L	0.7	✓ <0.7				
1,1-dichloroethylene	ug/L	0.5	✓ <0.5				
Dichloromethane	ug/L	4.0	✓ <4.0				
Tetrachloroethylene	ug/L	0.3	✓ <0.3				
Trichloroethylene	ug/L	0.3	✓ <0.3				
Vinyl Chloride	ug/L	0.5	✓ <0.5				
TOTALS							
Trihalomethanes (total)	ug/L	2.0	✓ 51.3				
Xylene; total	ug/L	2.0	✓ <2.0				
BTEX / 624 Surrogate Recoveries							
Toluene-d8	%		97				
1,2-dichloroethane-d4	%		99				
4-bromofluorobenzene	%		100				

MDL = Method Detection Limit
Comment:

INC = Incomplete

APPROVAL: _____

ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number:

2214702

Date:

2002-11-07

Date Submitted:

2002-10-22

ATT: Mr. Blair Henderson

Project:

Quarterly Chemicals

Sample Matrix:

Supply Water

			LAB ID:	212543				
			Sample Date:	2002-10-21				
			Sample ID:	MCW-01				
PARAMETER	UNITS	MDL						
PESTICIDES & PCB's								
Alachlor	ug/L	0.5	✓	<0.5				
Aldicarb	ug/L	5	✓	<5				
Aldrin	ug/L	0.006		<0.006				
Aldrin + Dieldrin	ug/L	0.012	✓	<0.012				
Atrazine	ug/L	0.5	✓	<0.5				
Desethyl-atrazine	ug/L	0.5		<0.5				
Atrazine+Desethyl-atrazine	ug/L	1		<1				
Azinphos-methyl	ug/L	2	✓	<2				
Bendiocarb	ug/L	2	✓	<2				
Chloroxynil	ug/L	0.5	✓	<0.5				
Carbaryl	ug/L	5	✓	<5				
Carbofuran	ug/L	5	✓	<5				
Chlordane (Total)	ug/L	0.012	✓	<0.012				
α-Chlorodane	ug/L	0.006		<0.006				
γ-Chlorodane	ug/L	0.006		<0.006				
Oxychlorodane	ug/L	0.006		<0.006				
Chloropyrifos	ug/L	1	✓	<1				
Cyanazine	ug/L	1	✓	<1				
Diazinon	ug/L	1	✓	<1				
Dicamba	ug/L	1	✓	<1				
Dieldrin	ug/L	0.006		<0.006				
Diquat	ug/L	7	✓	<7				
2,4-Dichlorophenol	ug/L	0.5	✓	<0.5				
DDT + Metabolites	ug/L	0.024	✓	<0.024				
o,p'-DDT	ug/L	0.006		<0.006				
p,p'-DDT	ug/L	0.006		<0.006				
2,4-D	ug/L	1	✓	<1				
p,p'-DDE	ug/L	0.006		<0.006				

NOTE: mg/L (ppm)=1000xug/L (ppb)

MDL = Method Detection Limit

Comment:

APPROVAL:

146 Colonnade Road, Unit 8, Nepean, Ontario K2E 7Y1 Tel:(613)727-5692 Fax:(613)727-5222

ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number: 2214702
Date: 2002-11-07
Date Submitted: 2002-10-22

ATT: Mr. Blair Henderson

Project: Quarterly Chemicals

Sample Matrix: Supply Water

LAB ID:			212543				
Sample Date:			2002-10-21				
Sample ID:			MCW-01				
PARAMETER	UNITS	MDL					
p,p'-DDD	ug/L	0.006	<0.006				
Diclofop-methyl	ug/L	0.9	✓<0.9				
Dimethoate	ug/L	2.5	✓<2.5				
Dinoseb	ug/L	1	✓<1				
Diuron	ug/L	10	✓<10				
Glyphosate	ug/L	10	✓<10				
Heptachlor	ug/L	0.006	<0.006				
Heptachlor epoxide	ug/L	0.006	<0.006				
Heptachlor + Hept. Epoxide	ug/L	0.012	✓<0.012				
Endane	ug/L	0.006	✓<0.006				
Malathion	ug/L	5	✓<5				
Methoxychlor	ug/L	0.024	✓<0.024				
Metolachlor	ug/L	0.5	✓<0.5				
Metribuzin	ug/L	5	✓<5				
Paraquat	ug/L	1	✓<1				
Parathion	ug/L	1	✓<1				
Pentachlorophenol	ug/L	0.5	✓<0.5				
Phorate	ug/L	0.5	✓<0.5				
Picloram	ug/L	5	✓<5				
PCB's (total)	ug/L	0.05	✓<0.05				
Prometryne	ug/L	0.25	✓<0.25				
Simazine	ug/L	1	✓<1				
Temephos	ug/L	10	✓<10				
Terbufos	ug/L	0.7	✓<0.7				
2,3,4,6-Tetrachlorophenol	ug/L	0.5	✓<0.5				
Triallate	ug/L	1	✓<1				
2,4,6-Trichlorophenol	ug/L	0.5	✓<0.5				
Trifluralin	ug/L	1	✓<1				
2,4,5-T	ug/L	1	✓<1				

NOTE: mg/L (ppm)=1000xug/L (ppb)

MDL = Method Detection Limit

Comment:

APPROVAL: _____

ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number: 2214701
Date: 2002-10-25
Date Submitted: 2002-10-22

ATT: Mr. Blair Henderson

Project: Quarterly Chemicals

P.O. Number:

Matrix: Supply Water

LAB ID:			212542				
Sample Date:			2002-10-21				
Sample ID:			MCW-02				
PARAMETER	UNITS	MDL					
BTEX / 624 / PURGEABLE HYDROCARBONS							
Bromodichloromethane	ug/L	0.3	17.4				
Bromoform	ug/L	0.4	0.4				
Chloroform	ug/L	0.5	47.7				
Dibromochloromethane	ug/L	0.3	7.6				
TOTALS							
Trihalomethanes (total)	ug/L	2.0	73.1				
BTEX / 624 Surrogate Recoveries							
Toluene-d8	%		88				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL: 

ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: MOOSE CREEK WELL SUPPLY

Report Number: 2215175
Date: 2002-11-06
Date Submitted: 2002-10-29

ATT: Mr. Blair Henderson

Project:

P.O. Number:

Matrix: Supply Water

LAB ID:			214335				
Sample Date:			2002-10-28				
Sample ID:			MCW- Xylene				
PARAMETER	UNITS	MDL					
TOTALS Xylene; total	ug/L	2.0	<2.0				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL:



Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency

8 Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: **Dave Markell**

Report:

220012190

Project:

Moose Creek WTP

Date Sampled:

November 4, 2002

Date Received:

November 5, 2002

Date Printed:

November 07, 2002

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05


Sample ID

Well #2 Raw	1	absent			absent	
Well #3 Raw	28	absent			15	
Treated Water		absent	1.72	absent	absent	1.99
Dist. Elevated Tank		absent	0.93	absent	absent	1.11
Dist. Post Office		absent	1.09		absent	1.29

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244


For Michael Ziebell, General Manager

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Report:

220012670

Project:

Moose Creek WTP

Date Sampled:

November 12, 2002

Date Received:

November 13, 2002

Date Printed:

November 15, 2002

Attention: Dave Markell

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05

Sample ID

Well #2 Raw	absent	absent			absent	
Well #3 Raw	1	absent			1	
Treated Water		absent	1.41	absent	absent	1.77
Dist. S.P.S		absent	0.65	absent	absent	0.75
Dist. 2265 Valley St.		absent	0.52		absent	0.62

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: **Dave Markell**

Report:

220012904

Project:

Moose Creek WTP

Date Sampled:

November 18, 2002

Date Received:

November 19, 2002

Date Printed:

November 21, 2002

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05
Sample ID						
Well # 2 Raw	5	absent			absent	
Well # 3 Raw	2	absent			1	
Treated Water		absent	1.71	absent	absent	2.02
Dist .Elevated Tank		absent	0.73	absent	absent	0.93
Post Office		absent	0.79		absent	0.91

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency

Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: Dave Markell

Report:

220013266

Project:

Moose Creek WTP

Date Sampled:

November 25, 2002

Date Received:

November 26, 2002

Date Printed:

November 28, 2002

Matrix:

Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well #2 Raw	Well #3 Raw	Treated Water -16950 McNeil Rd	Dist. SPS
Total Chlorine	mg/L	0.05			2.07	1.03
Free Chlorine	mg/L	0.05			1.65	0.87
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2			absent	absent
Background bacteria	/100mL	1	absent	absent		
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

ario Clean Water Agency
Industrial Dr.
Chesterville, ON
K0C 1H0

Report:

220013595

Project:

Moose Creek WTP

Date Sampled:

December 2, 2002

Date Received:

December 3, 2002

Date Printed:

December 05, 2002

Attention: Dave Markell

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05
Sample ID						
Well #2 Raw	absent	absent			absent	
Well #3 Raw	absent	absent			absent	
Treated Water		absent	1.73	absent	absent	2.20
Dist. Elevated Tank		absent	1.16	absent	absent	1.49
Dist. Post Office		absent	0.78		absent	0.98

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
5 Industrial Dr.
Chesterville, ON
K0C 1H0

Attention: Dave Markell

Report:

220013980

Project:

Moose Creek WTP

Date Sampled:

December 9, 2002

Date Received:

December 10, 2002

Date Printed:

December 12, 2002

Matrix:

Drinking Water

Parameter	Unit	MDL	Sample Identification				
			Well #2 Raw	Well #3 Raw	Treated Water	Dist. SPS	Dist. Moose Creek Main
Total Chlorine	mg/L	0.05			2.40	1.06	1.43
Free Chlorine	mg/L	0.05			1.93	0.94	1.16
E. coli	/100mL	1	absent	absent	absent	absent	absent
HPC	/mL	2			2	2	
Background bacteria	/100mL	1	absent	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario K1H 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency

Industrial Dr.

Chesterville, ON

K0C 1H0

Report:

220014314

Project:

Moose Creek WTP

Date Sampled:

December 16, 2002

Date Received:

December 17, 2002

Date Printed:

December 19, 2002

Attention: Dave Markell

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05
Sample ID						
Well #2 Raw	absent	absent			absent	
Well #3 Raw	absent	absent			absent	
Treated Water		absent	1.86	absent	absent	2.40
Dist. Elevated Tank		absent	1.14	absent	absent	1.36
Dist. 2041 Valley St.		absent	0.57		absent	0.69

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
Industrial Dr.
Chesterville, ON
K0C 1H0

Report:

220014629

Project:

Moose Creek WTP

Date Sampled:

December 23, 2002

Date Received:

December 23, 2002

Date Printed:

December 27, 2002

Attention: Dave Markell

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05

Sample ID

Well #2 Raw	absent	absent			absent	
Well #3 Raw	absent	absent			absent	
Treated Water		absent	1.81	absent	absent	2.18
Dist. Water Tower		absent	1.11	absent	absent	1.43
Dist. Moose Creek Mall		absent	1.39		absent	1.68

Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

Certificate of Analysis

Client:

Ontario Clean Water Agency
Industrial Dr.
Chesterville, ON
K0C 1H0

Report:

220014786

Project:

Moose Creek WTP

Date Sampled:

December 30, 2002

Date Received:

December 30, 2002

Date Printed:

January 02, 2003

Attention: **Dave Markell**

Matrix:

Drinking Water

Parameter	Background	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	1	0.05	2	1	0.05

Sample ID

Well # 2 Raw	absent	absent			absent	
Well # 3 Raw	absent	absent			absent	
Treated Water		absent	1.77	absent	absent	2.20
Dist. Moose Creek Mall		absent	1.10	absent	absent	1.40
Dist. Moose Creek Post Office		absent	0.86		absent	1.10

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244