

**ARCHIVED**

**MUNICIPAL WATER QUALITY  
REPORTS**

**FINCH WATER**

2002



**Ontario Clean Water Agency  
Agence Ontarienne Des Eaux**

*Chesterville Hub*  
5 Industrial Drive, P.O. Box 460  
Chesterville, Ontario K0C 1H0  
Tel: (613) 448-3098  
Fax: (613) 448-1616  
www.ocwa.com

# Fax

To MWH MOE

Company \_\_\_\_\_

Fax Number 933-7930 268-6061

From Dave

Date Oct 31/02

Number of Pages 3 (including this page)

Subject Finch 210003912

- Turb. over 1.0 NTU
- New Filters being Installed
- Bacti samples have been sent, results tomorrow on disinfected new equip.
- If. Samples show no bacti they will be put on line.

## Notice of Drinking Water Analysis and Remedial Actions for Waterworks as Required under Drinking Water Protection Regulation

In accordance with the Drinking Water Protection Regulation, Laboratories and Water Works Owners must immediately provide oral notification to the MOE Spills Action Centre (SAC) at 1-800-268-6060 or 1-416-325-3000 and the local Medical Officer of Health (MOH) of indicators of adverse drinking water quality and exceedances of standards as outlined in the Regulation and remedial actions taken. Further, within 24 hours of the oral notification, the party shall provide written notification on this completed form by Fax to the Spills Action Centre at 1-800-268-6061 or 1-416-325-3011 and the local Medical Officer of Health. Failure to notify these parties in accordance with the Regulation constitutes an offence under the Act. A copy of this form may be acquired through the Ministry of the Environment (MOE) public web site ([www.ene.gov.on.ca](http://www.ene.gov.on.ca)) or by contacting any MOE office.

### PART 1 - NOTIFICATION BY LABORATORY

Indicators of Adverse Water Quality <input type="checkbox"/>	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
<b>ORAL NOTIFICATION to SPILLS ACTION CENTRE by LABORATORY</b>		
Date:	Time:	By:
Laboratory Name:	Laboratory Emergency Contact Name	
Address	Position	
Email address	Phone #	Fax #
Waterworks Name	Waterworks Emergency Contact	
Works #	Name	
Location	Position	
Email Address	Phone #	Fax #
<b>NOTIFICATION OF WATER WORKS OWNER</b>		<b>NOTIFICATION OF LOCAL MEDICAL OFFICER OF HEALTH</b>
Person Contacted		Person Contacted
Position		Position
Date		Date
Time		Time
Laboratory Written Notification Prepared by: (Lab Results must be attached using Part 3 of form)		Name (please print)
Signature		Date

### PART 2 - NOTIFICATION BY WATER WORKS OWNER

Indicators of Adverse Water Quality <input checked="" type="checkbox"/>	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
<input checked="" type="checkbox"/> This notification is for operational problems identified at the waterworks; there is no Laboratory notification associated with this report		
<b>SPILLS ACTION CENTRE ORAL NOTIFICATION BY OWNER</b>		<b>WATERWORKS EMERGENCY CONTACT</b>
Date OCT. 31/02 Time 16:00		Name Dave Markell
Waterworks Name Finch Water		Position Process Tech.
Works # 210003912		Phone # 613-448-3098 Fax # 613-448-1616
Works Person Providing Oral Notification Dave Markell		
<b>MEDICAL OFFICER OF HEALTH ORAL NOTIFICATION BY OWNER</b>		<b>REMEDIAL ACTIONS TAKEN BY OWNER:</b>
Date Oct. 31/02 Time 16:00		Resampling Initiated <input type="checkbox"/> Yes <input type="checkbox"/> No
Person Contacted Adalia		Increase Chlorine Dose <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Position Special Project		Flushing Mains <input type="checkbox"/> Yes <input type="checkbox"/> No
Phone # 800-267-7120 Fax # 613-933-7930		Other Actions Taken <input type="checkbox"/> Yes <input type="checkbox"/> No
Works Person Providing Oral Notification Dave Markell		Describe:
Water Works Written Notification Prepared by: Name (please print) Dave Markell		Other information attached <input checked="" type="checkbox"/>
Signature Dave Markell		Date Oct. 31/02
For Ministry Use Only:		Occurrence Report #:

## PART 3:

**ADVERSE ANALYTICAL RESULTS - For Indicators Listed in SCHEDULE 6 -  
Drinking Water Protection Regulation**
**Microbiological Testing**

Lab Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) ( : am pm )	Sample Type / Location	Membrane Filtration Count/100mL			P-A/100mL Presumptive/ Confirmed (if applicable)	HPC/ 1mL	Date - Plates Prepared (M/D/Y)	Date - Plates Read (M/D/Y)
				Total Coliforms	Back- ground	E.coli <input type="checkbox"/> Fecal C. <input type="checkbox"/>				

**ADVERSE ANALYTICAL RESULTS - For Parameters Listed in SCHEDULE 4 and 5 or in a C of A or Order  
Drinking Water Protection Regulation**
**Physical/Chemical/Radiological Testing**

Lab Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) ( : am pm )	Sample Type / Location	Parameter	Result	Unit	MAC/ IMAC	Date - Analysis Completed (M/D/Y)	Date - Data Approved (M/D/Y)
	ON LINE	Cont.	Turbidity	Turbidity	1.9	NTU		Continuous	

Results Authorized By:	Authorization Date:
------------------------	---------------------

For Ministry Use Only:	Occurrence Report #:
------------------------	----------------------

HP OfficeJet K Series K80  
Personal Printer/Fax/Copier/Scanner

Log for  
OCWA  
613 448-1616  
Oct 31 2002 4:19pm

---

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Oct 31	4:18pm	Fax Sent	18002686061	0:49	3	OK

---

HP OfficeJet K Series K80  
Personal Printer/Fax/Copier/Scanner

Log for  
OCWA  
613 448-1616  
Oct 31 2002 4:22pm

---

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Oct 31	4:19pm	Fax Sent	16139337930	2:20	3	OK

---



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

*Chesterville Hub*  
5 Industrial Drive, P.O. Box 460  
Chesterville, Ontario K0C 1H0  
Tel: (613) 448-3098  
Fax: (613) 448-1616  
www.ocwa.com

# Fax

To Mott MOE

Company \_\_\_\_\_

Fax Number 613-933-7930 1-800-268-6061

From Dave

Date Oct-29/02

Number of Pages 3 (including this page)

Subject Finch

- Works # 210003912
- Turb exceedances over 1 NTU
- Filter being replaced
- Filters bypassed in interim.
- Media presently in & being superchlorinated.
- backwash test tomorrow & bacti sampling

## Notice of Drinking Water Analysis and Remedial Actions for Waterworks as Required under Drinking Water Protection Regulation

In accordance with the Drinking Water Protection Regulation, Laboratories and Water Works Owners must immediately provide oral notification to the MOE Spills Action Centre (SAC) at 1-800-268-6060 or 1-416-325-3000 and the local Medical Officer of Health (MOH) of indicators of adverse drinking water quality and exceedances of standards as outlined in the Regulation and remedial actions taken. Further, within 24 hours of the oral notification, the party shall provide written notification on this completed form by Fax to the Spills Action Centre at 1-800-268-6061 or 1-416-325-3011 and the local Medical Officer of Health. Failure to notify these parties in accordance with the Regulation constitutes an offence under the Act. A copy of this form may be acquired through the Ministry of the Environment (MOE) public web site ([www.ene.gov.on.ca](http://www.ene.gov.on.ca)) or by contacting any MOE office.

### PART 1 - NOTIFICATION BY LABORATORY

Indicators of Adverse Water Quality <input type="checkbox"/>	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
<b>ORAL NOTIFICATION to SPILLS ACTION CENTRE by LABORATORY</b>		
Date:	Time:	By:
Laboratory Name:	Laboratory Emergency Contact Name	
Address	Position	
Email address	Phone #	Fax #
Waterworks Name	Waterworks Emergency Contact	
Works #	Name	
Location	Position	
Email Address	Phone #	Fax #
<b>NOTIFICATION OF WATER WORKS OWNER</b>		<b>NOTIFICATION OF LOCAL MEDICAL OFFICER OF HEALTH</b>
Person Contacted		Person Contacted
Position		Position
Date		Date
Time		Time
Laboratory Written Notification Prepared by: (Lab Results must be attached using Part 3 of form)		Name (please print )
Signature		Date

### PART 2 - NOTIFICATION BY WATER WORKS OWNER

Indicators of Adverse Water Quality <input checked="" type="checkbox"/>	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
<input checked="" type="checkbox"/> This notification is for operational problems identified at the waterworks; there is no Laboratory notification associated with this report		
<b>SPILLS ACTION CENTRE ORAL NOTIFICATION BY OWNER</b>		<b>WATERWORKS EMERGENCY CONTACT</b>
Date Oct 29/02 Time 15:02		Name Dave Markell
Waterworks Name Finch Water		Position Process Tech
Works # 210003912		Phone # 613-448-3098 Fax # 613-448-1616
Works Person Providing Oral Notification Dave Markell		
<b>MEDICAL OFFICER OF HEALTH ORAL NOTIFICATION BY OWNER</b>		<b>REMEDIAL ACTIONS TAKEN BY OWNER:</b>
Date Oct 29/02 Time 15:00		Resampling Initiated <input type="checkbox"/> Yes <input type="checkbox"/> No
Person Contacted Adia Adahia		Increase Chlorine Dose <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Position Special Projects		Flushing Mains <input type="checkbox"/> Yes <input type="checkbox"/> No
Phone # 267-7120 Fax # 613-933-7930		Other Actions Taken <input type="checkbox"/> Yes <input type="checkbox"/> No
Works Person Providing Oral Notification Dave Markell		Describe:
Water Works Written Notification Prepared by: Name (please print ) Dave Markell		Other information attached <input checked="" type="checkbox"/>
Signature Dave Markell		Date Oct 29/02
<b>For Ministry Use Only:</b>		
<b>Occurrence Report #:</b>		



## PART 3:

**ADVERSE ANALYTICAL RESULTS - For Indicators Listed in SCHEDULE 6 -  
Drinking Water Protection Regulation**
**Microbiological Testing**

Lab Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) ( : am pm )	Sample Type / Location	Membrane Filtration Count/100mL			P-A/100mL Presumptive/ Confirmed (if applicable)	HPC/ 1mL	Date - Plates Prepared (M/D/Y)	Date - Plates Read (M/D/Y)
				Total Coliforms	Back- ground	E.coli <input type="checkbox"/> Fecal C. <input type="checkbox"/>				

**ADVERSE ANALYTICAL RESULTS - For Parameters Listed in SCHEDULE 4 and 5 or in a C of A or Order  
Drinking Water Protection Regulation**
**Physical/Chemical/Radiological Testing**

Lab Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) ( : am pm )	Sample Type / Location	Parameter	Result	Unit	MAC/ IMAC	Date - Analysis Completed (M/D/Y)	Date - Data Approved (M/D/Y)
		ON LINE	Cont.	Turbidity	1.7	NTU		continuous	

Results Authorized By:	Authorization Date:
------------------------	---------------------

For Ministry Use Only:	Occurrence Report #:
------------------------	----------------------

HP OfficeJet K Series K80  
Personal Printer/Fax/Copier/Scanner

Log for  
OCWA  
613 448-1616  
Oct 29 2002 3:20pm

---

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Oct 29	3:19pm	Fax Sent	18002686061	0:48	3	OK

---

HP OfficeJet K Series K80  
Personal Printer/Fax/Copier/Scanner

Log for  
OCWA  
613 448-1616  
Oct 29 2002 3:18pm

---

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Oct 29	3:15pm	Fax Sent	16139337930	2:20	3	OK

---



**Ontario Clean Water Agency  
Agence Ontarienne Des Eaux**

**Chesterville Hub**  
5 Industrial Drive, P.O. Box 460  
Chesterville, Ontario K0C 1H0  
Tel: (613) 448-3098  
Fax: (613) 448-1616  
www.ocwa.com

# Fax

To

MOT MOE.

Company

\_\_\_\_\_

Fax Number

933-7930 800-268-6061

From

Dave Markell

Date

Oct 26/02

Number of Pages

3 (including this page)

Subject

Finch Water Treatment Plant. 210003912

see fax  
LOS  
Oct. 27/02

- New Sand filters are being installed.
- Presently by passing filters
- On line turbidimeter shows 1.5 → 2.0 NTU  
Turbidity
- Raw Water from source (Well #1)
- Bact results Since Jan. 2002  
No E coli at any time, On ONE occasion  
1 detected T coli form, No counts of HPC or  
Background greater than 5.
- Cl<sub>2</sub> dosage has been increased and  
Free Cl<sub>2</sub> at plant will be kept at 2.4 mg/L  
0.5 higher than normal.
- Work will take 5 days.

Caution: This fax is private property intended solely for the information and use of the addressee. The contents are confidential and may be privileged. Any unauthorized use of this fax is strictly prohibited. If you are not the addressee, please notify sender immediately by telephone and either return or destroy this fax.

## Notice of Drinking Water Analysis and Remedial Actions for Waterworks as Required under Drinking Water Protection Regulation

In accordance with the Drinking Water Protection Regulation, Laboratories and Water Works Owners must immediately provide oral notification to the MOE Spills Action Centre (SAC) at 1-800-268-6060 or 1-416-325-3000 and the local Medical Officer of Health (MOH) of indicators of adverse drinking water quality and exceedances of standards as outlined in the Regulation and remedial actions taken. Further, within 24 hours of the oral notification, the party shall provide written notification on this completed form by Fax to the Spills Action Centre at 1-800-268-6061 or 1-416-325-3011 and the local Medical Officer of Health. Failure to notify these parties in accordance with the Regulation constitutes an offence under the Act. A copy of this form may be acquired through the Ministry of the Environment (MOE) public web site ([www.ene.gov.on.ca](http://www.ene.gov.on.ca)) or by contacting any MOE office.

### PART 1 - NOTIFICATION BY LABORATORY

Indicators of Adverse <input type="checkbox"/> Water Quality	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
<b>ORAL NOTIFICATION to SPILLS ACTION CENTRE by LABORATORY</b>		
Date:	Time:	By:
Laboratory Name:	Laboratory Emergency Contact Name	
Address	Position	
Email address	Phone #	Fax #
Waterworks Name	Waterworks Emergency Contact	
Works #	Name	
Location	Position	
Email Address	Phone #	Fax #
<b>NOTIFICATION OF WATER WORKS OWNER</b>		<b>NOTIFICATION OF LOCAL MEDICAL OFFICER OF HEALTH</b>
Person Contacted		Person Contacted
Position		Position
Date	Time	Date
Laboratory Written Notification Prepared by: (Lab Results must be attached using Part 3 of form)		Name (please print)
Signature		Date

### PART 2 - NOTIFICATION BY WATER WORKS OWNER

Indicators of Adverse <input checked="" type="checkbox"/> Water Quality	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
<input checked="" type="checkbox"/> This notification is for operational problems identified at the waterworks; there is no Laboratory notification associated with this report		
<b>SPILLS ACTION CENTRE ORAL NOTIFICATION BY OWNER</b>		<b>WATERWORKS EMERGENCY CONTACT</b>
Date <u>Oct. 26/02</u> Time <u>14:30</u>		Name <u>Jean Van Hout</u>
Waterworks Name <u>Finch Water</u>		Position <u>Process Tech</u>
Works # <u>210003912</u> <u>Jean Van Hout</u>		Phone # <u>613-448-3093</u> Fax # <u>613-448-1616</u>
Works Person Providing Oral Notification		
<b>MEDICAL OFFICER OF HEALTH ORAL NOTIFICATION BY OWNER</b>		<b>REMEDIAL ACTIONS TAKEN BY OWNER:</b>
Date <u>Oct 2, 2002</u> Time <u>11:35</u>		Resampling Initiated <input type="checkbox"/> Yes <input type="checkbox"/> No
Person Contacted <u>Christine</u>		Increase Chlorine Dose <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Position <u>Answering Service</u>		Flushing Mains <input type="checkbox"/> Yes <input type="checkbox"/> No
Phone # <u>18002677120</u> Fax # <u>933-7930</u>		Other Actions Taken <input type="checkbox"/> Yes <input type="checkbox"/> No
Works Person Providing Oral Notification		Describe:
Water Works Written Notification Prepared by: Name (please print)		Other information attached <input checked="" type="checkbox"/>
Signature <u>Jean Van Hout</u>		Date <u>Oct. 26/02</u>
For Ministry Use Only:		Occurrence Report #:

## PART 3:

**ADVERSE ANALYTICAL RESULTS - For Indicators Listed in SCHEDULE 6 -  
Drinking Water Protection Regulation**
**Microbiological Testing**

Lab Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) ( : am pm )	Sample Type / Location	Membrane Filtration Count/100mL			P-A/100mL Presumptive/ Confirmed (if applicable)	HPC/ 1mL	Date - Plates Prepared (M/D/Y)	Date - Plates Read (M/D/Y)
				Total Coliforms	Back- ground	E.coli <input type="checkbox"/> Fecal C. <input type="checkbox"/>				

**ADVERSE ANALYTICAL RESULTS - For Parameters Listed in SCHEDULE 4 and 5 or in a C of A or Order  
Drinking Water Protection Regulation**
**Physical/Chemical/Radiological Testing**

Lab Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) ( : am pm )	Sample Type / Location	Parameter	Result	Unit	MAC/ IMAC	Date - Analysis Completed (M/D/Y)	Date - Data Approved (M/D/Y)
			ON LINE	Turbidity	1.7	NTU		Continuous.	

Results Authorized By:

Authorization Date:

For Ministry Use Only:

Occurrence Report #:

HP OfficeJet K Series K80  
Personal Printer/Fax/Copier/Scanner

Log for  
OCWA  
613 448-1616  
Oct 27 2002 5:36pm

---

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Oct 27	5:35pm	Fax Sent	1 800 268-6061	0:50	3	OK

---

HP OfficeJet K Series K80  
Personal Printer/Fax/Copier/Scanner

Log for  
OCWA  
613 448-1616  
Oct 27 2002 5:34pm

---

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Oct 27	5:32pm	Fax Sent	1 613 933-7930	2:25	3	OK

---





**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

*Chesterville Hub*  
5 Industrial Drive, P.O. Box 460  
Chesterville, Ontario K0C 1H0  
Tel: (613) 448-3098  
Fax: (613) 448-1616  
www.ocwa.com

# Fax

To Mott MOE.

Company \_\_\_\_\_

Fax Number 933-7930 800-268-6061

From Dave Markell

Date Oct 25/02

Number of Pages 3 (including this page)

Subject Finch Water Treatment Plant. 210003912

- New Sand filters are being installed.
- Presently by passing filters
- On line turbidimeter. shows 1.5 → 2.0 NTU  
Turbidity
- Raw water from source (well #1)
- Bact results Since Jan. 2002  
No E coli at any time, On ONE occasion  
I detected T coliform, No counts of HPC or  
Background greater than 5.
- Cl<sub>2</sub> dosage has been increased and  
Free Cl<sub>2</sub> at plant will be kept at 2.4 mg/L  
0.5 higher than normal.
- Work will take 5 days.

**Caution:** This fax is private property intended solely for the information and use of the addressee. The contents are confidential and may be privileged. Any unauthorized use of this fax is strictly prohibited. If you are not the addressee, please notify sender immediately by telephone and either return or destroy this fax.

## Notice of Drinking Water Analysis and Remedial Actions for Waterworks as Required under Drinking Water Protection Regulation

In accordance with the Drinking Water Protection Regulation, Laboratories and Water Works Owners must immediately provide oral notification to the MOE Spills Action Centre (SAC) at 1-800-268-6060 or 1-416-325-3000 and the local Medical Officer of Health (MOH) of indicators of adverse drinking water quality and exceedances of standards as outlined in the Regulation and remedial actions taken. Further, within 24 hours of the oral notification, the party shall provide written notification on this completed form by Fax to the Spills Action Centre at 1-800-268-6061 or 1-416-325-3011 and the local Medical Officer of Health. Failure to notify these parties in accordance with the Regulation constitutes an offence under the Act. A copy of this form may be acquired through the Ministry of the Environment (MOE) public web site ([www.ene.gov.on.ca](http://www.ene.gov.on.ca)) or by contacting any MOE office.

### PART 1 - NOTIFICATION BY LABORATORY

Indicators of Adverse Water Quality <input type="checkbox"/>	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
<b>ORAL NOTIFICATION to SPILLS ACTION CENTRE by LABORATORY</b>		
Date:	Time:	By:
Laboratory Name:	Laboratory Emergency Contact Name	
Address	Position	
Email address	Phone #	Fax #
Waterworks Name	Waterworks Emergency Contact	
Works #	Name	
Location	Position	
Email Address	Phone #	Fax #
<b>NOTIFICATION OF WATER WORKS OWNER</b>		<b>NOTIFICATION OF LOCAL MEDICAL OFFICER OF HEALTH</b>
Person Contacted		Person Contacted
Position		Position
Date	Time	Date
Laboratory Written Notification Prepared by: (Lab Results must be attached using Part 3 of form)		Name (please print)
Signature		Date

### PART 2 - NOTIFICATION BY WATER WORKS OWNER

Indicators of Adverse Water Quality <input checked="" type="checkbox"/>	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
<input checked="" type="checkbox"/> This notification is for operational problems identified at the waterworks; there is no Laboratory notification associated with this report		
<b>SPILLS ACTION CENTRE ORAL NOTIFICATION BY OWNER</b>		<b>WATERWORKS EMERGENCY CONTACT</b>
Date Oct. 25/02	Time 11:30	Name Dave Markell
Waterworks Name Finch Water		Position Process Tech
Works # 210003912		Phone # 613-448-3093 Fax # 613-448-1616
Works Person Providing Oral Notification Dave Markell		
<b>MEDICAL OFFICER OF HEALTH ORAL NOTIFICATION BY OWNER</b>		<b>REMEDIAL ACTIONS TAKEN BY OWNER:</b>
Date Oct 25/02	Time 11:35	Resampling Initiated <input type="checkbox"/> Yes <input type="checkbox"/> No
Person Contacted Addin		Increase Chlorine Dose <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Position Special Project		Flushing Mains <input type="checkbox"/> Yes <input type="checkbox"/> No
Phone # 18002677120 Fax # 933-7930		Other Actions Taken <input type="checkbox"/> Yes <input type="checkbox"/> No
Works Person Providing Oral Notification Dave Markell		Describe:
Water Works Written Notification Prepared by: Name (please print) Dave Markell		Other information attached <input checked="" type="checkbox"/>
Signature Dave Markell		Date Oct. 25/02
For Ministry Use Only:		Occurrence Report #:

## PART 3:

**ADVERSE ANALYTICAL RESULTS - For Indicators Listed in SCHEDULE 6 -  
Drinking Water Protection Regulation**
**Microbiological Testing**

Lab Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) ( : am pm )	Sample Type / Location	Membrane Filtration Count/100mL			P-A/100mL Presumptive/ Confirmed (if applicable)	HPC/ 1mL	Date - Plates Prepared (M/D/Y)	Date - Plates Read (M/D/Y)
				Total Coliforms	Back- ground	E.coli <input type="checkbox"/> Fecal C. <input type="checkbox"/>				

**ADVERSE ANALYTICAL RESULTS - For Parameters Listed in SCHEDULE 4 and 5 or in a C of A or Order  
Drinking Water Protection Regulation**
**Physical/Chemical/Radiological Testing**

Lab Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) ( : am pm )	Sample Type / Location	Parameter	Result	Unit	MAC/ IMAC	Date - Analysis Completed (M/D/Y)	Date - Data Approved (M/D/Y)
			ON LINE	Turbidity	1.7	NTU		Continuous	

Results Authorized By:

Authorization Date:

For Ministry Use Only:

Occurrence Report #:

HP OfficeJet K Series K80  
Personal Printer/Fax/Copier/Scanner

Log for  
OCWA  
613 448-1616  
Oct 25 2002 11:42am

---

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Oct 25	11:42am	Fax Sent	18002686061	0:47	3	OK

---

HP OfficeJet K Series K80  
Personal Printer/Fax/Copier/Scanner

Log for  
OCWA  
613 448-1616  
Oct 25 2002 11:45am

---

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Oct 25	11:43am	Fax Sent	16139337930	2:22	3	OK

---



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

*Chesterville Hub*  
5 Industrial Drive, P.O. Box 460  
Chesterville, Ontario K0C 1H0  
Tel: (613) 448-3098  
Fax: (613) 448-1616  
[www.ocwa.com](http://www.ocwa.com)

# Fax

To MDH MOE.

Company \_\_\_\_\_

Fax Number 933-7930 800-268-6061

From Dave Markell

Date Oct 23/02

Number of Pages 3 (including this page)

Subject Finch Water Treatment Plant.

- New Sand filters are being installed.
- Presently by passing filters
- On line turbidimeter shows 1.5 → 2.0 NTU  
Turbidity
- Raw Water from source (Well #1)
- Bact results Since Jan. 2002  
No E coli at any time, On ONE occasion  
1 detected T coliform, No counts of HPC or  
Background greater than 5.
- Cl<sub>2</sub> dosage has been increased and  
Free Cl<sub>2</sub> at plant will be kept at 2.4 mg/L  
0.5 higher than normal.
- Work will take 5 days.

Caution: This fax is private property intended solely for the information and use of the addressee. The contents are confidential and may be privileged. Any unauthorized use of this fax is strictly prohibited. If you are not the addressee, please notify sender immediately by telephone and either return or destroy this fax.

## Notice of Drinking Water Analysis and Remedial Actions for Waterworks as Required under Drinking Water Protection Regulation

In accordance with the Drinking Water Protection Regulation, Laboratories and Water Works Owners must immediately provide oral notification to the MOE Spills Action Centre (SAC) at 1-800-268-6060 or 1-416-325-3000 and the local Medical Officer of Health (MOH) of indicators of adverse drinking water quality and exceedances of standards as outlined in the Regulation and remedial actions taken. Further, within 24 hours of the oral notification, the party shall provide written notification on this completed form by Fax to the Spills Action Centre at 1-800-268-6061 or 1-416-325-3011 and the local Medical Officer of Health. Failure to notify these parties in accordance with the Regulation constitutes an offence under the Act. A copy of this form may be acquired through the Ministry of the Environment (MOE) public web site ([www.ene.gov.on.ca](http://www.ene.gov.on.ca)) or by contacting any MOE office.

### PART 1 - NOTIFICATION BY LABORATORY

Indicators of Adverse Water Quality <input checked="" type="checkbox"/>	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
<b>ORAL NOTIFICATION to SPILLS ACTION CENTRE by LABORATORY</b>		
Date:	Time:	By:
Laboratory Name:	Laboratory Emergency Contact Name	
Address	Position	
Email address	Phone #	Fax #
Waterworks Name	Waterworks Emergency Contact	
Works #	Name	
Location	Position	
Email Address	Phone #	Fax #
<b>NOTIFICATION OF WATER WORKS OWNER</b>		<b>NOTIFICATION OF LOCAL MEDICAL OFFICER OF HEALTH</b>
Person Contacted		Person Contacted
Position		Position
Date	Time	Date
Laboratory Written Notification Prepared by: (Lab Results must be attached using Part 3 of form)		Name (please print )
Signature		Date

### PART 2 - NOTIFICATION BY WATER WORKS OWNER

Indicators of Adverse Water Quality <input checked="" type="checkbox"/>	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
<input type="checkbox"/> This notification is for operational problems identified at the waterworks; there is no Laboratory notification associated with this report		
<b>SPILLS ACTION CENTRE ORAL NOTIFICATION BY OWNER</b>		<b>WATERWORKS EMERGENCY CONTACT</b>
Date Oct-23/02	Time 11:31	Name Dave Markell
Waterworks Name Finch Water Treatment		Position Process Tech.
Works # 210003912		Phone # 613-448-3098 Fax # 613-448-1616
Works Person Providing Oral Notification Dave Markell		
<b>MEDICAL OFFICER OF HEALTH ORAL NOTIFICATION BY OWNER</b>		<b>REMEDIAL ACTIONS TAKEN BY OWNER:</b>
Date Oct-23/02	Time 11:30	Resampling Initiated <input type="checkbox"/> Yes <input type="checkbox"/> No
Person Contacted Adalia		Increase Chlorine Dose <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Position Special Projects		Flushing Mains <input type="checkbox"/> Yes <input type="checkbox"/> No
Phone # 1-800-267-7733 Fax # 933-7930		Other Actions Taken <input type="checkbox"/> Yes <input type="checkbox"/> No
Works Person Providing Oral Notification Dave Markell		Describe:
Water Works Written Notification Prepared by:		Other information attached <input type="checkbox"/>
Signature Dave Markell		Date Oct-23/02
For Ministry Use Only:		Occurrence Report #:

## PART 3:

**ADVERSE ANALYTICAL RESULTS - For Indicators Listed in SCHEDULE 6 -  
Drinking Water Protection Regulation**
**Microbiological Testing**

Lab Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) ( : am pm )	Sample Type / Location	Membrane Filtration Count/100mL			P-A/100mL Presumptive/ Confirmed (if applicable)	HPC/ 1mL	Date - Plates Prepared (M/D/Y)	Date - Plates Read (M/D/Y)
				Total Coliforms	Back- ground	E.coli <input type="checkbox"/> Fecal C. <input type="checkbox"/>				

**ADVERSE ANALYTICAL RESULTS - For Parameters Listed in SCHEDULE 4 and 5 or in a C of A or Order  
Drinking Water Protection Regulation**
**Physical/Chemical/Radiological Testing**

Lab Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) ( : am pm )	Sample Type / Location	Parameter	Result	Unit	MAC/ IMAC	Date - Analysis Completed (M/D/Y)	Date - Data Approved (M/D/Y)
			ON LINE	Turbidity	1.6	NTU		Continuous	

Results Authorized By:

Authorization Date:

For Ministry Use Only:

Occurrence Report #:



HP OfficeJet K Series K80  
Personal Printer/Fax/Copier/Scanner

Log for  
OCWA  
613 448-1616  
Oct 23 2002 12:01pm

---

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Oct 23	12:00pm	Fax Sent	18002686061	0:48	3	OK

---

HP OfficeJet K Series K80  
Personal Printer/Fax/Copier/Scanner

Log for  
OCWA  
613 448-1616  
Oct 23 2002 11:59am

---

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Oct 23	11:56am	Fax Sent	16139337930	2:23	3	OK

---



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

*Chesterville Hub*  
5 Industrial Drive, P.O. Box 460  
Chesterville, Ontario K0C 1H0  
Tel: (613) 448-3098  
Fax: (613) 448-1616  
[www.ocwa.com](http://www.ocwa.com)

# Fax

To Cindy.

Company \_\_\_\_\_

Fax Number 613-962-1866

From \_\_\_\_\_

Date Oct 25/02 - Oct. 23

Number of Pages 11 (including this page)

Subject Adverse Water

You want these you got em.

Dave

Finch

HP OfficeJet K Series K80  
Personal Printer/Fax/Copier/Scanner

Log for  
OCWA  
613 448-1616  
Oct 25 2002 11:50am

---

Last Transaction

<u>Date</u>	<u>Time</u>	<u>Type</u>	<u>Identification</u>	<u>Duration</u>	<u>Pages</u>	<u>Result</u>
Oct 25	11:47am	Fax Sent	16139621966	3:09	11	OK

---



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

*Chesterville Hub*  
5 Industrial Drive, P.O. Box 460  
Chesterville, Ontario K0C 1H0  
Tel: (613) 448-3098  
Fax: (613) 448-1616  
www.ocwa.com

# Fax

To MOH MOE

Company \_\_\_\_\_

Fax Number 933-7930 263-6061

From Dave Markell

Date Apr 10 / 02

Number of Pages 4 (including this page)

Subject Finch.

Adverse water.

Total Coliforms (system sample.)

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



Ministry  
of the  
Environment

Ministère  
de  
l'Environnement

## Notice of Drinking Water Analysis and Remedial Actions for Waterworks as Required under Drinking Water Protection Regulation

In accordance with the Drinking Water Protection Regulation, Laboratories and Water Works Owners must immediately provide oral notification to the MOE Spills Action Centre (SAC) at 1-800-368-6060 or 1-816-325-3000 and the local Medical Officer of Health (MOH) of indicators of adverse drinking water quality and exceedances of standards as outlined in the Regulation and remedial actions taken. Further, within 24 hours of the oral notification, the party shall provide written notification on this completed form by Fax to the Spills Action Centre at 1-800-368-6061 or 1-816-325-3011 and the local Medical Officer of Health. Failure to notify these parties in accordance with the Regulation constitutes an offence under the Act. A copy of this form may be acquired through the Ministry of the Environment (MOE) public web site ( www.ene.gov.on.ca ) or by contacting any MOE office.

### PART 1 - NOTIFICATION BY LABORATORY

Indicators of Adverse Water Quality <input checked="" type="checkbox"/>	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
<b>ORAL NOTIFICATION to SPILLS ACTION CENTRE by LABORATORY</b>		
Date:	Time:	By:
Laboratory Name:	Laboratory Emergency Contact Name:	
Address:	Position:	
Email address:	Phone #:	Fax #:
Waterworks Name: FINCH	Waterworks Emergency Contact:	
Works #: 210003912	Name: Dave Markell	
Location: FINCH	Position: OPERATOR	
Email Address:	Phone #:	Fax #: 613-448-3098 Fax # 448-1616
<b>NOTIFICATION OF WATER WORKS OWNER</b>		
Person Contacted: Brian Henderson		
Position: OPERATOR		
Date: April 10/02 Time: 1:41		
Laboratory Written Notification Prepared by: Name (please print):		
Signature: [Signature] Date: April 10/02		

### PART 2 - NOTIFICATION BY WATER WORKS OWNER

Indicators of Adverse Water Quality <input checked="" type="checkbox"/>	Phys/Chem <input type="checkbox"/> Exceeds MAC <input type="checkbox"/> Exceeds IMAC	Radiological <input type="checkbox"/> Exceeds IMAC CofA/Order <input type="checkbox"/> Exceeds Limit
<input type="checkbox"/> This notification is for operational problems identified at the waterworks; there is no Laboratory notification associated with this report.		
<b>SPILLS ACTION CENTRE ORAL NOTIFICATION BY OWNER</b>		
Date: Apr. 10/02	Time: 14:00	
Waterworks Name: FINCH	Position: OPERATOR	
Works #: 210003912	Phone #: 613-448-3098	Fax #: 613-448-1616
Works Person Providing Oral Notification: D. Markell		
<b>MEDICAL OFFICER OF HEALTH ORAL NOTIFICATION BY OWNER</b>		
Date: Apr. 10/02	Time: 13:55	
Person Contacted: Claudette		
Position: Receptionist		
Phone #: 800-267-7120	Fax #: 933-7930	
Works Person Providing Oral Notification: D. Markell		
Water Works Written Notification Prepared by: Name (please print): Dave Markell		
Signature: [Signature] Date: Apr. 10/02		
For Ministry Use Only: Occurrence Report #:		



Ministry of the Environment  
Ministère de l'Environnement

PART 3:

ADVERSE ANALYTICAL RESULTS - For Indicators Listed in SCHEDULE 6 -  
Drinking Water Protection Regulation

Microbiological Testing

Laboratory Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) ( : a.m. p.m.)	Sample Type / Location	Membrane Filtration Count/100ml			P-A/100ml Presumptive/ Confirmed (if applicable)	HPC/ 1ml	Date of Analysis (M/D/Y)
				Total Coliforms	Back-ground	E.coli/ Fecal C.			
22203202	FW 34	24/08/02	SEWAGE PUMP STATION SPS	2	—	0	—	—	09/09/02

ADVERSE ANALYTICAL RESULTS - For Parameters Listed in SCHEDULE 4 and 5 or in a C of A or Order  
Drinking Water Protection Regulation

Physical/Chemical/Radiological Testing

Laboratory Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) ( : a.m. p.m.)	Sample Type/ Location	Parameter	Result	Unit	MAC/ IMAC	Date of Analysis (M/D/Y)

Laboratory Results Authorized by:

Authorization Date:

For Ministry Use Only:

Occurrence Report #:

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

**Client:**

Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Attention: **Dave Markell**

**Report:**

**220003203**

**Project:**

Finch WTP

**Date Sampled:**

April 8, 2002

**Date Received:**

April 9, 2002

**Date Printed:**

April 10, 2002

**Matrix:**

Drinking Water

Parameter	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	0.05	2	1	0.05

**Sample ID**

Well - Raw	absent			absent	
WTP Treated	absent	2.20		absent	2.40
Dist. Barb's Diner	absent	1.10		absent	1.30
Dist. Sewage Pumping Station (SPS)	absent	1.00		2	1.20

page 4 of 4



TRANSMISSION VERIFICATION REPORT

TIME : 04/10/2002 14:18

DATE, TIME  
FAX NO./NAME  
DURATION  
PAGE(S)  
RESULT  
MODE

04/10 14:16  
18002686061  
00:01:42  
04  
OK  
STANDARD  
ECM

TRANSMISSION VERIFICATION REPORT

TIME : 04/10/2002 14:14

DATE, TIME  
FAX NO./NAME  
DURATION  
PAGE(S)  
RESULT  
MODE

04/10 14:12  
16139337930  
00:02:03  
04  
OK  
STANDARD



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

*Chesterville Hub*  
5 Industrial Drive, P.O. Box 460  
Chesterville, Ontario K0C 1H0  
Tel: (613) 448-3098  
Fax: (613) 448-1616  
www.ocwa.com

# Fax

To IRENE  
Company MOH  
Fax Number 1-613-~~267-7130~~ 7930 933-7930  
From Dave  
Date FEB 21/02  
Number of Pages 5 (including this page)  
Subject Please find attached

lab sheets from Moose Creek,  
Finch, Chesterville and Winchester  
Wells # 1, 5 & 6.

These are as a required follow-up  
to notifications of adverse water  
(Sodium over 20 ms/c) FEB 7/02.

any questions please call Dave



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

Chesterville Hub  
5 Industrial Drive,  
Chesterville, Ontario K0C 1H0  
Tel: (613) 448-3098  
Fax: (613) 448-1616  
bhenderson@ocwa.com

# Fax

**To** Rheal Delaquis  
**Company** Ministry of Environment  
**Fax Number** (613) 933-6402  
**From** Blair Henderson  
**Date** February 21, 2002  
**Number of Pages** 1 (including this page)  
**Subject** Finch Water and Moose Creek Water - Sodium Exceedance

As a follow up to notification of sodium exceedance dated February 7, 2002, as per ODWR, all sites have been resampled and the results are as follows.

Finch Treated Water - 77.0 mg/Litre  
Moose Creek Treated Water - 27 mg/Litre

These results have been forwarded to the Ministry of Health.

These results are consistent with historic sodium results.

**Caution:** This fax is private property intended solely for the information and use of the addressee. The contents are confidential and may be privileged. Any unauthorized use of this fax is strictly prohibited. If you are not the addressee, please notify sender immediately by telephone and either return or destroy this fax.

**ACCUTEST LABORATORIES LTD.**

## REPORT OF ANALYSIS

**Client: FINCH WELL SUPPLY**

ATT: Mr. Blair Henderson

**Report Number:**

2201833

**Date:**

2002-02-20

**Date Submitted:**

2002-02-14

**Project:**

### Finch Wells Resample

**P.O. Number:**

**Matrix:**

### Supply Water

LAB ID:			169944	Matrix:		Supply Water	
Sample Date:			2002-02-13				
Sample ID:			FW-01				
PARAMETER	UNITS	MDL	TREATED WATER				
Na	mg/L	2	77				
MDL = Method Detection Limit N/A = Not Applicable							

MDL = Method Detection Limit  
Comment:

INC = Incomplete

APPROVAL:

8-146 Colonnade Road, Ottawa, ON, K2E 7Y1

608 Narris Court, Kingston, ON, K7P 2R9

TRANSMISSION VERIFICATION REPORT

TIME : 02/21/2002 13:47

DATE, TIME  
FAX NO./NAME  
DURATION  
PAGE(S)  
RESULT  
MODE

02/21 13:45  
16139337930  
00:02:05  
05  
OK  
STANDARD

Accutest Laboratories Ltd.

146 Colonnade Rd., Unit 8, Nepean, Ontario, K2E 7Y1

www.accutestlabs.com



# ACCUTEST FAX

Date: February 7, 2002Number of pages including cover sheet: 15

To:

Blair Henderson  
OCWA Chesterville

Phone: 613-448-3098Fax phone: 613-448-1616

CC:

From:

Kristina Hay  
QA/QC Coordinator

Phone: 613-727-5692Fax phone: 613-727-5222e-mail: khay@accutestlabs.com

## REMARKS

☐ Urgent ☐ For your review ☐ Reply ASAP ☐ Please commentOriginals to follow: ☐ YES ☐ NO VIA: ☐ Mail ☐ CourierYour Reference: Na ODWS Exceedances

Our Reference:

Mr. Henderson,

This is a notice of adverse Na results for the Winchester, Finch, Moose Creek and Chesterville Well Supplies. I have attached a preliminary copy of the reports as well as Part 1 and 3 of the MOE Notice of Drinking Water Analysis form.

Please contact me if you have any questions.

Best regards,

*Kristina Hay*  
Kristina Hay

Ottawa • Kingston

**ACCUTEST LABORATORIES LTD.**

## REPORT OF ANALYSIS

**Client: FINCH WELL SUPPLY**

ATT. Mr. Blair Henderson

**Report Number:**

2200718

**Date:**

2002-01-29

**Date Submitted:**

2002-01-22

**Project:**

## Finch Wells - Quarterly

**P.O. Number:**

**Matrix:**

### Supply Water

LAB ID: 167006							
Sample Date: 2002-01-21							
Sample ID: FW-01							
PARAMETER	UNITS	MDL	TREATED WATER				
Ca	mg/L	1	66				
F	mg/L	0.10	0.47				
Mg	mg/L	1	29				
N-NO2	mg/L	0.10	<0.10				
N-NO3	mg/L	0.10	<0.10				
K	mg/L	1	6				
Na	mg/L	2	82				

MDL = Method Detection Limit

INC = Incomplete

**Comment:**

APPROVAL:



# Notice of Drinking Water Analysis and Remedial Actions for Waterworks as Required under Drinking Water Protection Regulation

In accordance with the Drinking Water Protection Regulation, Laboratory and Water Works Owners must immediately provide oral notification to the MOE Spills Action Centre (SAC) at 1-800-268-4666 or 1-816-325-1000 and the local Medical Officer of Health (MOH) of the province of Ontario and the local Medical Officer of Health (MOH) of the province of Ontario. Further, within 24 hours of the oral notification, the party shall provide written notification on this completed form by Fax to the Spills Action Centre at 1-800-268-4666 or 1-816-325-1000 and the local Medical Officer of Health (MOH) of the province of Ontario and the local Medical Officer of Health (MOH) of the province of Ontario. Failure to notify those parties in accordance with the Regulation constitutes an offence under the Act. A copy of this form may be acquired through the Ministry of the Environment (MOE) public web site (www.moe.gov.on.ca) or by contacting any MOE office.

## PART 1 - NOTIFICATION BY LABORATORY

Indicators of Adverse ☒ Phys/Chem ☐ Exceeds MAC ☐ Radiological ☐ Exceeds IMAC ☐ Col/Order ☐ Exceeds Limit

ORAL NOTIFICATION TO SPLITS ACTION CENTRE BY LABORATORY

Date: Feb 7, 2002 Time: 4:00 pm By: Kristina Hay

Laboratory Name: Accutest Laboratories Ltd.

Address: 146 Colonnade Rd., Unit 8, Nepean, ON K2E 7Y1

Phone: (613) 727-5692 Fax: (613) 727-5222

Waterworks Name: Fack well Supply

Waterworks Address: 21000 3912

Name: Blair Henderson

Position: Operator

Waterworks Emergency Contact: Operator

Phone: (613) 448-3098 Fax: (613) 448-1616

NOTIFICATION OF WATER WORKS OWNER

Version Controlled: Blair Henderson

Position: Operator

Date: Feb 7, 2002 Time: 3:15 pm

Laboratory Written Notification Prepared by: Kristina Hay

(Lab Results must be attached using Part 3 of form)

Signature: Kristina Hay

Date: Feb 7, 2002

## PART 2 - NOTIFICATION BY WATER WORKS OWNER

Indicators of Adverse ☒ Phys/Chem ☐ Exceeds MAC ☐ Radiological ☐ Exceeds IMAC ☐ Col/Order ☐ Exceeds Limit

☐ This notification is for operational problems identified at the waterworks; there is no laboratory notification associated with this report

SPLITS ACTION CENTRE ORAL NOTIFICATION BY OWNER

WATERWORKS EMERGENCY CONTACT

Date: Feb 07, 2002 Time: 16:16

Waterworks Name: FINCH W.T.P.

Waterworks Address: 21000 3912

Phone: 613-448-3098 Fax: 613-448-1616

Name: Blair Henderson

Position: Active Operations Manager

Medical Officer of Health Oral Notification by Owner

Date: Feb 07, 2002 Time: 16:25 Hrs

Form Contained: CLAUDETTE

Position: RECEPTIONIST

Phone: 613-933-1375 Fax: 613-933-7930

Water Person Providing Oral Notification: DAVID MAREL

Water Works Written Notification Prepared by: Name (please print)

Signature: Blair Henderson

Date: Feb 07, 2002

For Ministry Use Only: Occurrence Report #:



Ministry of the Environment  
Ministère de l'Environnement

## PART 3:

# ADVERSE ANALYTICAL RESULTS - For Indicators Listed in SCHEDULE 6 - Drinking Water Protection Regulation

## Microbiological Testing

Laboratory Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) ( : : a.m.)	Sample Type / Location	Membrane Filtration Count/100ml			P-A/100ml Presumptive/Confirmed (if applicable)	IIPC/1ml	Date of Analysis (M/D/Y)
				Total Coliforms	Back-ground	E.coli/Fecal C.			

## ADVERSE ANALYTICAL RESULTS - For Parameters Listed in SCHEDULE 4 and 5 or in a C of A or Order Drinking Water Protection Regulation

## Physical/Chemical/Radiological Testing

Laboratory Sample ID No.	Sample Field ID No.	Date/Time Collected (M/D/Y) ( : : a.m.)	Sample Type / Location	Parameter	Result	Unit	MAC/IMAC (Per 500L)	Date of Analysis (M/D/Y)
167606		01/22/01	FW-01	Na	82	mg/L	20	01/23/02

Laboratory Results Authorized by:

Dionne Hay

Authorizing Date:

Feb 7, 2002

For Ministry Use Only:

Occurrence Report #:

Page of

TRANSMISSION VERIFICATION REPORT

TIME : 02/07/2002 17:24

DATE, TIME  
FAX NO./NAME  
DURATION  
PAGE(S)  
RESULT  
MODE

02/07 17:21  
16139337930  
00:02:27  
04  
OK  
STANDARD

TRANSMISSION VERIFICATION REPORT

TIME : 02/07/2002 17:30

DATE, TIME  
FAX NO./NAME  
DURATION  
PAGE(S)  
RESULT  
MODE

02/07 17:25  
18002686061  
00:04:48  
09  
OK  
STANDARD  
ECM

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*January - March 2002, Finch Water Plant - Serving the Village of Finch*

## Finch Drinking Water Quality

### ***Ontario Drinking Water Protection Regulations***

The Ontario Clean Water Agency, as the contract operator of the Finch Water Treatment Facility on behalf of the Township of North Stormont, is pleased to present the 2002 First Quarter Report on drinking water quality. This report has been prepared in response to legislative changes brought about by "Operation Clean Water", an initiative of Ontario's Ministry of the Environment to ensure high quality drinking water for the residents of Ontario. The new regulations put into law what was formerly the Ontario Drinking Water Objectives (ODWO), and sets requirements for public waterworks with regard to sampling and testing, levels of treatment, licensing of staff, and notification of authorities and the public about water quality.

Further information on the Ontario Drinking Water Regulations can be found on the Ministry of the Environment web site at [www.ene.gov.on.ca](http://www.ene.gov.on.ca)

## Where to contact us for information



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

Web site at [www.ocwa.com](http://www.ocwa.com)

Client Services Representative: John Kingsbury Operations Manager: Blair Henderson

Phone : (613) 774-3663

Phone: (613) 448-3098

E-mail Address: [jkingsbury@ocwa.com](mailto:jkingsbury@ocwa.com)

E-mail Address: [bhenderson@ocwa.com](mailto:bhenderson@ocwa.com)

You may also contact the Township of North Stormont directly by contacting Rheal Charbonneau, Clerk-Treasurer, Tel. (613) 984-2821 or e-mail address: [norstor@cnwl.igs.net](mailto:norstor@cnwl.igs.net)

Free copies of this report are available at the Township office or their website @ [www.cnwl.igs.net/~northstormont](http://www.cnwl.igs.net/~northstormont)



## INSIDE THIS REPORT

Drinking Water Regulations	1
Where To Contact Us	1
Plant Description & Treatment Processes	2
Quality Control and Compliance with Provincial Regulations	3

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*January - March 2002, Finch Water Plant - Serving the Village of Finch*

Definitions & Terms	4
Required Testing	4
Water Quality Test Results	5
Questions & Answers	7

## **Introduction**

We are proud to report that for the period January to March 2002, your water conformed to the Ontario Drinking Water Standards as set out in Ontario Regulation 459/00. The Ontario Clean Water Agency (OCWA) is dedicated to maximizing public health and safety through efficient and reliable operation of your water facility and distribution system.

## **Plant Description and Treatment Processes**

Facility Name:	Finch WTP & Distribution System
Total Design Capacity	691 cubic meters/day
Raw Water Source	Groundwater
Disinfection Method	Sodium Hypochlorite
Municipal Location	Municipal Office, 2 Victoria Street, Berwick
Service Area	Village of Finch
Service Population	441

### **Operational Description:**

**Raw Water Source:** Two drilled wells located at 20 William Street in the Village of Finch.

**Low Lift Pumps:** Two submersible well pumps, one duty and one standby, direct the water from the wells to a 9.5 L/second force draft aeration tower, where H<sub>2</sub>S is removed from the raw water.

Water from the aeration tower is chemically injected with Sodium Hypochlorite for disinfection, prior to entry to the 20 cubic meter clear well.

**High Lift Pumps:** Two high lift pumps, one duty and one standby, move the chlorinated water from the clear well to the pressure filters.

**Filters:** Two 4 Litre/second dual media pressure filters, remove particles from the chlorinated water.

Filter backwash treatment system consists of a 15 cubic meter surge tank, with a 1.4 cubic meter settling tank and an 18 cubic meter sludge holding tank.

**Elevated Storage Tank:** The plant treated water, after filtration, is directed to the distribution grid and elevated storage tank with a capacity of 580 cubic meters.

**Distribution System:** There are approximately 441 persons supplied with water from the Finch Water Treatment Plant.

# QUARTERLY REPORT ON DRINKING WATER QUALITY

January - March 2002, Finch Water Plant - Serving the Village of Finch

## Quality Control & Compliance With Provincial Regulations

This plant provides multiple barriers against bacteriological contamination. Bacteriological testing is carried out on raw water, treated water and distribution samples on a regular frequency. On-line analysers for chlorine residuals and turbidity ensure daily monitoring of water leaving the plant. Chlorine levels in the distribution system are also checked on a regular basis. More specialized testing occurs monthly and quarterly and includes Volatile Organics, Inorganics, Pesticides and PCB's.

OCWA uses internal compliance auditing techniques by teams from within the organization. OCWA operates the Finch Water Treatment Facility in accordance with provincial regulations. Here is how we do it:

- Use of Accredited Labs. Analytical tests to monitor your water quality are conducted by a laboratory audited by the Canadian Association for Environmental Analytical Laboratories (CAEAL) and accredited by the Standards Council of Canada (SCC). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods.
- Operation by Licensed Operators. Your water treatment plant is operated and maintained by the Ontario Clean Water Agency's competent and licensed staff. The mandatory licensing program for operators of drinking water facilities is regulated under the *Ontario Water Resources Act (OWRA)* Regulation 435/93. Licensing means that an individual meets the education and experience requirements and has successfully passed the certificate exam.
- Sampling and Analytical requirements. OCWA follows a sampling and analysis schedule required by *OWRA* Regulation 459/00, the Ontario Drinking Water Standards. More information on sampling and analysis including results are available in this report and from your municipal office.
- Adherence to Ministry Guidelines and Procedures. To ensure the protection of the health and operational excellence, the OCWA adheres to the guidelines and procedures developed by the Ministry of the Environment and the Ministry of Health.

### **Did We Exceed the Standards?**

During the First Quarter, Sodium was found to exceed the Ontario Drinking Water Standards concentration of 20 mg/L as set out in Ontario Regulation 459/00. The sodium concentrations of the treated water at Finch Water Treatment Plant in the first quarter were 82 mg/L and 77 mg/L. The local Medical Officer of Health must be notified when the sodium concentration exceeds 20 mg/L so that this information may be communicated to the local physicians for their use with patients on sodium restricted diets. The aesthetic objective for sodium in drinking water is 200 mg/L at which it can be detected by a salty taste.

## QUARTERLY REPORT ON DRINKING WATER QUALITY

*January - March 2002, Finch Water Plant - Serving the Village of Finch*

As a result we actively undertook the following remedial actions:

Immediately notified the Ministry of Environment and the Ministry of Health as per the Ontario Drinking Water Standards. The result of the first sample was 82 mg/L and as per Reg. 459 re-sampling was initiated and the results were 82 mg/L.

### Definitions & Terms

**m<sup>3</sup>** - Cubic Meter, 1m<sup>3</sup> = 1000 litres

**TCU** - True Colour Units

**CaCO<sub>3</sub>** - Calcium Carbonate

**mg** - milligram

**mg/L** - milligrams per litre

**ug/L** - micrograms per litre

**ng/L** - nanograms per litre

**NTU** - Nephelometric Turbidity Units

**MAC** - Maximum Acceptable Concentration

**IMAC** - Interim Maximum Acceptable Concentration

**Coliform Bacteria** - a group of commonly occurring rod shaped bacteria. Their presence in a water sample is indicative of inadequate filtration and/or disinfection.

**Fecal Coliform Bacteria** - refers to a subgroup of coliform bacteria present in the digestive system of warm blooded animals and humans.

**Heterotrophic Plate Count** - a method of measuring bacterial content in water samples. Also known as Standard Plate Count.

**Organic Parameter** - a group of chemical compounds containing carbon.

**Inorganic Parameter** - a group of chemical compounds not containing carbon.

**Raw Water** - Surface or ground water available as a source of drinking water that has not received any treatment.

### Required Testing

The Ontario Drinking Water Regulations and Certificates of Approval (C of A) set sampling requirements for the plant. All other sampling conforms to the Drinking Water Protection Regulation schedule for sampling and analysis. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases can pick up substances resulting from the presence of animals or from human activity. Your water is extensively tested for the presence of dozens of compounds. The results of all analytical tests are available at your municipal office. The following table lists all compounds analyzed.



# QUARTERLY REPORT ON DRINKING WATER QUALITY

January - March 2002, Finch Water Plant - Serving the Village of Finch

## Finch Water Quality Test Results

Microbiological Parameters	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence?	Typical Source of Contaminant
Total Coliform (counts/100ml)	0	40	0	01/01-03/31	n/a	no	Indicate possible presence of coliform
Escherichia Coliform (counts/100ml)	0	40	0	01/01-03/31	n/a	no	Definite indicator of fecal contamination
Heterotrophic Plate Count (counts/100ml)	500	27	10	01/01-03/31	2-120	no	Indicator of deteriorating water quality if greater than 500
Parameters related to Microbiological Quality	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence?	Typical Source of Contaminant
Turbidity (NTU)	1	Continuous	Continuous	01/01-03/31	0.07-0.17	no	Turbidity is a measure of particles in water
Free Chlorine - Plant Effluent (mg/l)	-	Continuous	Continuous	01/01-03/31	0.77-2.40	no	Chlorine added for Disinfection
Free Chlorine-Distribution (mg/l min 0.05 & max. 4.0)	-	Grab Sample weekly	weekly	01/01-03/31	0.9-2.0	no	Objective is 0.20 mg/l in the Distribution System (min. 0.05 mg/l required)
Inorganic Parameters (mg/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Lead - Distribution (ug/l)	0.01	1	1	01/21/02	0.001	no	Leached from lead solder or brass plumbing fixtures
Nitrate	10	1	1	01/21/02	<0.1	no	Natural component of water
Nitrite	1	1	1	01/21/02	<0.1	no	
Arsenic	IMAC= 0.025	1	1	09/18/00	<0.001	no	
Barium	1	1	1	09/18/00	0.43	no	
Boron	IMAC= 5.0	1	1	09/18/00	0.17	no	
Cadmium	0.005	1	1	09/18/00	<0.0001	no	
Chromium (Total)	0.05	1	1	09/18/00	<0.01	no	
Copper	1	1	1	09/18/00	0.013	no	
Iron	0.3	1	1	09/18/00	<0.01	no	
Lead	0.01	1	1	09/18/00	<0.001	no	
Manganese	0.05	1	1	09/18/00	<0.01	no	
Mercury	0.001	1	1	09/18/00	<0.0001	no	
Selenium	0.01	1	1	09/18/00	<0.001	no	
Uranium	0.1	1	1	09/18/00	<0.001	no	
Sodium (System)	200	2	2	01/21/02-02/13/02	82-77	no	
Fluoride	2.4	1	1	01/21/02	0.47	no	

Volatile Organics (ug/l)	MAC or	# of	# of	Sampling	Range	Exceedence?	Typical Source of
--------------------------	--------	------	------	----------	-------	-------------	-------------------

# QUARTERLY REPORT ON DRINKING WATER QUALITY

January - March 2002, Finch Water Plant - Serving the Village of Finch

	IMAC	Samples	Detectable Results	Dates (m/d/y)			Contaminant
Trihalomethanes - Plant	100	1	1	01/21/02	82.4	no	
Trihalomethanes - Dist.	100	1	1	01/21/02	46.1	no	
Benzene	5	1	1	01/21/02	<0.5	no	
Carbon Tetrachloride	5	1	1	01/21/02	<0.9	no	
Dichloromethane	50	1	1	01/21/02	<4	no	
1,2 - Dichlorobenzene	200	1	1	01/21/02	<0.4	no	
1, 4 - Dichlorobenzene	5	1	1	01/21/02	<0.4	no	
1,2 - Dichloroethane	IMAC=5	1	1	01/21/02	<0.7	no	
1,1 - Dichloroethylene	14	1	1	01/21/02	<0.5	no	
Ethylbenzene	24	1	1	01/21/02	<0.5	no	
Monochlorobenzene	80	1	1	01/21/02	<0.2	no	
Tetrachloroethylene	30	1	1	01/21/02	<0.3	no	
Toluene	24	1	1	01/21/02	<0.5	no	
Volatile Organics (ug/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Trichloroethylene	50	1	1	01/21/02	<0.3	no	
Vinyl chloride	2	1	1	01/21/02	<0.5	no	
Xylene	300	1	1	01/21/02	2	no	
Bromodichloromethane	n/a	1	1	01/21/02	22.6	no	
Bromoform	n/a	1	1	01/21/02	2.8	no	
Chloroform	n/a	1	1	01/21/02	31	no	
Dibromochloromethane	n/a	1	1	01/21/02	26	no	

Pesticides & PCB (ug/L)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Alachlor	IMAC=5	1	1	01/21/02	<0.5	no	
Aldicarb	9	1	1	01/21/02	<5.0	no	
Aldrin+Dieldrin	0.7	1	1	01/21/02	<0.07	no	
Atrazine	IMAC=5	1	1	01/21/02	<1.0	no	
Azinphos-methyl	20	1	1	01/21/02	<2.0	no	
Bendiocarb	40	1	1	01/21/02	<2.0	no	
Bromoxynil	IMAC=5	1	1	01/21/02	<0.5	no	
Carbaryl	90	1	1	01/21/02	<5.0	no	
Carbofuran	90	1	1	01/21/02	<5.0	no	
Chlordane	7	1	1	01/21/02	<0.7	no	
Chorpyrifus	90	1	1	01/21/02	<1.0	no	
Cyanazine	IMAC=10	1	1	01/21/02	<1.0	no	
Diaznon	20	1	1	01/21/02	<1.0	no	
Dicamba	120	1	1	01/21/02	<1.0	no	
2,4 Dichlorophenol	900	1	1	01/21/02	<0.5	no	
DDT + Metapolites	30	1	1	01/21/02	<3.0	no	
2,4 - Dichlorophenexy acid (2,4 -D)	IMAC=10 0	1	1	01/21/02	<1.0	no	
Diclofop-methyl	9	1	1	01/21/02	<0.9	no	
Dimethoate	IMAC=20	1	1	01/21/02	<2.5	no	
Dinoseb	10	1	1	01/21/02	<1.0	no	
Diquat	70	1	1	01/21/02	<7.0	no	
Diuron	150	1	1	01/21/02	<10.0	no	
Glyphosate	IMAC=28 0	1	1	01/21/02	<10.0	no	
Heprachlor + Heptachlor epoxide	3	1	1	01/21/02	<0.3	no	

# QUARTERLY REPORT ON DRINKING WATER QUALITY

January - March 2002, Finch Water Plant - Serving the Village of Finch

Lindane	4	1	1	01/21/02	<0.4	no	
Malathion	190	1	1	01/21/02	<5.0	no	
Methoxychlor	900	1	1	01/21/02	<90	no	
Metolachlor	IMAC=50	1	1	01/21/02	<0.5	no	
Metribuzin	80	1	1	01/21/02	<5.0	no	
Paraquat	IMAC=10	1	1	01/21/02	<1.0	no	
Parathion	50	1	1	01/21/02	<1.0	no	
Pentachlorophenol	60	1	1	01/21/02	<0.5	no	
Phorate	IMAC=2	1	1	01/21/02	<0.5	no	
Picloram	IMAC=190	1	1	01/21/02	<5.0	no	
Polychlorinated Biphenyls	IMAC=3	1	1	01/21/02	<0.3	no	
Prometryne	IMAC=1	1	1	01/21/02	<0.25	no	
Simazine	IMAC=10	1	1	01/21/02	<1.0	no	
Temephos	IMAC=280	1	1	01/21/02	<10	no	
Terbufos	IMAC=1	1	1	01/21/02	<0.7	no	
2,3,4,6 Tetrachlorophenol	100	1	1	01/21/02	<0.5	no	
Triallate	230	1	1	01/21/02	<1.0	no	
2,4,6-Trichlorophenol	5	1	1	01/21/02	<0.5	no	
2,4,5 - trichlorophenoxy acetic acid	IMAC=280	1	1	01/21/02	<1.0	no	
Trifluralin	45	1	1	01/21/02	<1.0	no	

Additional Parameters Non-Health Related (mg/L)	AO or OG	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Calcium	---	1	1	01/21/02	66	no	
Magnesium	---	1	1	01/21/02	29	no	
Potassium	---	1	1	01/21/02	6	no	

## Questions & Answers

Q. What is an Accredited Laboratory?

A. Accredited labs must have undergone an on-site assessment and performance review of their methods by the Canadian Association of Environmental and Analytical Laboratories. The Standards Council of Canada grants accreditation to the lab based on the recommendation of the CAEAL. The accreditation requirements are repeated every two years.

Q. What had to be done to meet the new regulations?

A. The Finch Water Treatment Plant was following the Ontario Drinking Water Objectives (ODWO) before they became law, so little change was required to meet the new regulations. Our chlorine residual in the water leaving the plant was raised to slightly to achieve the (0.20 mg/L free chlorine) required level in the distribution system, and some changes were required in the way results are reported. This report to the public is also the result of the new regulations.

Q. What parameters did you test for?

A. Microbiological parameters, volatile organics, inorganics, pesticides and PCB's have been tested. The results are included in this report.

Q. Sometimes my water looks rusty or coloured. Why is that, and what should I do about it?

## **QUARTERLY REPORT ON DRINKING WATER QUALITY**

*January - March 2002, Finch Water Plant - Serving the Village of Finch*

A. This is quite often caused when the tanks in older water heaters start to decay. If the colour is seen only in your hot water, this may be the problem. If the colour is also noticed in your cold water it could be coming from the water main. Various maintenance procedures in the distribution system - such as fire hydrant and valve maintenance, or main break repairs - require flushing of the water mains. Flushing can cause small particles of sediment to break off adding colour to the water. Please note that there is no health risk associated with this problem. This is usually only temporary, and opening your taps for a while to flush out your service line (the pipe from the water main to your house) should take care of the problem. Let the water run until the colour disappears.

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

**Client:**

Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

**Report:**

**230000130**

**Project:**

Finch WTP

**Date Sampled:**

January 6, 2003

**Date Received:**

January 7, 2003

**Date Printed:**

January 09, 2003

**Attention:** Dave Markell

**Matrix:**

Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Arena	Dist. St. Bernards School
Total Chlorine	mg/L	0.05		2.10	1.47	1.96
Free Chlorine	mg/L	0.05		1.74	1.29	1.70
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	4			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

**Client:**

Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

**Report:**

**230000763**

**Project:**

Finch WTP

**Date Sampled:**

January 20, 2003

**Date Received:**

January 21, 2003

**Date Printed:**

January 23, 2003

**Attention:** Dave Markell

**Matrix:**

Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. S.P.S	Dist. Arena
Total Chlorine	mg/L	0.05		2.20	1.29	1.48
Free Chlorine	mg/L	0.05		1.88	1.18	1.23
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	2	
Background bacteria	/100mL	1	4			
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Attention: Dave Markell

Report: 230000449  
Project: Finch WTP  
Date Sampled: January 13, 2003  
Date Received: January 14, 2003  
Date Printed: January 16, 2003  
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	Well - Treated	Dist. MQA Sonar	Dist. SPS # 1
Total Chlorine	mg/L	0.05		2.18	1.85	1.14
Free Chlorine	mg/L	0.05		1.96	1.66	1.03
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		6	absent	
Background bacteria	/100mL	1	3			
Total Coliforms	/100mL	1	absent	absent	absent	absent

**Caduceon Enterprises Inc.**  
**Environmental Laboratory**

**Certificate of Analysis**

**Client:**  
**ario Clean Water Agency**  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

**Report:** 220000056  
**Project:** Finch WTP  
**Date Sampled:** January 2, 2002  
**Date Received:** January 3, 2002  
**Date Printed:** January 07, 2002  
**Matrix:** Drinking Water

**Attention:** Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well #1 Raw	WTP Treated	Dist. Senior Center	Dist. Sewage Pumping Station #1
Total Chlorine	mg/L	0.05		2.30	1.20	1.00
Free Chlorine	mg/L	0.05		2.00	1.00	0.90
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	2	absent	
Total Coliforms	/100mL	1	absent	absent	absent	absent



**Caduceon Enterprises Inc.**  
**Environmental Laboratory**

**Certificate of Analysis**

Client:  
**Ontario Clean Water Agency**  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220000170**  
Project: **Finch WTP**  
Date Sampled: **January 7, 2002**  
Date Received: **January 8, 2002**  
Date Printed: **January 10, 2002**

Attention: **Dave Markell**


Matrix: **Drinking Water**

Parameter	Unit	MDL	Sample Identification			
			Well #1 Raw	WTP Treated	Dist. Co-op	Dist. Water Tower
Total Chlorine	mg/L	0.05		2.00	1.60	1.30
Free Chlorine	mg/L	0.05		1.90	1.60	1.20
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	absent	34	2
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Enterprises Inc. Environmental Laboratory

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

  
Michael Ziebell, General Manager

**Caduceon Enterprises Inc.**  
**Environmental Laboratory**

**Certificate of Analysis**

**Client:**  
**Ontario Clean Water Agency**  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

**Report:** **220000386**  
**Project:** Finch WTP  
**Date Sampled:** January 14, 2002  
**Date Received:** January 15, 2002  
**Date Printed:** January 17, 2002

**Attention:** Dave Markell

**Matrix:** Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well #1 Raw	WTP Treated	Dist. St. Burnards	Dist. Barb's
Total Chlorine	mg/L	0.05		1.40	1.90	1.50
Free Chlorine	mg/L	0.05		1.30	1.70	1.40
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2	2	absent	absent	
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Enterprises Inc. Environmental Laboratory

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

  
Michael Ziebell, General Manager

**Caduceon Enterprises Inc.**  
**Environmental Laboratory**

**Certificate of Analysis**

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220000610**  
Project: Finch WTP  
Date Sampled: January 21, 2002  
Date Received: January 22, 2002  
Date Printed: January 25, 2002

Attention: **Dave Markell**

Matrix: **Drinking Water**

Parameter	Unit	MDL	Sample Identification			
			Well #1 Raw	WTP Treated	Dist. St. Bernard's School	Dist. SPS #1
Total Chlorine	mg/L	0.05		2.50	1.90	1.40
Free Chlorine	mg/L	0.05		2.30	1.60	1.20
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	6	absent	
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Enterprises Inc. Environmental Laboratory

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

  
Michael Ziebell, General Manager

**Caduceon Enterprises Inc.**  
**Environmental Laboratory**

**Certificate of Analysis**

**Client:**  
**Ontario Clean Water Agency**  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

**Report:** **220000786**  
**Project:** Finch WTP  
**Date Sampled:** January 28, 2002  
**Date Received:** January 29, 2002  
**Date Printed:** January 31, 2002

**Attention:** Dave Markell


**Matrix:** Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well #1 Raw	WTP Treated	Dist. St. Burnards	Dist. SPS
Total Chlorine	mg/L	0.05		1.90	2.10	1.40
Free Chlorine	mg/L	0.05		1.80	1.90	1.30
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	absent	absent	
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Enterprises Inc. Environmental Laboratory

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

  
Michael Ziebell, General Manager

# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

Client: FINCH WELL SUPPLY

Report Number: 2200718  
Date: 2002-01-25  
Date Submitted: 2002-01-22

ATT: Mr. Blair Henderson

Project: Finch Wells - Quarterly Chemicals

P.O. Number:

Matrix: Supply Water

LAB ID: 167006  
Sample Date: 2002-01-21  
Sample ID: FW-01

PARAMETER	UNITS	MDL				
<b>BTEX / 624 / PURGEABLE HYDROCARBONS</b>						
Benzene	ug/L	0.5	<0.5 ✓			
Toluene	ug/L	0.5	<0.5 ✓			
Ethylbenzene	ug/L	0.5	<0.5 ✓			
m/p-xylene	ug/L	1.0	<1.0 ✓			
o-xylene	ug/L	0.5	<0.5 ✓			
Bromodichloromethane	ug/L	0.3	22.6 ✓			
Bromoform	ug/L	0.4	2.8 ✓			
Carbon Tetrachloride	ug/L	0.9	<0.9 ✓			
Monochlorobenzene	ug/L	0.2	<0.2 ✓			
Chloroform	ug/L	0.5	31.0 ✓			
Dibromochloromethane	ug/L	0.3	26.0 ✓			
1,2-dichlorobenzene	ug/L	0.4	<0.4 ✓			
1,4-dichlorobenzene	ug/L	0.4	<0.4 ✓			
1,2-dichloroethane	ug/L	0.7	<0.7 ✓			
1,1-dichloroethylene	ug/L	0.5	<0.5 ✓			
Dichloromethane	ug/L	4.0	<4.0 ✓			
Tetrachloroethylene	ug/L	0.3	<0.3 ✓			
Trichloroethylene	ug/L	0.3	<0.3 ✓			
Vinyl Chloride	ug/L	0.5	<0.5 ✓			
<b>TOTALS</b>						
Trihalomethanes (total)	ug/L	2.0	82.4 ✓			
Xylene; total	ug/L	2.0	<2.0 ✓			
<b>BTEX / 624 Surrogate Recoveries</b>						
Toluene-d8	%		97			
1,2-dichloroethane-d4	%		104			
4-bromofluorobenzene	%		103			

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL: 

# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

**Client:** Finch Well Supply

**Report Number:** 2200718  
**Date:** 2002-03-12  
**Date Submitted:** 2002-01-22

**ATT:** Mr. Blair Henderson

**Project:** Finch Wells - Quarterly Chemicals  
**Sample Matrix:** Supply Water

<b>LAB ID:</b>			167006				
<b>Sample Date:</b>			2002-01-21				
<b>Sample ID:</b>			FW-01				
PARAMETER	UNITS	MDL					
<b>PESTICIDES &amp; PCB's</b>							
Alachlor	mg/L	0.0005	<0.0005				
Aldicarb	mg/L	0.0050	<0.0050				
Aldrin + Dieldrin	mg/L	0.00007	<0.00007				
Atrazine	mg/L	0.001	<0.001				
Azinphos-methyl	mg/L	0.002	<0.002				
Bendiocarb	mg/L	0.0020	<0.0020				
Bromoxynil	mg/L	0.0005	<0.0005				
Carbaryl	mg/L	0.0050	<0.0050				
Carbofuran	mg/L	0.0050	<0.0050				
Chlordane (Total)	mg/L	0.0007	<0.0007				
Chlorpyrifos	mg/L	0.0010	<0.0010				
Cyanazine	mg/L	0.0010	<0.0010				
Diazinon	mg/L	0.0010	<0.0010				
Dicamba	mg/L	0.0010	<0.0010				
Diquat	mg/L	0.0070	<0.0070				
2,4-Dichlorophenol	mg/L	0.0005	<0.0005				
DDT	mg/L	0.0030	<0.0030				
2,4-D	mg/L	0.0010	<0.0010				
Diclofop-methyl	mg/L	0.0009	<0.0009				
Dimethoate	mg/L	0.0025	<0.0025				
Dinoseb	mg/L	0.0010	<0.0010				
Diuron	mg/L	0.010	<0.010				
Glyphosate	mg/L	0.010	<0.010				
Heptachlor + Hept. Epoxide	mg/L	0.0003	<0.0003				
Lindane (Total)	mg/L	0.0004	<0.0004				
Malathion	mg/L	0.0050	<0.0050				
Methoxychlor	mg/L	0.0900	<0.0900				
Metolachlor	mg/L	0.0005	<0.0005				

ND = Not Detected (< MDL)

MDL = Method Detection Limit

**Comment:**

**APPROVAL:**



# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

Client: Finch Well Supply

Report Number:

2200718

Date:

2002-03-12

Date Submitted:

2002-01-22

ATT: Mr. Blair Henderson

Project:

Finch Wells - Quarterly  
Chemicals

Sample Matrix:

Supply Water

LAB ID: 167006  
Sample Date: 2002-01-21  
Sample ID: FW-01

PARAMETER	UNITS	MDL				
Metribuzin	mg/L	0.005	<0.005			
Paraquat	mg/L	0.0010	<0.0010			
Parathion	mg/L	0.0010	<0.0010			
Pentachlorophenol	mg/L	0.0005	<0.0005			
Phorate	mg/L	0.0005	<0.0005			
Picloram	mg/L	0.0050	<0.0050			
PCB's (total)	mg/L	0.0003	<0.0003			
Prometryne	mg/L	0.00025	<0.00025			
Simazine	mg/L	0.0010	<0.0010			
Terbufos	mg/L	0.010	<0.010			
Triallate	mg/L	0.0007	<0.0007			
2,3,4,6-Tetrachlorophenol	mg/L	0.0005	<0.0005			
2,4,6-Trichlorophenol	mg/L	0.0005	<0.0005			
Trifluralin	mg/L	0.0010	<0.0010			
2,4,5-T	mg/L	0.0010	<0.0010			

ND = Not Detected (< MDL)

MDL = Method Detection Limit

Comment:

APPROVAL: 

## ACCUTEST LABORATORIES LTD.

REPORT OF ANALYSIS

Client: FINCH WELL SUPPLY

Report Number:

2200718

Date:

2002-01-29

Date Submitted:

2002-01-22

ATT: Mr. Blair Henderson

Project:

Finch Wells - Quarterly

P.O. Number:

Matrix:

Supply Water

		LAB ID:	167006				
		Sample Date:	2002-01-21				
		Sample ID:	FW-01				
PARAMETER	UNITS	MDL	TREATED WATER				
Ca	mg/L	1	66	✓			
F	mg/L	0.10	0.47	✓			
Mg	mg/L	1	29	✓			
N-NO2	mg/L	0.10	<0.10	✓			
N-NO3	mg/L	0.10	<0.10	✓			
K	mg/L	1	6	✓			
Na	mg/L	2	82	✓			

MDL = Method Detection Limit  
Comment.

INC = Incomplete

APPROVAL: 



# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

Client: FINCH WELL SUPPLY

Report Number: 2200722  
Date: 2002-01-25  
Date Submitted: 2002-01-22

ATT: Mr. Blair Henderson

Project: Finch System

P.O. Number:

Matrix: Supply Water

LAB ID:			167010				
Sample Date:			2002-01-21				
Sample ID:			FW-System SPS#1				
PARAMETER	UNITS	MDL					
<b>BTEX / 624 / PURGEABLE HYDROCARBONS</b>							
Bromodichloromethane	ug/L	0.3	18.7				
Bromoform	ug/L	0.4	2.0				
Chloroform	ug/L	0.5	10.4				
Dibromochloromethane	ug/L	0.3	15.0				
<b>TOTALS</b>							
Trihalomethanes (total)	ug/L	2.0	46.1	✓			
<b>BTEX / 624 Surrogate Recoveries</b>							
Toluene-d8	%		102				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL: 

**ACCUTEST** LABORATORIES LTD.

## REPORT OF ANALYSIS

**Client: FINCH WELL SUPPLY**

ATT: Mr. Blair Henderson

**Report Number:** 2200722  
**Date:** 2002-01-29  
**Date Submitted:** 2002-01-22

**Project:** Finch System

**P.O. Number:**  
**Matrix:** Supply Water

<b>LAB ID:</b> <b>Sample Date:</b> <b>Sample ID:</b>			167010				
			2002-01-21				
			FW-System SPS#1				
<b>PARAMETER</b>			<b>UNITS</b>	<b>MDL</b>	<b>TREATEDWATER</b>		
Pb			mg/L	0.001	<0.001 ✓		

MDL = Method Detection Limit  
Comment:

INC = Incomplete

APPROVAL:

*[Signature]*

**Caduceon Enterprises Inc.**  
**Environmental Laboratory**

**Certificate of Analysis**

Client:  
Ottario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220000965**  
Project: Finch WTP  
Date Sampled: February 4, 2002  
Date Received: February 5, 2002  
Date Printed: February 07, 2002  
Matrix: Drinking Water

Attention: **Dave Markell**

Parameter	Unit	MDL	Sample Identification			
			Well #1 Raw	WTP Treated	Dist. Co-op	Dist. Smith's Cotage
Total Chlorine	mg/L	0.05		2.70	1.50	1.40
Free Chlorine	mg/L	0.05		2.50	1.40	1.20
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	absent	8	
Total Coliforms	/100mL	1	absent	absent	absent	absent

**Caduceon Enterprises Inc.**  
**Environmental Laboratory**

**Certificate of Analysis**

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220001205**  
Project: Finch WTP  
Date Sampled: February 11, 2002  
Date Received: February 12, 2002  
Date Printed: February 14, 2002  
Matrix: Drinking Water

Attention: **Dave Markell**

Parameter	Unit	MDL	Sample Identification			
			Well #1 Raw	WTP Treated	Dist. MacEwen	Dist. SPS #1
Total Chlorine	mg/L	0.05		1.90	1.20	1.30
Free Chlorine	mg/L	0.05		1.80	1.00	1.20
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	absent	absent	
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Enterprises Inc. Environmental Laboratory

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220001420**  
Project: Finch WTP  
Date Sampled: February 18, 2002  
Date Received: February 19, 2002  
Date Printed: February 21, 2002

Attention: Dave Markell

Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well #1 Raw	WTP Treated	Dist. Seniors Res.	Dist. Community Center
Total Chlorine	mg/L	0.05		2.30	1.70	1.90
Free Chlorine	mg/L	0.05		2.10	1.50	1.70
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	2	120	
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220001625**  
Project: Finch WTP  
Date Sampled: February 25, 2002  
Date Received: February 26, 2002  
Date Printed: February 28, 2002

Attention: Dave Markell

Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well #1 Raw	WTP Treated	Dist. 3163 Victoria St.	Dist. Smith Cottage
Total Chlorine	mg/L	0.05		1.90	1.50	1.40
Free Chlorine	mg/L	0.05		1.70	1.40	1.20
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	absent	12	
Total Coliforms	/100mL	1	absent	absent	absent	absent

## REPORT OF ANALYSIS

**Matrix:** Supply Water

608 Norris Court, Kingston, ON, K7P 2R9

# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

Client: OCWA Chesterville

ATT: Blair Henderson

Report Number: 2201743  
Date: 2002-02-19  
Date Submitted: 2002-02-13

Project: Finch Water Filter Backwash  
to Sanitary Sewer

P.O. Number:  
Matrix: Sewage

LAB ID:			169744	169745			
Sample Date:			2002-02-12	2002-02-12			
Sample ID:			FW-0010	FW-0011			
PARAMETER	UNITS	MDL					
BOD5	mg/L	1	11				
pH			8.35				
Total P	mg/L	0.01	0.28				
Total Suspended Solids	mg/L	2	32				
Escherichia Coli	ct/100mL			<10			
Total Coliforms	ct/100mL			<10			

MDL = Method Detection Limit  
Comment:

INC = Incomplete

APPROVAL: \_\_\_\_\_





# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:

Ontario Clean Water Agency

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Report:

220001905

Project:

Finch WTP

Date Sampled:

March 4, 2002

Date Received:

March 5, 2002

Date Printed:

March 07, 2002

Attention: Dave Markell

Matrix:

Drinking Water

Parameter	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	0.05	2	1	0.05
Sample ID					
Well #2 Raw	absent		absent	absent	
WTP Treated	absent	1.90	2	absent	2.20
Dist. St. Bernard's School	absent	1.40	absent	absent	1.70
Dist. SPS # Main North	absent	1.10		absent	1.40
Well #1 Raw	absent			absent	

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

**Client:**

Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

**Report:**

**220002210**

**Project:**

Finch WTP

**Date Sampled:**

March 11, 2002

**Date Received:**

March 12, 2002

**Date Printed:**

March 14, 2002

**Attention:** Dave Markell

**Matrix:**

Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Raw	WTP Treated	Dist. Water Tower	Dist. Senior's
Total Chlorine	mg/L	0.05		2.00	1.90	2.00
Free Chlorine	mg/L	0.05		1.80	1.80	1.80
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	absent	absent	
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

*E. Piper*

Michael Ziebell, General Manager

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

**Client:**

Ontario Clean Water Agency  
8 Industrial Dr.  
Chesterville, ON  
K0C 1H0

**Report:**

**220002450**

**Project:**

Finch WTP

**Date Sampled:**

March 18, 2002

**Date Received:**

March 19, 2002

**Date Printed:**

March 21, 2002

**Attention:** Dave Markell

**Matrix:**

Drinking Water

Parameter	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	0.05	2	1	0.05
Sample ID					
Well Raw	absent		absent	absent	
WTP Treated	absent	0.70	absent	absent	1.35
Dist. Post Office	absent	1.68	2	absent	1.70
Dist. Ambulance Bldg	absent	2.00		absent	2.20
St. Bernard's School	absent	2.00		absent	2.08

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:

Ontario Clean Water Agency

Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: Dave Markell

Report:

220002713

Project:

Finch WTP

Date Sampled:

March 25, 2002

Date Received:

March 26, 2002

Date Printed:

April 01, 2002

Matrix:

Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well #1 Raw	WTP Treated	Dist. St. Bernards School	Dist. SPS #1
Total Chlorine	mg/L	0.05		2.20	1.90	1.20
Free Chlorine	mg/L	0.05		1.80	1.70	1.20
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	absent	absent	
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*April - June 2002, Finch Water Plant - Serving the Village of Finch*

## Finch Drinking Water Quality

### ***Ontario Drinking Water Protection Regulations***

The Ontario Clean Water Agency, as the contract operator of the Finch Water Treatment Facility on behalf of the Township of North Stormont, is pleased to present the 2002 Second Quarter Report on drinking water quality. This report has been prepared in response to legislative changes brought about by "Operation Clean Water", an initiative of Ontario's Ministry of the Environment to ensure high quality drinking water for the residents of Ontario. The new regulations put into law what was formerly the Ontario Drinking Water Objectives (ODWO), and sets requirements for public waterworks with regard to sampling and testing, levels of treatment, licensing of staff, and notification of authorities and the public about water quality.

Further information on the Ontario Drinking Water Regulations can be found on the Ministry of the Environment web site at [www.ene.gov.on.ca](http://www.ene.gov.on.ca)

## Where to contact us for information



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

Web site at [www.ocwa.com](http://www.ocwa.com)

Client Services Representative: John Kingsbury Operations Manager: Blair Henderson

Phone : (613) 774-3663

Phone: (613) 448-3098

E-mail Address: [jkingsbury@ocwa.com](mailto:jkingsbury@ocwa.com)

E-mail Address: [bhenderson@ocwa.com](mailto:bhenderson@ocwa.com)

You may also contact the Township of North Stormont directly by contacting Rheel Charbonneau, Clerk-Treasurer, Tel. (613) 984-2821 or e-mail address: [admin@northstormont.on.ca](mailto:admin@northstormont.on.ca)

Free copies of this report are available at the Township office or their website @ [www.townshipofnorthstormont.on.ca](http://www.townshipofnorthstormont.on.ca)



## INSIDE THIS REPORT

Drinking Water Regulations	1
Where To Contact Us	1
Plant Description & Treatment Processes	2
Quality Control and Compliance with Provincial Regulations	3
Definitions & Terms	4
Required Testing	4
Water Quality Test Results	5
Questions & Answers	7

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*April - June 2002, Finch Water Plant - Serving the Village of Finch*

## Introduction

We are proud to report that for the period April to June 2002, your water conformed to the Ontario Drinking Water Standards as set out in Ontario Regulation 459/00. The Ontario Clean Water Agency (OCWA) is dedicated to maximizing public health and safety through efficient and reliable operation of your water facility and distribution system.

## Plant Description and Treatment Processes

Facility Name:	Finch WTP & Distribution System
Total Design Capacity	691 cubic meters/day
Raw Water Source	Groundwater
Disinfection Method	Sodium Hypochlorite
Municipal Location	Municipal Office, 2 Victoria Street, Berwick
Service Area	Village of Finch
Service Population	441

### Operational Description:

Raw Water Source: Two drilled wells located at 20 William Street in the Village of Finch.

Low Lift Pumps: Two submersible well pumps, one duty and one standby, direct the water from the wells to a 9.5 L/second force draft aeration tower, where H<sub>2</sub>S is removed from the raw water. Water from the aeration tower is chemically injected with Sodium Hypochlorite for disinfection, prior to entry to the 20 cubic meter clear well.

High Lift Pumps: Two high lift pumps, one duty and one standby, move the chlorinated water from the clear well to the pressure filters.

Filters: Two 4 Litre/second dual media pressure filters, remove particles from the chlorinated water. Filter backwash treatment system consists of a 15 cubic meter surge tank, with a 1.4 cubic meter settling tank and an 18 cubic meter sludge holding tank.

Elevated Storage Tank: The plant treated water, after filtration, is directed to the distribution grid and elevated storage tank with a capacity of 580 cubic meters.

Distribution System: There are approximately 441 persons supplied with water from the Finch Water Treatment Plant.

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*April - June 2002, Finch Water Plant - Serving the Village of Finch*

## Quality Control & Compliance With Provincial Regulations

This plant provides multiple barriers against bacteriological contamination. Bacteriological testing is carried out on raw water, treated water and distribution samples on a regular frequency. On-line analysers for chlorine residuals and turbidity ensure daily monitoring of water leaving the plant. Chlorine levels in the distribution system are also checked on a regular basis. More specialized testing occurs monthly and quarterly and includes Volatile Organics, Inorganics, Pesticides and PCB's.

OCWA uses internal compliance auditing techniques by teams from within the organization. OCWA operates the Finch Water Treatment Facility in accordance with provincial regulations. Here is how we do it:

- **Use of Accredited Labs.** Analytical tests to monitor your water quality are conducted by a laboratory audited by the Canadian Association for Environmental Analytical Laboratories (CAEAL) and accredited by the Standards Council of Canada (SCC). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods.
- **Operation by Licensed Operators.** Your water treatment plant is operated and maintained by the Ontario Clean Water Agency's competent and licensed staff. The mandatory licensing program for operators of drinking water facilities is regulated under the *Ontario Water Resources Act (OWRA)* Regulation 435/93. Licensing means that an individual meets the education and experience requirements and has successfully passed the certificate exam.
- **Sampling and Analytical requirements.** OCWA follows a sampling and analysis schedule required by *OWRA* Regulation 459/00, the Ontario Drinking Water Standards. More information on sampling and analysis including results are available in this report and from your municipal office.
- **Adherence to Ministry Guidelines and Procedures.** To ensure the protection of the health and operational excellence, the OCWA adheres to the guidelines and procedures developed by the Ministry of the Environment and the Ministry of Health.

## **Did We Exceed the Standards?**

During the second quarter, in the month of April, a sample of treated water from the distribution system was found to exceed the Ontario Drinking Water Standards as set out in Ontario Regulation 459/00. On April 8, 2002 a sample collected from the sink at #1 sewage pumping station exceeded MAC for Total Coliform with a result of 2 per 100/ml. As a result we actively undertook the following remedial actions:

## QUARTERLY REPORT ON DRINKING WATER QUALITY

*April - June 2002, Finch Water Plant - Serving the Village of Finch*

Immediately notified the Ministry of Environment and the Ministry of Health as per the Ontario Drinking Water Standards. Ensured a minimum chlorine residual in the distribution of greater than 0.2 mg/L. Subsequent re-sampling indicated no adverse results.

### Definitions & Terms

**m<sup>3</sup>** - Cubic Meter, 1m<sup>3</sup> = 1000 litres

**TCU** - True Colour Units

**CaCO<sub>3</sub>** - Calcium Carbonate

**mg** - milligram

**mg/L** - milligrams per litre

**ug/L** - micrograms per litre

**ng/L** - nanograms per litre

**NTU** - Nephelometric Turbidity Units

**MAC** - Maximum Acceptable Concentration

**IMAC** - Interim Maximum Acceptable Concentration

**Coliform Bacteria** - a group of commonly occurring rod shaped bacteria. Their presence in a water sample is indicative of inadequate filtration and/or disinfection.

**Fecal Coliform Bacteria** - refers to a subgroup of coliform bacteria present in the digestive system of warm blooded animals and humans.

**Heterotrophic Plate Count** - a method of measuring bacterial content in water samples. Also known as Standard Plate Count.

**Organic Parameter** - a group of chemical compounds containing carbon.

**Inorganic Parameter** - a group of chemical compounds not containing carbon.

**Raw Water** - Surface or ground water available as a source of drinking water that has not received any treatment.

### Required Testing

The Ontario Drinking Water Regulations and Certificates of Approval (C of A) set sampling requirements for the plant. All other sampling conforms to the Drinking Water Protection Regulation schedule for sampling and analysis. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases can pick up substances resulting from the presence of animals or from human activity. Your water is extensively tested for the presence of dozens of compounds. The results of all analytical tests are available at your municipal office. The following table lists all compounds analyzed.



# QUARTERLY REPORT ON DRINKING WATER QUALITY

April - June 2002, Finch Water Plant - Serving the Village of Finch

## Finch Water Quality Test Results

Microbiological Parameters	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence?	Typical Source of Contaminant
Total Coliform (counts/100ml)	0	42	1	04/01-06/30	2	yes	Indicate possible presence of coliform
Escherichia Coliform (counts/100ml)	0	42	0	04/01-06/30	n/a	no	Definite indicator of fecal contamination
Heterotrophic Plate Count (counts/100ml)	500	29	7	04/01-06/30	2-8	no	Indicator of deteriorating water quality if greater than 500
Parameters related to Microbiological Quality	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence?	Typical Source of Contaminant
Turbidity (NTU)	1	Continuous	Continuous	04/01-06/30	0.07-0.85	no	Turbidity is a measure of particles in water
Free Chlorine - Plant Effluent (mg/l)	-	Continuous	Continuous	04/01-06/30	0.87-2.38	no	Chlorine added for Disinfection
Free Chlorine-Distribution (mg/l min 0.05 & max. 4.0)	-	Grab Sample weekly	weekly	04/01-06/30	1.0-2.0	no	Objective is 0.20 mg/l in the Distribution System (min. 0.05 mg/l required)
Inorganic Parameters (mg/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Lead - Distribution (ug/l)	0.01	1	1	01/21/02	0.001	no	Leached from lead solder or brass plumbing fixtures
Nitrate	10	1	1	04/11/02	<0.1	no	Natural component of water
Nitrite	1	1	1	04/11/02	<0.1	no	
Arsenic	IMAC= 0.025	1	1	09/18/00	<0.001	no	
Barium	1	1	1	09/18/00	0.43	no	
Boron	IMAC= 5.0	1	1	09/18/00	0.17	no	
Cadmium	0.005	1	1	09/18/00	<0.0001	no	
Chromium (Total)	0.05	1	1	09/18/00	<0.01	no	
Copper	1	1	1	09/18/00	0.013	no	
Iron	0.3	1	1	09/18/00	<0.01	no	
Lead	0.01	1	1	09/18/00	<0.001	no	
Manganese	0.05	1	1	09/18/00	<0.01	no	
Mercury	0.001	1	1	09/18/00	<0.0001	no	
Selenium	0.01	1	1	09/18/00	<0.001	no	
Uranium	0.1	1	1	09/18/00	<0.001	no	
Sodium (System)	200	2	2	01/21/02-02/13/02	82-77	no	
Fluoride	2.4	1	1	01/21/02	0.47	no	
Volatile Organics (ug/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Trihalomethanes - Plant	100	1	1	04/11/02	72.6	no	

# QUARTERLY REPORT ON DRINKING WATER QUALITY

April - June 2002, Finch Water Plant - Serving the Village of Finch

Trihalomethanes - Dist.	100	1	1	04/11/02	74.6	no	
Benzene	5	1	1	04/11/02	<0.5	no	
Carbon Tetrachloride	5	1	1	04/11/02	<0.9	no	
Dichloromethane	50	1	1	04/11/02	<4	no	
1,2 - Dichlorobenzene	200	1	1	04/11/02	<0.4	no	
1, 4 - Dichlorobenzene	5	1	1	04/11/02	<0.4	no	
1,2 - Dichloroethane	IMAC=5	1	1	04/11/02	<0.7	no	
1,1 - Dichloroethylene	14	1	1	04/11/02	<0.5	no	
<b>Volatile Organics (ug/l)</b>	<b>MAC or IMAC</b>	<b># of Samples</b>	<b># of Detectable Results</b>	<b>Sampling Dates (m/d/y)</b>	<b>Range</b>	<b>Exceedence?</b>	<b>Typical Source of Contaminant</b>
Ethylbenzene	24	1	1	04/11/02	<0.5	no	
Monochlorobenzene	80	1	1	04/11/02	<0.2	no	
Tetrachloroethylene	30	1	1	04/11/02	<0.3	no	
Toluene	24	1	1	04/11/02	<0.5	no	
Trichloroethylene	50	1	1	04/11/02	<0.3	no	
Vinyl chloride	2	1	1	04/11/02	<0.5	no	
Xylene	300	1	1	04/11/02	<2	no	
Bromodichloromethane	n/a	1	1	04/11/02	25.1	no	
Bromoform	n/a	1	1	04/11/02	2	no	
Chloroform	n/a	1	1	04/11/02	24.1	no	
Dibromochloromethane	n/a	1	1	04/11/02	21.4	no	
<b>Pesticides &amp; PCB (ug/L)</b>	<b>MAC or IMAC</b>	<b># of Samples</b>	<b># of Detectable Results</b>	<b>Sampling Dates (m/d/y)</b>	<b>Range</b>	<b>Exceedence?</b>	<b>Typical Source of Contaminant</b>
Alachlor	IMAC=5	1	1	04/11/02	<0.5	no	
Aldicarb	9	1	1	04/11/02	<5.0	no	
Aldrin+Dieldrin		1	1	04/11/02	<0.07	no	
Atrazine	IMAC=5	1	1	04/11/02	<1.0	no	
Azinphos-methyl	20	1	1	04/11/02	<2.0	no	
Bendiocarb	40	1	1	04/11/02	<2.0	no	
Bromoxynil	IMAC=5	1	1	04/11/02	<0.5	no	
Carbaryl	90	1	1	04/11/02	<5.0	no	
Carbofuran	90	1	1	04/11/02	<5.0	no	
Chlordane	7	1	1	04/11/02	<0.7	no	
Chorpyrifus	90	1	1	04/11/02	<1.0	no	
Cyanazine	IMAC=10	1	1	04/11/02	<1.0	no	
Diaznon	20	1	1	04/11/02	<1.0	no	
Dicamba	120	1	1	04/11/02	<1.0	no	
2,4 Dichlorophenol	900	1	1	04/11/02	<0.5	no	
DDT + Metapolites	30	1	1	04/11/02	<3.0	no	
2,4 - Dichlorophenexy acid (2,4 -D)	IMAC=10 0	1	1	04/11/02	<1.0	no	
Diclofop-methyl	9	1	1	04/11/02	<0.9	no	
Dimethoate	IMAC=20	1	1	04/11/02	<2.5	no	
Dinoseb	10	1	1	04/11/02	<1.0	no	
Diquat	70	1	1	04/11/02	<7.0	no	
Diuron	150	1	1	04/11/02	<10.0	no	
Glyphosate	IMAC=28 0	1	1	04/11/02	<10.0	no	
Heprachlor + Heptachlor epoxide	3	1	1	04/11/02	<0.3	no	
Lindane	4	1	1	04/11/02	<0.4	no	
Malathion	190	1	1	04/11/02	<5.0	no	
Methoxychlor	900	1	1	04/11/02	<90	no	
Metolachlor	IMAC=50	1	1	04/11/02	<0.5	no	
Metribuzin	80	1	1	04/11/02	<5.0	no	
Paraquat	IMAC=10	1	1	04/11/02	<1.0	no	
Parathion	50	1	1	04/11/02	<1.0	no	

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*April - June 2002, Finch Water Plant - Serving the Village of Finch*

Pentachlorophenol	60	1	1	04/11/02	<0.5	no	
Phorate	IMAC=2	1	1	04/11/02	<0.5	no	
Picloram	IMAC=19 0	1	1	04/11/02	<5.0	no	
Polychlorinated Biphenyls	IMAC=3	1	1	04/11/02	<0.3	no	
Prometryne	IMAC=1	1	1	04/11/02	<0.25	no	
Simazine	IMAC=10	1	1	04/11/02	<1.0	no	
Temephos	IMAC=28 0	1	1	04/11/02	<10	no	
Terbufos	IMAC=1	1	1	04/11/02	<0.7	no	
2,3,4,6 Tetrachlorophenol	100	1	1	04/11/02	<0.5	no	
Triallate	230	1	1	04/11/02	<1.0	no	
2,4,6-Trichlorophenol	5	1	1	04/11/02	<0.5	no	
2,4,5 - trichlorophenoxy acetic acid	IMAC=28 0	1	1	04/11/02	<1.0	no	
Trifluralin	45	1	1	04/11/02	<1.0	no	

Additional Parameters Non-Health Related (mg/L)	AO or OG	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Calcium	---	1	1	01/21/02	66	no	
Magnesium	---	1	1	01/21/02	29	no	
Potassium	---	1	1	01/21/02	6	no	

## Questions & Answers

Q. What is an Accredited Laboratory?

A. Accredited labs must have undergone an on-site assessment and performance review of their methods by the Canadian Association of Environmental and Analytical Laboratories. The Standards Council of Canada grants accreditation to the lab based on the recommendation of the CAEAL. The accreditation requirements are repeated every two years.

Q. What had to be done to meet the new regulations?

A. The Finch Water Treatment Plant was following the Ontario Drinking Water Objectives (ODWO) before they became law, so little change was required to meet the new regulations. Our chlorine residual in the water leaving the plant was raised to slightly to achieve the (0.20 mg/L free chlorine) required level in the distribution system, and some changes were required in the way results are reported. This report to the public is also the result of the new regulations.

Q. What parameters did you test for?

A. Microbiological parameters, volatile organics, inorganics, pesticides and PCB's have been tested. The results are included in this report.

Q. Sometimes my water looks rusty or coloured. Why is that, and what should I do about it?

A. This is quite often caused when the tanks in older water heaters start to decay. If the colour is seen only in your hot water, this may be the problem. If the colour is also noticed in your cold water it could be coming from the water main. Various maintenance procedures in the distribution system - such as fire hydrant and valve maintenance, or main break repairs - require flushing of the water mains. Flushing can cause small particles of sediment to break off adding colour to the water. Please note that there is no health risk associated with this problem. This is usually only temporary, and opening your taps for a while to flush out your service line (the pipe from the water main to your house) should take care of the problem. Let the water run until the colour disappears.

# **QUARTERLY REPORT ON DRINKING WATER QUALITY**

*April - June 2002, Finch Water Plant - Serving the Village of Finch*

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Attention: Dave Markell

Report: 220002968  
Project: Finch WTP  
Date Sampled: April 2, 2002  
Date Received: April 3, 2002  
Date Printed: April 05, 2002  
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. 83 Front	Dist. Seniors Res. (Kitchen)
Total Chlorine	mg/L	0.05		2.20	1.90	1.90
Free Chlorine	mg/L	0.05		1.90	1.70	1.30
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	8	absent	
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

**Client:**

Ontario Clean Water Agency

Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: Dave Markell

**Report:**

220003203

**Project:**

Finch WTP

**Date Sampled:**

April 8, 2002

**Date Received:**

April 9, 2002

**Date Printed:**

April 11, 2002

**Matrix:**

Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Barb's Diner	Dist. Sewage Pumping Station (SPS)
Total Chlorine	mg/L	0.05		2.40	1.30	1.20
Free Chlorine	mg/L	0.05		2.20	1.10	1.00
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	absent	absent	
Total Coliforms	/100mL	1	absent	absent	absent	2

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

**Client:**

Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

**Report:**

**220003352**

**Project:**

Finch WTP

**Date Sampled:**

April 10, 2002

**Date Received:**

April 11, 2002

**Date Printed:**

April 15, 2002

**Attention:** Dave Markell

**Matrix:**

Drinking Water

Parameter	Unit	MDL	Sample Identification		
			Special SPS #1	Special Co-op Upstream	Special JLK Plumbing Upstream
Total Chlorine	mg/L	0.05	1.40	1.40	1.70
Free Chlorine	mg/L	0.05	1.20	1.20	1.40
E. coli	/100mL	1	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	absent	absent
Total Coliforms	/100mL	1	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220003480**  
Project: Finch WTP  
Date Sampled: April 15, 2002  
Date Received: April 16, 2002  
Date Printed: April 18, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Smith Cartage	Dist. SPS #1
Total Chlorine	mg/L	0.05		2.60	1.50	1.70
Free Chlorine	mg/L	0.05		2.20	1.20	1.40
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2	absent	absent	absent	
Total Coliforms	/100mL	1	1	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

Michael Ziebell, General Manager



# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:

Ontario Clean Water Agency

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Report:

220003772

Project:

Finch WTP

Date Sampled:

April 22, 2002

Date Received:

April 23, 2002

Date Printed:

April 25, 2002

Attention: Dave Markell

Matrix:

Drinking Water

Parameter	E. coli	Free Cl2	HPC	TC	Total Cl2
Unit	/100mL	mg/L	/mL	/100mL	mg/L
MDL	1	0.05	2	1	0.05
Sample ID					
Well - Raw	absent		absent	absent	
WTP Treated	absent	2.10	absent	absent	2.20
Dist. Barb's	absent	1.80	absent	absent	2.80
Dist. St. Bernard's	absent	2.00		absent	2.20

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220004028**  
Project: Finch WTP  
Date Sampled: April 29, 2002  
Date Received: April 30, 2002  
Date Printed: May 02, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Water Tower	Dist. SPS
Total Chlorine	mg/L	0.05		2.20	1.70	2.00
Free Chlorine	mg/L	0.05		1.70	1.50	1.70
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		6	absent	
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

  
Michael Ziebell, General Manager

# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

Client: FINCH WELL SUPPLY

Report Number: 2204294  
Date: 2002-04-17  
Date Submitted: 2002-04-12

ATT: Mr. Blair Henderson

Project: Finch - Quarterly Chem

P.O. Number:

Matrix: Supply Water

LAB ID:			176579				
Sample Date:			2002-04-11				
Sample ID:			FW-01				
PARAMETER	UNITS	MDL					
<b>BTEX / 624 / PURGEABLE HYDROCARBONS</b>							
Benzene	ug/L	0.5	<0.5 ✓				
Toluene	ug/L	0.5	<0.5 ✓				
Ethylbenzene	ug/L	0.5	<0.5 ✓				
m/p-xylene	ug/L	1.0	<1.0				
o-xylene	ug/L	0.5	<0.5				
Bromodichloromethane	ug/L	0.3	25.1 ✓				
Bromoform	ug/L	0.4	2.0 ✓				
Carbon Tetrachloride	ug/L	0.9	<0.9 ✓				
Monochlorobenzene	ug/L	0.2	<0.2 ✓				
Chloroform	ug/L	0.5	24.1 ✓				
Dibromochloromethane	ug/L	0.3	21.4 ✓				
1,2-dichlorobenzene	ug/L	0.4	<0.4 ✓				
1,4-dichlorobenzene	ug/L	0.4	<0.4 ✓				
1,2-dichloroethane	ug/L	0.7	<0.7 ✓				
1,1-dichloroethylene	ug/L	0.5	<0.5 ✓				
Dichloromethane	ug/L	4.0	<4.0 ✓				
Tetrachloroethylene	ug/L	0.3	<0.3 ✓				
Trichloroethylene	ug/L	0.3	<0.3 ✓				
Vinyl Chloride	ug/L	0.5	<0.5 ✓				
<b>TOTALS</b>							
Trihalomethanes (total)	ug/L	2.0	72.6 ✓				
Xylene; total	ug/L	2.0	<2.0 ✓				
<b>BTEX / 624 Surrogate Recoveries</b>							
Toluene-d8	%		98				
1,2-dichloroethane-d4	%		89				
4-bromofluorobenzene	%		102				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL:



## REPORT OF ANALYSIS

### Supply Water

**APPROVAL:**



# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

**Client:** Finch Well Supply

**Report Number:**

2204294

**Date:**

2002-05-07

**Date Submitted:**

2002-04-12

**ATT:** Mr. Blair Henderson

**Project:**

Finch - Quarterly Chem

**Sample Matrix:**

Supply Water

<b>LAB ID:</b>			176579				
<b>Sample Date:</b>			2002-04-11				
<b>Sample ID:</b>			FW-01				
PARAMETER	UNITS	MDL					
<b>PESTICIDES &amp; PCB's</b>							
Alachlor	mg/L	0.0005	<0.0005 ✓				
Aldicarb	mg/L	0.0050	<0.0050 ✓				
Aldrin + Dieldrin	mg/L	0.00007	<0.00007 ✓				
Atrazine	mg/L	0.001	<0.001 ✓				
Azinphos-methyl	mg/L	0.002	<0.002 ✓				
Bendiocarb	mg/L	0.0020	<0.0020 ✓				
Bromoxynil	mg/L	0.0005	<0.0005 ✓				
Carbaryl	mg/L	0.0050	<0.0050 ✓				
Carbofuran	mg/L	0.0050	<0.0050 ✓				
Chlordane (Total)	mg/L	0.0007	<0.0007 ✓				
Chlorpyrifos	mg/L	0.0010	<0.0010 ✓				
Cyanazine	mg/L	0.0010	<0.0010 ✓				
Diazinon	mg/L	0.0010	<0.0010 ✓				
Dicamba	mg/L	0.0010	<0.0010 ✓				
Diquat	mg/L	0.0070	<0.0070 ✓				
2,4-Dichlorophenol	mg/L	0.0005	<0.0005 ✓				
DDT	mg/L	0.0030	<0.0030 ✓				
2,4-D	mg/L	0.0010	<0.0010 ✓				
Diclofop-methyl	mg/L	0.0009	<0.0009 ✓				
Dimethoate	mg/L	0.0025	<0.0025 ✓				
Dinoseb	mg/L	0.0010	<0.0010 ✓				
Diuron	mg/L	0.010	<0.010 ✓				
Glyphosate	mg/L	0.010	<0.010 ✓				
Heptachlor + Hept. Epoxide	mg/L	0.0003	<0.0003 ✓				
Lindane (Total)	mg/L	0.0004	<0.0004 ✓				
Malathion	mg/L	0.0050	<0.0050 ✓				
Methoxychlor	mg/L	0.0900	<0.0900 ✓				
Metolachlor	mg/L	0.0005	<0.0005 ✓				

ND = Not Detected (< MDL)

MDL = Method Detection Limit

**Comment:**

**APPROVAL:**

# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

**Client:** Finch Well Supply

**Report Number:**

2204294

**Date:**

2002-05-07

**Date Submitted:**

2002-04-12

**ATT:** Mr. Blair Henderson

**Project:**

Finch - Quarterly Chem

**Sample Matrix:**

Supply Water

			<b>LAB ID:</b>	176579				
			<b>Sample Date:</b>	2002-04-11				
			<b>Sample ID:</b>	FW-01				
PARAMETER	UNITS	MDL						
Metribuzin	mg/L	0.005	<0.005	<i>all checked</i>				
Paraquat	mg/L	0.0010	<0.0010					
Parathion	mg/L	0.0010	<0.0010					
Pentachlorophenol	mg/L	0.0005	<0.0005					
Phorate	mg/L	0.0005	<0.0005					
Picloram	mg/L	0.0050	<0.0050					
PCB's (total)	mg/L	0.0003	<0.0003					
Prometryne	mg/L	0.00025	<0.00025					
Simazine	mg/L	0.0010	<0.0010					
Meephos	mg/L	0.010	<0.010					
Terbufos	mg/L	0.0007	<0.0007					
2,3,4,6-Tetrachlorophenol	mg/L	0.0005	<0.0005					
Triallate	mg/L	0.0010	<0.0010					
2,4,6-Trichlorophenol	mg/L	0.0005	<0.0005					
Trifluralin	mg/L	0.0010	<0.0010					
2,4,5-T	mg/L	0.0010	<0.0010					

ND = Not Detected (< MDL)

MDL = Method Detection Limit

**Comment:**

**APPROVAL:**



# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

Client: FINCH WELL SUPPLY

Report Number:

2204303

Date:

2002-04-17

Date Submitted:

2002-04-12

ATT: Mr. Blair Henderson

Project:

Finch - Quarterly Chem

P.O. Number:

Matrix:

Supply Water

LAB ID:			176592				
Sample Date:			2002-04-11				
Sample ID:			FW-01				
PARAMETER	UNITS	MDL					
<b>BTEX / 624 / PURGEABLE HYDROCARBONS</b>							
Bromodichloromethane	ug/L	0.3	23.6				
Bromoform	ug/L	0.4	2.3				
Chloroform	ug/L	0.5	25.7				
Dibromochloromethane	ug/L	0.3	23.0				
<b>TOTALS</b>							
Trihalomethanes (total)	ug/L	2.0	74.6	✓			
<b>BTEX / 624 Surrogate Recoveries</b>							
ene-d8	%		98				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL: 

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

**Client:**

Ontario Clean Water Agency

Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: Dave Markell

**Report:**

220004302

**Project:**

Finch WTP

**Date Sampled:**

May 6, 2002

**Date Received:**

May 7, 2002

**Date Printed:**

May 09, 2002

**Matrix:**


Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well -Raw	WTP Treated	Dist. Seniors	Dist. Co-op
Total Chlorine	mg/L	0.05		2.30	1.90	2.00
Free Chlorine	mg/L	0.05		1.90	1.80	1.90
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	2	
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

FOR   
Michael Ziebell, General Manager



# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220004586**  
Project: Finch WTP  
Date Sampled: May 13, 2002  
Date Received: May 13, 2002  
Date Printed: May 15, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well #2 - Raw	WTP Treated	Dist. Separate School	Dist. Barb's Diner
Total Chlorine	mg/L	0.05		1.70	1.80	1.70
Free Chlorine	mg/L	0.05		1.30	1.60	1.40
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	2	
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Attention: Dave Markell

Report: 220004900  
Project: Finch WTP  
Date Sampled: May 21, 2002  
Date Received: May 22, 2002  
Date Printed: May 24, 2002  
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Water Tower	Dist. Sonar
Total Chlorine	mg/L	0.05		1.90	1.50	2.20
Free Chlorine	mg/L	0.05		1.60	1.30	1.80
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

Michael Ziebell, General Manager

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Attention: Dave Markell

Report: 220005177  
Project: Finch WTP  
Date Sampled: May 27, 2002  
Date Received: May 28, 2002  
Date Printed: May 30, 2002  
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Barb's	Dist. Carl's
Total Chlorine	mg/L	0.05		2.30	1.70	1.70
Free Chlorine	mg/L	0.05		2.00	1.30	1.50
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

*K. P. Ziebell*  
For Michael Ziebell, General Manager

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220005452**  
Project: Finch WTP  
Date Sampled: June 3, 2002  
Date Received: June 4, 2002  
Date Printed: June 06, 2002  
Matrix: Drinking Water

Attention: **Dave Markell**

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. St. Bernard	Dist. SPS
Total Chlorine	mg/L	0.05		1.90	1.80	1.40
Free Chlorine	mg/L	0.05		1.70	1.80	1.30
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220005850**  
Project: Finch WTP  
Date Sampled: June 10, 2002  
Date Received: June 11, 2002  
Date Printed: June 13, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Barb's Diner	Dist. St. Bernard's School
Total Chlorine	mg/L	0.05		1.90	1.60	2.00
Free Chlorine	mg/L	0.05		1.60	1.40	1.70
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		4	8	
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
ario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: 220006125  
Project: Finch WTP  
Date Sampled: June 17, 2002  
Date Received: June 18, 2002  
Date Printed: June 20, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Water Tower	Dist. Barb's
Total Chlorine	mg/L	0.05		1.90	1.60	1.20
Free Chlorine	mg/L	0.05		1.60	1.50	1.10
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: 220006430  
Project: Finch WTP  
Date Sampled: June 24, 2002  
Date Received: June 25, 2002  
Date Printed: June 27, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. SPS	Dist. Sonar
Total Chlorine	mg/L	0.05		1.60	1.10	1.10
Free Chlorine	mg/L	0.05		1.30	1.00	1.00
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		2	absent	
Background bacteria	/100mL	1	3			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*July-September 2002, Finch Water Plant - Serving the Village of Finch*

## Finch Drinking Water Quality

### ***Ontario Drinking Water Protection Regulations***

The Ontario Clean Water Agency, as the contract operator of the Finch Water Treatment Facility on behalf of the Township of North Stormont, is pleased to present the 2002 Third Quarter Report on drinking water quality. This report has been prepared in response to legislative changes brought about by "Operation Clean Water", an initiative of Ontario's Ministry of the Environment to ensure high quality drinking water for the residents of Ontario. The new regulations put into law what was formerly the Ontario Drinking Water Objectives (ODWO), and sets requirements for public waterworks with regard to sampling and testing, levels of treatment, licensing of staff, and notification of authorities and the public about water quality.

Further information on the Ontario Drinking Water Regulations can be found on the Ministry of the Environment web site at [www.ene.gov.on.ca](http://www.ene.gov.on.ca)

## Where to contact us for information



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

Web site at [www.ocwa.com](http://www.ocwa.com)

Client Services Representative: John Kingsbury

Phone : (613) 774-3663

E-mail Address: [jkingsbury@ocwa.com](mailto:jkingsbury@ocwa.com)

Operations Manager: Blair Henderson

Phone: (613) 448-3098

E-mail Address: [bhenderson@ocwa.com](mailto:bhenderson@ocwa.com)

You may also contact the Township of North Stormont directly by contacting Rheel Charbonneau, Clerk-Treasurer, Tel. (613) 984-2821 or e-mail address: [admin@northstormont.on.ca](mailto:admin@northstormont.on.ca)

Free copies of this report are available at the Township office or their website @ [www.townshipofnorthstormont.on.ca](http://www.townshipofnorthstormont.on.ca)



## INSIDE THIS REPORT

Drinking Water Regulations	1
Where To Contact Us	1
Plant Description & Treatment Processes	2
Quality Control and Compliance with Provincial Regulations	3
Definitions & Terms	4
Required Testing	4
Water Quality Test Results	4
Questions & Answers	7



# QUARTERLY REPORT ON DRINKING WATER QUALITY

July - September 2001, Finch Water Plant - Serving the Village of Finch

## Finch Drinking Water Quality

### ***Ontario Drinking Water Protection Regulations***

The Ontario Clean Water Agency, as the contract operator of the Finch Water Treatment Facility on behalf of the Township of North Stormont, is pleased to present the 2001 Third Quarter Report on drinking water quality. This report has been prepared in response to legislative changes brought about by "Operation Clean Water", an initiative of Ontario's Ministry of the Environment to ensure high quality drinking water for the residents of Ontario. The new regulations put into law what was formerly the Ontario Drinking Water Objectives (ODWO), and sets requirements for public waterworks with regard to sampling and testing, levels of treatment, licensing of staff, and notification of authorities and the public about water quality.

Further information on the Ontario Drinking Water Regulations can be found on the Ministry of the Environment web site at [www.ene.gov.on.ca](http://www.ene.gov.on.ca)

## Where to contact us for information



**Ontario Clean Water Agency  
Agence Ontarienne Des Eaux**

Web site at [www.ocwa.com](http://www.ocwa.com)

Client Services Representative: John Kingsbury  
Phone : (613) 821-3371  
E-mail Address: [jkingsbury@ocwa.com](mailto:jkingsbury@ocwa.com)

Operations Manager: Blair Henderson  
Phone: (613) 448-3098  
E-mail Address: [bhenderson@ocwa.com](mailto:bhenderson@ocwa.com)

You may also contact the Township of North Stormont directly by contacting Rheal Charbonneau, Clerk-Treasurer, Tel. (613) 984-2821 or  
e-mail address: [norstor@cnwl.igs.net](mailto:norstor@cnwl.igs.net)

Free copies of this report are available at the  
Township office or their website @  
[www.cnwl.igs.net/~northstormont](http://www.cnwl.igs.net/~northstormont)



## INSIDE THIS REPORT

Drinking Water Regulations	1
Where To Contact Us	1
Plant Description & Treatment Processes	2
Quality Control and Compliance with Provincial Regulations	3
Definitions & Terms	4
Required Testing	4
Water Quality Test Results	4
Questions & Answers	7

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*July-September 2002, Finch Water Plant - Serving the Village of Finch*

## Introduction

We are proud to report that for the period July to September 2002, your water conformed to the Ontario Drinking Water Standards as set out in Ontario Regulation 459/00. The Ontario Clean Water Agency (OCWA) is dedicated to maximizing public health and safety through efficient and reliable operation of your water facility and distribution system.

## Plant Description and Treatment Processes

Facility Name:	Finch WTP & Distribution System
Total Design Capacity	778 cubic meters/day
Raw Water Source	Groundwater
Disinfection Method	Sodium Hypochlorite
Municipal Location	Municipal Office, 2 Victoria Street, Berwick
Service Area	Village of Finch
Service Population	441

### Operational Description:

Raw Water Source: Two drilled wells located at 20 William Street in the Village of Finch.

Low Lift Pumps: Two submersible well pumps, one duty and one standby, direct the water from the wells to a 9.5 L/second force draft aeration tower, where H<sub>2</sub>S is removed from the raw water. Water from the aeration tower is chemically injected with Sodium Hypochlorite for disinfection, prior to entry to the 20 cubic meter clear well.

High Lift Pumps: Two high lift pumps, one duty and one standby, move the chlorinated water from the clear well to the pressure filters.

Filters: Two 4 Litre/second dual media pressure filters, remove particles from the chlorinated water. Filter backwash treatment system consists of a 15 cubic meter surge tank, with a 1.4 cubic meter settling tank and an 18 cubic meter sludge holding tank.

Elevated Storage Tank: The plant treated water, after filtration, is directed to the distribution grid and elevated storage tank with a capacity of 580 cubic meters.

Distribution System: There are approximately 441 persons supplied with water from the Finch Water Treatment Plant.

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*July - September 2001, Finch Water Plant - Serving the Village of Finch*

## Introduction

We are proud to report that for the period July to September 2001, your water conformed to the Ontario Drinking Water Standards as set out in Ontario Regulation 459/00. The Ontario Clean Water Agency (OCWA) is dedicated to maximizing public health and safety through efficient and reliable operation of your water facility and distribution system.

## Plant Description and Treatment Processes

Facility Name:	Finch WTP & Distribution System
Total Design Capacity	691 cubic meters/day
Raw Water Source	Groundwater
Disinfection Method	Sodium Hypochlorite
Municipal Location	Municipal Office, 2 Victoria Street, Berwick
Service Area	Village of Finch
Service Population	441

### Operational Description:

Raw Water Source: Two drilled wells located at 20 William Street in the Village of Finch.

Low Lift Pumps: Two submersible well pumps, one duty and one standby, direct the water from the wells to a 9.5 L/second force draft aeration tower, where H<sub>2</sub>S is removed from the raw water. Water from the aeration tower is chemically injected with Sodium Hypochlorite for disinfection, prior to entry to the 20 cubic meter clear well.

High Lift Pumps: Two high lift pumps, one duty and one standby, move the chlorinated water from the clear well to the pressure filters.

Filters: Two 4 Litre/second dual media pressure filters, remove particles from the chlorinated water. Filter backwash treatment system consists of a 15 cubic meter surge tank, with a 1.4 cubic meter settling tank and an 18 cubic meter sludge holding tank.

Elevated Storage Tank: The plant treated water, after filtration, is directed to the distribution grid and elevated storage tank with a capacity of 580 cubic meters.

Distribution System: There are approximately 441 persons supplied with water from the Finch Water Treatment Plant.

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*July-September 2002, Finch Water Plant - Serving the Village of Finch*

## **Quality Control & Compliance With Provincial Regulations**

This plant provides multiple barriers against bacteriological contamination. Bacteriological testing is carried out on raw water, treated water and distribution samples on a regular frequency. On-line analysers for chlorine residuals and turbidity ensure daily monitoring of water leaving the plant. Chlorine levels in the distribution system are also checked on a regular basis. More specialized testing occurs monthly and quarterly and includes Volatile Organics, Inorganics, Pesticides and PCB's.

OCWA uses internal compliance auditing techniques by teams from within the organization. OCWA operates the Finch Water Treatment Facility in accordance with provincial regulations. Here is how we do it:

- Use of Accredited Labs. Analytical tests to monitor your water quality are conducted by a laboratory audited by the Canadian Association for Environmental Analytical Laboratories (CAEAL) and accredited by the Standards Council of Canada (SCC). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods.
- Operation by Licensed Operators. Your water treatment plant is operated and maintained by the Ontario Clean Water Agency's competent and licensed staff. The mandatory licensing program for operators of drinking water facilities is regulated under the *Ontario Water Resources Act (OWRA)* Regulation 435/93. Licensing means that an individual meets the education and experience requirements and has successfully passed the certificate exam.
- Sampling and Analytical requirements. OCWA follows a sampling and analysis schedule required by *OWRA* Regulation 459/00, the Ontario Drinking Water Standards. More information on sampling and analysis including results are available in this report and from your municipal office.
- Adherence to Ministry Guidelines and Procedures. To ensure the protection of the health and operational excellence, the OCWA adheres to the guidelines and procedures developed by the Ministry of the Environment and the Ministry of Health.

## **Did We Exceed the Standards?**

With respect to Operational Parameters, no reportable exceedances were experienced.

## **Definitions & Terms**

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*July - September 2001, Finch Water Plant - Serving the Village of Finch*

## Quality Control & Compliance With Provincial Regulations

This plant provides multiple barriers against bacteriological contamination. Bacteriological testing is carried out on raw water, treated water and distribution samples on a regular frequency. On-line analysers for chlorine residuals and turbidity ensure daily monitoring of water leaving the plant. Chlorine levels in the distribution system are also checked on a regular basis. More specialized testing occurs monthly and quarterly and includes Volatile Organics, Inorganics, Pesticides and PCB's.

OCWA uses internal compliance auditing techniques by teams from within the organization. OCWA operates the Finch Water Treatment Facility in accordance with provincial regulations. Here is how we do it:

- **Use of Accredited Labs.** Analytical tests to monitor your water quality are conducted by a laboratory audited by the Canadian Association for Environmental Analytical Laboratories (CAEAL) and accredited by the Standards Council of Canada (SCC). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods.
- **Operation by Licensed Operators.** Your water treatment plant is operated and maintained by the Ontario Clean Water Agency's competent and licensed staff. The mandatory licensing program for operators of drinking water facilities is regulated under the *Ontario Water Resources Act (OWRA)* Regulation 435/93. Licensing means that an individual meets the education and experience requirements and has successfully passed the certificate exam.
- **Sampling and Analytical requirements.** OCWA follows a sampling and analysis schedule required by *OWRA* Regulation 459/00, the Ontario Drinking Water Standards. More information on sampling and analysis including results are available in this report and from your municipal office.
- **Adherence to Ministry Guidelines and Procedures.** To ensure the protection of the health and operational excellence, the OCWA adheres to the guidelines and procedures developed by the Ministry of the Environment and the Ministry of Health.

### **Did We Exceed the Standards?**

During the third quarter, in the month of July, 2 samples from the distribution system were found to exceed the Ontario Drinking Water Standards as set out in Ontario Regulation 459/00. As a result we actively undertook the following remedial actions:

Immediately notified the Ministry of Environment as per O.D.W.O.. Ensured a minimum chlorine residual in the distribution of greater than 0.2 mg/L. Subsequent re-sampling indicated no adverse results.

# QUARTERLY REPORT ON DRINKING WATER QUALITY

July-September 2002, Finch Water Plant - Serving the Village of Finch

**m<sup>3</sup>** - Cubic Meter, 1m<sup>3</sup> = 1000 litres

**TCU** - True Colour Units

**CaCO<sub>3</sub>** - Calcium Carbonate

**mg** - milligram

**mg/L** - milligrams per litre

**ug/L** - micrograms per litre

**ng/L** - nanograms per litre

**NTU** - Nephelometric Turbidity Units

**MAC** - Maximum Acceptable Concentration

**IMAC** - Interim Maximum Acceptable Concentration

**Coliform Bacteria** - a group of commonly occurring rod shaped bacteria. Their presence in a water sample is indicative of inadequate filtration and/or disinfection.

**Fecal Coliform Bacteria** - refers to a subgroup of coliform bacteria present in the digestive system of warm blooded animals and humans.

**Heterotrophic Plate Count** - a method of measuring bacterial content in water samples. Also known as Standard Plate Count.

**Organic Parameter** - a group of chemical compounds containing carbon.

**Inorganic Parameter** - a group of chemical compounds not containing carbon.

**Raw Water** - Surface or ground water available as a source of drinking water that has not received any treatment.

## Required Testing

The Ontario Drinking Water Regulations and Certificates of Approval (C of A) set sampling requirements for the plant. All other sampling conforms to the Drinking Water Protection Regulation schedule for sampling and analysis. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases can pick up substances resulting from the presence of animals or from human activity. Your water is extensively tested for the presence of dozens of compounds. The results of all analytical tests are available at your municipal office. The following table lists all compounds analyzed.

## Finch Water Quality Test Results

Microbiological Parameters	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence?	Typical Source of Contaminant
Total Coliform (counts/100ml)	0	42	0	07/01-09/30	n/a	no	Indicate possible presence of coliform
Escherichia Coliform (counts/100ml)	0	42	0	07/01-09/30	n/a	no	Definite indicator of fecal contamination
Heterotrophic Plate Count (counts/100ml)	500	28	12	07/01-09/30	2-478	no	Indicator of deteriorating water quality if greater than 500
Parameters related to Microbiological Quality	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence?	Typical Source of Contaminant

# QUARTERLY REPORT ON DRINKING WATER QUALITY

July - September 2001, Finch Water Plant - Serving the Village of Finch

## Definitions & Terms

**m<sup>3</sup>** - Cubic Meter, 1m<sup>3</sup> = 1000 litres

**TCU** - True Colour Units

**CaCO<sub>3</sub>** - Calcium Carbonate

**mg** - milligram

**mg/L** - milligrams per litre

**ug/L** - micrograms per litre

**ng/L** - nanograms per litre

**NTU** - Nephelometric Turbidity Units

**MAC** - Maximum Acceptable Concentration

**IMAC** - Interim Maximum Acceptable Concentration

**Coliform Bacteria** - a group of commonly occurring rod shaped bacteria. Their presence in a water sample is indicative of inadequate filtration and/or disinfection.

**Fecal Coliform Bacteria** - refers to a subgroup of coliform bacteria present in the digestive system of warm blooded animals and humans.

**Heterotrophic Plate Count** - a method of measuring bacterial content in water samples. Also known as Standard Plate Count.

**Organic Parameter** - a group of chemical compounds containing carbon.

**Inorganic Parameter** - a group of chemical compounds not containing carbon.

**Raw Water** - Surface or ground water available as a source of drinking water that has not received any treatment.

## Required Testing

The Ontario Drinking Water Regulations and Certificates of Approval (C of A) set sampling requirements for the plant. All other sampling conforms to the Drinking Water Protection Regulation schedule for sampling and analysis. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases can pick up substances resulting from the presence of animals or from human activity. Your water is extensively tested for the presence of dozens of compounds. The results of all analytical tests are available at your municipal office. The following table lists all compounds analyzed.

## Finch Water Quality Test Results

Microbiological Parameters	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedences	Typical Source of Contaminant
Total Coliform (counts/100ml)	0	45	1	07/01/01-09/30/01	0-1	yes	Indicate possible presence of coliform
Escherichia Coliform (counts/100ml)	0	45	0	07/01/01-09/30/01	n/a	no	Definite indicator of fecal contamination
Heterotrophic Plate Count (counts/100ml)	500	34	10	07/01/01-09/30/01	2 - >500	yes	Indicator of deteriorating water quality if greater than 500
Parameters related to Microbiological	MAC or IMAC	# of Samples	# of Detectable	Sampling Dates	Range	Exceedences	Typical Source of Contaminant

# QUARTERLY REPORT ON DRINKING WATER QUALITY

July-September 2002, Finch Water Plant - Serving the Village of Finch

Turbidity (NTU)	1	Continuous	Continuous	07/01-09/30	0.11-0.58	no	Turbidity is a measure of particles in water
Free Chlorine – Plant Effluent (mg/l)	-	Continuous	Continuous	07/01-09/30	1.09-2.40	no	Chlorine added for Disinfection
Free Chlorine-Distribution (mg/l min 0.05 & max. 4.0)	-	Grab Sample weekly	weekly	07/01-09/30	0.70-2.20	no	Objective is 0.20 mg/l in the Distribution System (min. 0.05 mg/l required)
Inorganic Parameters (mg/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Lead - Distribution (ug/l)	0.01	1	1	01/21/02	0.001	no	Leached from lead solder or brass plumbing fixtures
Nitrate	10	1	1	08/08/02	0.11	no	Natural component of water
Nitrite	1	1	1	08/08/02	<0.1	no	
Arsenic	IMAC= 0.025	1	1	09/18/00	<0.001	no	
Barium	1	1	1	09/18/00	0.43	no	
Boron	IMAC= 5.0	1	1	09/18/00	0.17	no	
Cadmium	0.005	1	1	09/18/00	<0.0001	no	
Chromium (Total)	0.05	1	1	09/18/00	<0.01	no	
Copper	1	1	1	09/18/00	0.013	no	
Iron	0.3	1	1	09/18/00	<0.01	no	
Lead	0.01	1	1	09/18/00	<0.001	no	
Manganese	0.05	1	1	09/18/00	<0.01	no	
Mercury	0.001	1	1	09/18/00	<0.0001	no	
Selenium	0.01	1	1	09/18/00	<0.001	no	
Uranium	0.1	1	1	09/18/00	<0.001	no	
Sodium (System)	200	2	2	01/21/02-02/13/02	82-77	no	
Fluoride	2.4	1	1	01/21/02	0.47	no	

Volatile Organics (ug/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Trihalomethanes - Plant	100	1	1	08/08/02	50.9	no	
Trihalomethanes - Dist.	100	1	1	08/08/02	59.8	no	
Benzene	5	1	1	08/08/02	<0.5	no	
Carbon Tetrachloride	5	1	1	08/08/02	<0.9	no	
Dichloromethane	50	1	1	08/08/02	<4	no	
1,2 - Dichlorobenzene	200	1	1	08/08/02	<0.4	no	
1,4 - Dichlorobenzene	5	1	1	08/08/02	<0.4	no	
1,2 - Dichloroethane	IMAC= 5	1	1	08/08/02	<0.7	no	
1,1 - Dichloroethylene	14	1	1	08/08/02	<0.5	no	
Ethylbenzene	24	1	1	08/08/02	<0.5	no	
Monochlorobenzene	80	1	1	08/08/02	<0.2	no	
Tetrachloroethylene	30	1	1	08/08/02	<0.3	no	
Toluene	24	1	1	08/08/02	<0.5	no	
Trichloroethylene	50	1	1	08/08/02	<0.3	no	
Vinyl chloride	2	1	1	08/08/02	<0.5	no	
Xylene	300	1	1	08/08/02	<2	no	
Bromodichloromethane	n/a	1	1	08/08/02	16.3	no	
Bromoform	n/a	1	1	08/08/02	<0.4	no	
Chloroform	n/a	1	1	08/08/02	16.8	no	
Dibromochloromethane	n/a	1	1	08/08/02	17.8	no	

Pesticides & PCB (ug/L)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Alachlor	IMAC=5	1	1	08/08/02	<0.5	no	



# QUARTERLY REPORT ON DRINKING WATER QUALITY

July - September 2001, Finch Water Plant - Serving the Village of Finch

Quality	IMAC	Results	(m/d/y)				
Turbidity (NTU)	1	daily	daily	07/01/01-09/30/01	0.11-0.38	no	Turbidity is a measure of particles in water
Free Chlorine - Plant Effluent (mg/l)	-	Continuous	Continuous	07/01/01-09/30/01	1.3-2.33	no	Chlorine added for disinfection
Free Chlorine-Distribution (mg/l min 0.05 & max. 4.0)	-	Grab Sample weekly	weekly	07/01/01-09/30/01	0.6-2.2	no	Objective is 0.20 mg/l in the Distribution System (min. 0.05 mg/l required)
Inorganic Parameters (mg/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Lead - Distribution (ug/l)	0.01	1	1	02/01/01	0.001	no	Leached from lead solder or brass plumbing fixtures
Nitrate	10	1	1	08/08/01	<0.1	no	Natural component of water
Nitrite	1	1	1	08/08/01	<0.1	no	
Arsenic	IMAC= 0.025	1	1	09/18/00	<0.001	no	
Barium	1	1	1	09/18/00	0.43	no	
Boron	IMAC= 5.0	1	1	09/18/00	0.17	no	
Cadmium	0.005	1	1	09/18/00	<0.0001	no	
Chromium (Total)	0.05	1	1	09/18/00	<0.01	no	
Copper	1	1	1	09/18/00	0.013	no	
Iron	0.3	1	1	09/18/00	<0.01	no	
Lead	0.01	1	1	09/18/00	<0.001	no	
Manganese	0.05	1	1	09/18/00	<0.01	no	
Mercury	0.001	1	1	09/18/00	<0.0001	no	
Selenium	0.01	1	1	09/18/00	<0.001	no	
Uranium	0.1	1	1	09/18/00	<0.001	no	
Sodium (System)	200	1	1	02/01/01	80	no	
Fluoride	2.4	1	1	02/01/01	0.5	no	
Volatile Organics (ug/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Trihalomethanes - Plant	100	1	1	08/08/01	87.4	no	
Trihalomethanes - Dist.	100	1	1	08/08/01	0	no	System sample lost in transit. Re-sampled Oct.25/01.MoE notified.
Benzene	5	1	1	08/08/01	<0.5	no	
Carbon Tetrachloride	5	1	1	08/08/01	<0.9	no	
Dichloromethane	50	1	1	08/08/01	<4	no	
1,2 - Dichlorobenzene	200	1	1	08/08/01	<0.4	no	
1,4 - Dichlorobenzene	5	1	1	08/08/01	<0.4	no	
1,2 - Dichloroethane	IMAC= 5	1	1	08/08/01	<0.7	no	
1,1 - Dichloroethylene	14	1	1	08/08/01	<0.5	no	
Ethylbenzene	24	1	1	08/08/01	<0.5	no	
Monochlorobenzene	80	1	1	08/08/01	<0.2	no	
Tetrachloroethylene	30	1	1	08/08/01	<0.3	no	
Toluene	24	1	1	08/08/01	<0.5	no	
Trichloroethylene	50	1	1	08/08/01	<0.3	no	
Vinyl chloride	2	1	1	08/08/01	<0.5	no	
Xylene	300	1	1	08/08/01	<2.0	no	
Bromodichloromethane	n/a	1	1	08/08/01	21.3	no	
Bromoform	n/a	1	1	08/08/01	3.3	no	
Chloroform	n/a	1	1	08/08/01	33.1	no	
Dibromochloromethane	n/a	1	1	08/08/01	29.7	no	

Pesticides & PCB (ug/L)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates	Range	Exceedence?	Typical Source of Contaminant
-------------------------	-------------	--------------	-------------------------	----------------	-------	-------------	-------------------------------

# QUARTERLY REPORT ON DRINKING WATER QUALITY

July-September 2002, Finch Water Plant - Serving the Village of Finch

Aldicarb	9	1	1	08/08/02	<5.0	no	
Aldrin+Dieldrin	0.7	1	1	08/08/02	<0.018	no	
Atrazine	IMAC=5	1	1	08/08/02	<1.0	no	
Azinphos-methyl	20	1	1	08/08/02	<2.0	no	
Bendiocarb	40	1	1	08/08/02	<2.0	no	
Bromoxynil	IMAC=5	1	1	08/08/02	<0.5	no	
Carbaryl	90	1	1	08/08/02	<5.0	no	
Carbofuran	90	1	1	08/08/02	<5.0	no	
Chlordane	7	1	1	08/08/02	<0.012	no	
Chlorpyrifus	90	1	1	08/08/02	<1.0	no	
Cyanazine	IMAC=10	1	1	08/08/02	<1.0	no	
Diazon	20	1	1	08/08/02	<1.0	no	
Dicamba	120	1	1	08/08/02	<1.0	no	
2,4 Dichlorophenol	900	1	1	08/08/02	<0.5	no	
DDT + Metabolites	30	1	1	08/08/02	<0.024	no	
2,4 - Dichlorophenoxy acid (2,4 -D)	IMAC=100	1	1	08/08/02	<1.0	no	
Diclofop-methyl	9	1	1	08/08/02	<0.9	no	
Dimethoate	IMAC=20	1	1	08/08/02	<2.5	no	
Dinoseb	10	1	1	08/08/02	<1.0	no	
Diquat	70	1	1	08/08/02	<7.0	no	
Diuron	150	1	1	08/08/02	<10.0	no	
Glyphosate	IMAC=280	1	1	08/08/02	<10.0	no	
Heptachlor + Heptachlor epoxide	3	1	1	08/08/02	<0.012	no	
Lindane	4	1	1	08/08/02	<0.006	no	
Malathion	190	1	1	08/08/02	<5.0	no	
Methoxychlor	900	1	1	08/08/02	<0.024	no	
Metolachlor	IMAC=50	1	1	08/08/02	<0.5	no	
Metribuzin	80	1	1	08/08/02	<5.0	no	
Paraquat	IMAC=10	1	1	08/08/02	<1.0	no	
Parathion	50	1	1	08/08/02	<1.0	no	
Pentachlorophenol	60	1	1	08/08/02	<0.5	no	
Phorate	IMAC=2	1	1	08/08/02	<0.5	no	
Picloram	IMAC=190	1	1	08/08/02	<5.0	no	
Polychlorinated Biphenyls	IMAC=3	1	1	08/08/02	<0.05	no	
Prometryne	IMAC=1	1	1	08/08/02	<0.25	no	
Simazine	IMAC=10	1	1	08/08/02	<1.0	no	
Temephos	IMAC=280	1	1	08/08/02	<10	no	
Terbufos	IMAC=1	1	1	08/08/02	<0.7	no	
2,3,4,6 Tetrachlorophenol	100	1	1	08/08/02	<0.5	no	
Triallate	230	1	1	08/08/02	<1.0	no	
2,4,6-Trichlorophenol	5	1	1	08/08/02	<0.5	no	
2,4,5 - trichlorophenoxy acetic acid	IMAC=280	1	1	08/08/02	<1.0	no	
Trifluralin	45	1	1	08/08/02	<1.0	no	

Additional Parameters Non-Health Related (mg/L)	AO or OG	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence?	Typical Source of Contaminant
Calcium	---	1	1	01/21/02	66	no	
Magnesium	---	1	1	01/21/02	29	no	
Potassium	---	1	1	01/21/02	6	no	

## Questions & Answers

Q. What is an Accredited Laboratory?

# QUARTERLY REPORT ON DRINKING WATER QUALITY

July - September 2001, Finch Water Plant - Serving the Village of Finch

		Results	(mg/L)			
Alachlor	IMAC=5	1	1	08/08/01	<0.5	no
Aldicarb	9	1	1	08/08/01	<5.0	no
Aldrin+Dieldrin	0.7	1	1	08/08/01	<0.07	no
Atrazine	IMAC=5	1	1	08/08/01	<0.49	no
Azinphos-methyl	20	1	1	08/08/01	<2.0	no
Bendiocarb	40	1	1	08/08/01	<2.0	no
Bromoxynil	IMAC=5	1	1	08/08/01	<0.5	no
Carbaryl	90	1	1	08/08/01	<5.0	no
Carbofuran	90	1	1	08/08/01	<5.0	no
Chlordane	7	1	1	08/08/01	<0.7	no
Chlorpyrifus	90	1	1	08/08/01	<1.0	no
Cyanazine	IMAC=10	1	1	08/08/01	<1.0	no
Diazinon	20	1	1	08/08/01	<1.0	no
Dicamba	120	1	1	08/08/01	<1.0	no
2,4 Dichlorophenol	900	1	1	08/08/01	<0.5	no
DDT + Metapolites	30	1	1	08/08/01	<3.0	no
2,4 - Dichlorophenoxy acid (2,4 -D)	IMAC=100	1	1	08/08/01	<1.0	no
Diclofop-methyl	9	1	1	08/08/01	<0.9	no
Dimethoate	IMAC=20	1	1	08/08/01	<2.5	no
Dinoseb	10	1	1	08/08/01	<1.0	no
Diquat	70	1	1	08/08/01	<7.0	no
Diuron	150	1	1	08/08/01	<10.0	no
Glyphosate	IMAC=280	1	1	08/08/01	<10.0	no
Heptachlor + Heptachlor epoxide	3	1	1	08/08/01	<0.3	no
Lindane	4	1	1	08/08/01	<0.4	no
Malathion	190	1	1	08/08/01	<5.0	no
Methoxychlor	900	1	1	08/08/01	<90.0	no
Metolachlor	IMAC=50	1	1	08/08/01	<0.5	no
Metribuzin	80	1	1	08/08/01	<5.0	no
Paraquat	IMAC=10	1	1	08/08/01	<1.0	no
Parathion	50	1	1	08/08/01	<1.0	no
Pentachlorophenol	60	1	1	08/08/01	<0.5	no
Phorate	IMAC=2	1	1	08/08/01	<0.5	no
Picloram	IMAC=190	1	1	08/08/01	<5.0	no
Polychlorinated Biphenyls	IMAC=3	1	1	08/08/01	<0.3	no
Prometryne	IMAC=1	1	1	08/08/01	<0.25	no
Simazine	IMAC=10	1	1	08/08/01	<1.0	no
Temephos	IMAC=280	1	1	08/08/01	<10	no
Terbufos	IMAC=1	1	1	08/08/01	<0.7	no
2,3,4,6 Tetrachlorophenol	100	1	1	08/08/01	<0.5	no
Triallate	230	1	1	08/08/01	<1.0	no
2,4,6-Trichlorophenol	5	1	1	08/08/01	<0.5	no
2,4,5 - trichlorophenoxy acetic acid	IMAC=280	1	1	08/08/01	<1.0	no
Trifluralin	45	1	1	08/08/01	<1.0	no

## Questions & Answers

## QUARTERLY REPORT ON DRINKING WATER QUALITY

*July-September 2002, Finch Water Plant - Serving the Village of Finch*

A. Accredited labs must have undergone an on-site assessment and performance review of their methods by the Canadian Association of Environmental and Analytical Laboratories. The Standards Council of Canada grants accreditation to the lab based on the recommendation of the CAEAL. The accreditation requirements are repeated every two years.

Q. What had to be done to meet the new regulations?

A. The Finch Water Treatment Plant was following the Ontario Drinking Water Objectives (ODWO) before they became law, so little change was required to meet the new regulations. Our chlorine residual in the water leaving the plant was raised to slightly to achieve the (0.20 mg/L free chlorine) required level in the distribution system, and some changes were required in the way results are reported. This report to the public is also the result of the new regulations.

Q. What parameters did you test for?

A. Microbiological parameters, volatile organics, inorganics, pesticides and PCB's have been tested. The results are included in this report.

Q. Sometimes my water looks rusty or coloured. Why is that, and what should I do about it?

A. This is quite often caused when the tanks in older water heaters start to decay. If the colour is seen only in your hot water, this may be the problem. If the colour is also noticed in your cold water it could be coming from the water main. Various maintenance procedures in the distribution system - such as fire hydrant and valve maintenance, or main break repairs - require flushing of the water mains. Flushing can cause small particles of sediment to break off adding colour to the water. Please note that there is no health risk associated with this problem. This is usually only temporary, and opening your taps for a while to flush out your service line (the pipe from the water main to your house) should take care of the problem. Let the water run until the colour disappears.

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*July - September 2001, Finch Water Plant - Serving the Village of Finch*

Q. What is an Accredited Laboratory?

A. Accredited labs must have undergone an on-site assessment and performance review of their methods by the Canadian Association of Environmental and Analytical Laboratories. The Standards Council of Canada grants accreditation to the lab based on the recommendation of the CAEAL. The accreditation requirements are repeated every two years.

Q. What had to be done to meet the new regulations?

A. The Finch Water Treatment Plant was following the Ontario Drinking Water Objectives (ODWO) before they became law, so little change was required to meet the new regulations. Our chlorine residual in the water leaving the plant was raised to slightly to achieve the (0.20 mg/L free chlorine) required level in the distribution system, and some changes were required in the way results are reported. This report to the public is also the result of the new regulations.

Q. What parameters did you test for?

A. Microbiological parameters, volatile organics, inorganics, pesticides and PCB's have been tested. The results are included in this report.

Q. Sometimes my water looks rusty or coloured. Why is that, and what should I do about it?

A. This is quite often caused when the tanks in older water heaters start to decay. If the colour is seen only in your hot water, this may be the problem. If the colour is also noticed in your cold water it could be coming from the water main. Various maintenance procedures in the distribution system - such as fire hydrant and valve maintenance, or main break repairs - require flushing of the water mains. Flushing can cause small particles of sediment to break off adding colour to the water. Please note that there is no health risk associated with this problem. This is usually only temporary, and opening your taps for a while to flush out your service line (the pipe from the water main to your house) should take care of the problem. Let the water run until the colour disappears.

## REQUIRED SAMPLES

**JULY, AUGUST, SEPTEMBER 2002**

### Chemical Parameters

Table B & D  
NO2&NO3

Treated  
Treated

## System THM

TreatedDate  
Samples  
Collected705

### Bacti Parameters

Raw			
Well#1or2	E.Coli	Total Coli.	Background
Treated			
	E.Coli	Total Coli.	HPC
System			
2 Sites	E.Coli	Total Coli.	HPC 25%

JULY 1  
JULY 8  
JULY 15  
JULY 22  
JULY 29

Bacti's  
Bacti's  
Bacti's  
Bacti's  
Bacti's

AUG. 5  
AUG. 12  
AUG. 19  
AUG. 26

**Bacti's**  
**Bacti's**  
**Bacti's**  
**Bacti's**

SEPT. 2  
SEPT. 9  
SEPT. 1  
SEPT. 2  
SEPT. 3

Bacti's  
Bacti's  
Bacti's  
Bacti's  
Bacti's

Flouride Treated Water (Annual)  
Lead Distribution System (Annual)  
Table C Treated Water (Jan. 2003)  
Sodium Treated Water (Jan. 2007)

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220006761**  
Project: Finch WTP  
Date Sampled: July 2, 2002  
Date Received: July 3, 2002  
Date Printed: July 05, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Seniors	Dist. St. Bernard's
Total Chlorine	mg/L	0.05		2.30	0.90	2.00
Free Chlorine	mg/L	0.05		2.00	0.80	1.60
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		2	50	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Attention: Dave Markell

Report: 220007056  
Project: Finch WTP  
Date Sampled: July 8, 2002  
Date Received: July 9, 2002  
Date Printed: July 11, 2002  
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Barb's	Dist. Water Tower
Total Chlorine	mg/L	0.05		2.30	1.20	2.10
Free Chlorine	mg/L	0.05		1.90	0.90	1.90
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	16	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent



# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

**Client:**

Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

**Report:**

**220007322**

**Project:**

Finch WTP

**Date Sampled:**

July 15, 2002

**Date Received:**

July 16, 2002

**Date Printed:**

July 18, 2002

**Attention:** Dave Markell

**Matrix:**

Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Fosters	Dist. Patsy's Diner
Total Chlorine	mg/L	0.05		2.10	1.30	1.40
Free Chlorine	mg/L	0.05		1.80	1.10	1.30
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220007574**  
Project: Finch WTP  
Date Sampled: July 22, 2002  
Date Received: July 23, 2002  
Date Printed: July 25, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. SPS #1	Dist. Magu Sonar
Total Chlorine	mg/L	0.05		2.30	1.00	1.60
Free Chlorine	mg/L	0.05		2.10	0.90	1.20
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220007875**  
Project: Finch WTP  
Date Sampled: July 30, 2002  
Date Received: July 31, 2002  
Date Printed: August 02, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Barb's Diner	Dist. Senior Support Center
Total Chlorine	mg/L	0.05		2.50	1.80	2.20
Free Chlorine	mg/L	0.05		2.20	1.40	2.00
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	12	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220008068**  
Project: Finch WTP  
Date Sampled: August 6, 2002  
Date Received: August 7, 2002  
Date Printed: August 09, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Water Tower	Dist. Barb's
Total Chlorine	mg/L	0.05		2.30	2.00	1.20
Free Chlorine	mg/L	0.05		2.00	1.80	1.10
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	4	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

**Client:**

Ontario Clean Water Agency

5 Industrial Dr.

Chesterville, ON

K0C 1H0

Attention: Dave Markell

**Report:**

**220008350**

**Project:**

Finch WTP

**Date Sampled:**

August 12, 2002

**Date Received:**

August 13, 2002

**Date Printed:**

August 15, 2002

**Matrix:**

Drinking Water

Parameter	Unit	MDL	Sample Identification				
			Well Raw	WTP Treated	Dist. 3163 Rd #12	Dist. Senior Center	Well #2 Raw
Total Chlorine	mg/L	0.05		2.00	1.70	1.70	
Free Chlorine	mg/L	0.05		1.90	1.50	1.50	
E. coli	/100mL	1	absent	absent	absent	absent	absent
HPC	/mL	2		4	20		
Background bacteria	/100mL	1	absent				absent
Total Coliforms	/100mL	1	absent	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Mario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: 220008620  
Project: Finch WTP  
Date Sampled: August 19, 2002  
Date Received: August 20, 2002  
Date Printed: August 22, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Smith Cartage	Dist. SPS #1
Total Chlorine	mg/L	0.05		2.30	1.90	1.00
Free Chlorine	mg/L	0.05		2.10	1.60	0.80
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Attention: Dave Markell

Report: 220008935  
Project: Finch WTP  
Date Sampled: August 26, 2002  
Date Received: August 27, 2002  
Date Printed: August 29, 2002  
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. MacEwen's Gas Bar	Dist. Pump Station #1
Total Chlorine	mg/L	0.05		2.20	1.20	0.90
Free Chlorine	mg/L	0.05		2.00	1.00	0.80
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	12	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

## REPORT OF ANALYSIS

**Matrix:** Supply Water

APPROVAL: 



# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

Client: FINCH WELL SUPPLY

Report Number: 2210860  
Date: 2002-08-19  
Date Submitted: 2002-08-09

ATT: Mr. Blair Henderson

Project: Finch Wells

P.O. Number:  
Matrix: Supply Water


LAB ID:			198048				
Sample Date:			2002-08-08				
Sample ID:			FW-01				
PARAMETER	UNITS	MDL					
<b>BTEX / 624 / PURGEABLE HYDROCARBONS</b>							
Benzene	ug/L	0.5	<0.5 ✓				
Toluene	ug/L	0.5	<0.5 ✓				
Ethylbenzene	ug/L	0.5	<0.5 ✓				
m/p-xylene	ug/L	1.0	<1.0 ✓				
o-xylene	ug/L	0.5	<0.5 ✓				
Bromodichloromethane	ug/L	0.3	16.3 ✓				
Bromoform	ug/L	0.4	<0.4 ✓				
Carbon Tetrachloride	ug/L	0.9	<0.9 ✓				
Monochlorobenzene	ug/L	0.2	<0.2 ✓				
Chloroform	ug/L	0.5	16.8 ✓				
Dibromochloromethane	ug/L	0.3	17.8 ✓				
1,2-dichlorobenzene	ug/L	0.4	<0.4 ✓				
1,4-dichlorobenzene	ug/L	0.4	<0.4 ✓				
1,2-dichloroethane	ug/L	0.7	<0.7 ✓				
1,1-dichloroethylene	ug/L	0.5	<0.5 ✓				
Dichloromethane	ug/L	4.0	<4.0 ✓				
Tetrachloroethylene	ug/L	0.3	<0.3 ✓				
Trichloroethylene	ug/L	0.3	<0.3 ✓				
Vinyl Chloride	ug/L	0.5	<0.5 ✓				
<b>TOTALS</b>							
Trihalomethanes (total)	ug/L	2.0	50.9 ✓				
Xylene; total	ug/L	2.0	<2.0 ✓				
<b>BTEX / 624 Surrogate Recoveries</b>							
Toluene-d8	%		97				
1,2-dichloroethane-d4	%		101				
4-bromofluorobenzene	%		101				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL:



# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

Client: FINCH WELL SUPPLY

Report Number: 2210860  
Date: 2002-08-29  
Date Submitted: 2002-08-09

ATT: Mr. Blair Henderson

Project: Finch Wells

Sample Matrix: Supply Water

LAB ID:			198048				
Sample Date:			8/8/02				
Sample ID:			FW-01				
PARAMETER	UNITS	MDL					
<b>PESTICIDES &amp; PCB's</b>							
Alachlor	ug/L	0.5	<0.5 ✓				
Aldicarb	ug/L	5	<5 ✓				
Aldrin	ug/L	0.006	<0.006 ✓				
Aldrin + Dieldrin	ug/L	0.012	<0.012 ✓				
Atrazine	ug/L	0.5	<0.5 ✓				
Desethyl-atrazine	ug/L	0.5	<0.5 ✓				
Atrazine+Desethyl-atrazine	ug/L	1	<1 ✓				
Azinphos-methyl	ug/L	2	<2 ✓				
Endosulfan	ug/L	2	<2 ✓				
Fluometo	ug/L	0.5	<0.5 ✓				
Carbaryl	ug/L	5	<5 ✓				
Carbofuran	ug/L	5	<5 ✓				
Chlordane (Total)	ug/L	0.012	<0.012 ✓				
α-Chlorodane	ug/L	0.006	<0.006 ✓				
γ-Chlorodane	ug/L	0.006	<0.006 ✓				
Oxychlorodane	ug/L	0.006	<0.006 ✓				
Chlorpyrifos	ug/L	1	<1 ✓				
Cyanazine	ug/L	1	<1 ✓				
Diazinon	ug/L	1	<1 ✓				
Dicamba	ug/L	1	<1 ✓				
Dieldrin	ug/L	0.006	<0.006 ✓				
Diquat	ug/L	7	<7 ✓				
2,4-Dichlorophenol	ug/L	0.5	<0.5 ✓				
DDT + Metabolites	ug/L	0.024	<0.024 ✓				
o,p'-DDT	ug/L	0.006	<0.006 ✓				
p,p'-DDT	ug/L	0.006	<0.006 ✓				
2,4-D	ug/L	1	<1 ✓				
p,p'-DDE	ug/L	0.006	<0.006 ✓				

NOTE: mg/L=1000ug/L

MDL = Method Detection Limit

Comment:

APPROVAL: 

146 Colonnade Road, Unit 8, Nepean, Ontario K2E 7Y1 Tel:(613)727-5692 Fax:(613)727-5222

# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

Client: FINCH WELL SUPPLY

Report Number: 2210860

Date: 2002-08-29

Date Submitted: 2002-08-09

ATT: Mr. Blair Henderson

Project: Finch Wells

Sample Matrix: Supply Water

LAB ID: 198048  
Sample Date: 8/8/02  
Sample ID: FW-01

PARAMETER	UNITS	MDL				
p,p'-DDD	ug/L	0.006	<0.006			
Diclofop-methyl	ug/L	0.9	<0.9 ✓			
Dimethoate	ug/L	2.5	<2.5 ✓			
Dinoseb	ug/L	1	<1 ✓			
Diuron	ug/L	10	<10 ✓			
Glyphosate	ug/L	10	<10 ✓			
Heptachlor	ug/L	0.006	<0.006 ✓			
Heptachlor epoxide	ug/L	0.006	<0.006 ✓			
Heptachlor + Hept. Epoxide	ug/L	0.012	<0.012 ✓			
ane	ug/L	0.006	<0.006 ✓			
Malathion	ug/L	5	<5 ✓			
Methoxychlor	ug/L	0.024	<0.024 ✓			
Metolachlor	ug/L	0.5	<0.5 ✓			
Metribuzin	ug/L	5	<5 ✓			
Paraquat	ug/L	1	<1 ✓			
Parathion	ug/L	1	<1 ✓			
Pentachlorophenol	ug/L	0.5	<0.5 ✓			
Phorate	ug/L	0.5	<0.5 ✓			
Picloram	ug/L	5	<5 ✓			
PCB's (total)	ug/L	0.05	<0.05 ✓			
Prometryne	ug/L	0.25	<0.25 ✓			
Simazine	ug/L	1	<1 ✓			
Temephos	ug/L	10	<10 ✓			
Terbufos	ug/L	0.7	<0.7 ✓			
2,3,4,6-Tetrachlorophenol	ug/L	0.5	<0.5 ✓			
Triallate	ug/L	1	<1 ✓			
2,4,6-Trichlorophenol	ug/L	0.5	<0.5 ✓			
Trifluralin	ug/L	1	<1 ✓			
2,4,5-T	ug/L	1	<1 ✓			

NOTE: mg/L=1000xug/L

MDL = Method Detection Limit

Comment:

APPROVAL: 

# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

Client: FINCH WELL SUPPLY

Report Number: 2210856  
Date: 2002-08-16  
Date Submitted: 2002-08-09

ATT: Mr. Blair Henderson

Project:

P.O. Number:

Matrix: Supply Water

LAB ID:			198044				
Sample Date:			2002-08-08				
Sample ID:			FW System				
PARAMETER	UNITS	MDL					
<b>BTEX / 624 / PURGEABLE HYDROCARBONS</b>							
Bromodichloromethane	ug/L	0.3	18.8				
Bromoform	ug/L	0.4	<0.4				
Chloroform	ug/L	0.5	19.3				
Dibromochloromethane	ug/L	0.3	21.7				
<b>TOTALS</b>							
Trihalomethanes (total)	ug/L	2.0	59.8 ✓				
<b>BTEX / 624 Surrogate Recoveries</b>							
ene-d8	%		96				

MDL = Method Detection Limit

INC = Incomplete

Comment:

APPROVAL: 

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220009261**  
Project: Finch WTP  
Date Sampled: September 3, 2002  
Date Received: September 4, 2002  
Date Printed: September 06, 2002

Attention: Dave Markell

Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Raw Well	WTP Treated	Water Tower	Barb's
Total Chlorine	mg/L	0.05		2.10	1.70	1.40
Free Chlorine	mg/L	0.05		2.00	1.40	1.30
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Attention: Dave Markell

Report: **220009543**  
Project: Finch WTP  
Date Sampled: September 9, 2002  
Date Received: September 10, 2002  
Date Printed: September 12, 2002  
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well Raw	WTP Treated	Dist. St. Bernard's	Dist. SPS #1
Total Chlorine	mg/L	0.05		2.20	1.70	0.80
Free Chlorine	mg/L	0.05		2.00	1.40	0.70
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	478	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220009884**  
Project: Finch WTP  
Date Sampled: September 16, 2002  
Date Received: September 17, 2002  
Date Printed: September 19, 2002

Attention: Dave Markell

Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Foster Acres House -20 Main	Dist. Barb's Diner
Total Chlorine	mg/L	0.05		2.20	2.19	1.49
Free Chlorine	mg/L	0.05		1.99	1.87	1.38
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220010230**  
Project: Finch WTP  
Date Sampled: September 23, 2002  
Date Received: September 24, 2002  
Date Printed: September 26, 2002

Attention: Dave Markell

Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	Well - Treated	Dist. Fire Hall	Dist. Smith Cartage
Total Chlorine	mg/L	0.05		2.10	2.00	1.70
Free Chlorine	mg/L	0.05		1.90	1.80	1.60
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	110	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent



# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Attention: Dave Markell

Report: 220010460  
Project: Finch WTP  
Date Sampled: September 30, 2002  
Date Received: October 1, 2002  
Date Printed: October 03, 2002  
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. County Bldg	Dist. St. Bernards School
Total Chlorine	mg/L	0.05		1.90	1.70	1.80
Free Chlorine	mg/L	0.05		1.70	1.60	1.60
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		8	2	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

**ACCUTEST LABORATORIES LTD.****REPORT OF ANALYSIS**

Client: OCWA Chesterville

Report Number:

2213036

Date:

2002-09-26

Date Submitted:

2002-09-20

ATT: Dave

Project:

P.O. Number:

Matrix:

Water FILTER BACKWASH

LAB ID:			206273	206274			
Sample Date:			2002-09-19	2002-09-19			
Sample ID:			FW-100	FW-200			
PARAMETER	UNITS	MDL					
BOD5	mg/L	1	41				
pH			8.38				
Total P	mg/L	0.01	0.69				
Total Suspended Solids	mg/L	2	102				
Background Colonies	cf/100 mL			>200			
Escherichia Coli	cf/100 mL			<10			
Total Coliforms	cf/100 mL			OG			

MDL = Method Detection Limit

INC = Incomplete

Comment:

OG = Overgrown - The presence of a large number of bacteria interfered with the Total Coliform analysis.

APPROVAL: \_\_\_\_\_

# QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Finch Water Plant - Serving the Village of Finch

## Finch Drinking Water Quality

### ***Ontario Drinking Water Protection Regulations***

The Ontario Clean Water Agency, as the contract operator of the Finch Water Treatment Facility on behalf of the Township of North Stormont, is pleased to present the 2002 Fourth Quarter Report on drinking water quality. This report has been prepared in response to legislative changes brought about by "Operation Clean Water", an initiative of Ontario's Ministry of the Environment to ensure high quality drinking water for the residents of Ontario. The new regulations put into law what was formerly the Ontario Drinking Water Objectives (ODWO), and sets requirements for public waterworks with regard to sampling and testing, levels of treatment, licensing of staff, and notification of authorities and the public about water quality.

Further information on the Ontario Drinking Water Regulations can be found on the Ministry of the Environment web site at [www.ene.gov.on.ca](http://www.ene.gov.on.ca)

## Where to contact us for information



**Ontario Clean Water Agency  
Agence Ontarienne Des Eaux**

Web site at [www.ocwa.com](http://www.ocwa.com)

### *Client Services Representative:*

John Kingsbury

Phone : (613) 774-3663

E-mail Address: [jkingsbury@ocwa.com](mailto:jkingsbury@ocwa.com)

### *Operations Manager:*

Blair Henderson

Phone: (613) 448-3098

E-mail Address: [bhenderson@ocwa.com](mailto:bhenderson@ocwa.com)

You may also contact the Township of North Stormont directly.

Rheal Charbonneau, Clerk - Treasurer

Phone: (613) 984-2821

E-mail Address: [admin@townshipofnorthstormont.on.ca](mailto:admin@townshipofnorthstormont.on.ca)

Free copies of this report are available at the Township Office at 2 Victoria St., Berwick, or their website @ [www.townshipofnorthstormont.on.ca](http://www.townshipofnorthstormont.on.ca)



## **INSIDE THIS REPORT**

Drinking Water Regulations	1
Where To Contact Us	1
Plant Description & Treatment Processes	2
Quality Control and Compliance with Provincial Regulations	3
Definitions & Terms	5
Required Testing	5
Water Quality Test Results	6
Questions & Answers	9

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*October - December 2002, Finch Water Plant - Serving the Village of Finch*

## Introduction

We are proud to report that for the period October to December 2002, your water conformed to the Ontario Drinking Water Standards as set out in Ontario Regulation 459/00. The Ontario Clean Water Agency (OCWA) is dedicated to maximizing public health and safety through efficient and reliable operation of your water facility and distribution system.

## Plant Description and Treatment Processes

Facility Name:	Finch WTP & Distribution System
Total Design Capacity	778 cubic meters/day
Raw Water Source	Groundwater
Disinfection Method	Sodium Hypochlorite
Municipal Location	Municipal office, 2 Victoria Street, Berwick
Service Area	Village of Finch
Service Population	441
<b>Operational Description:</b>	
<u>Raw Water Source:</u> Two drilled wells located at 20 William Street in the Village of Finch.	
<u>Low Lift Pumps:</u> Two submersible well pumps, one duty and one standby, direct the water from the wells to a 9.5 L/second force draft aeration tower, where H <sub>2</sub> S is removed from the raw water. Water from the aeration tower is chemically injected with Sodium Hypochlorite for disinfection, prior to entry to the 20 cubic meter clear well.	
<u>High Lift Pumps:</u> Two high lift pumps, one duty and one standby, move the chlorinated water from the clear well to the pressure filters.	
<u>Elevated Tank:</u> The plant treated water, after filtration, is directed to the distribution grid and elevated storage tank with a capacity of 580 cubic meters.	
<u>Filters:</u> Two 4 Litre/second dual media pressure filters, remove particles from the chlorinated water. Filter backwash treatment system consists of a 15 cubic meter surge tank, with a 1.4 cubic meter settling tank and an 18 cubic meter sludge holding tank.	
<u>Distribution System:</u> There are approximately 441 persons supplied with water from the Finch Water Treatment Plant.	

# QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Finch Water Plant - Serving the Village of Finch

## Quality Control & Compliance With Provincial Regulations

This plant provides multiple barriers against bacteriological contamination. Bacteriological testing is carried out on raw water, treated water and distribution samples on a regular frequency. On-line analysers for chlorine residuals and turbidity ensure daily monitoring of water leaving the plant. Chlorine levels in the distribution system are also checked on a regular basis. More specialized testing occurs monthly and quarterly and includes Volatile Organics, Inorganics, Pesticides and PCB's.

OCWA uses internal compliance auditing techniques by teams from within the organization. OCWA operates the Finch Water Treatment Facility in accordance with provincial regulations. Here is how we do it:

- Use of Accredited Labs. Analytical tests to monitor your water quality are conducted by a laboratory audited by the Canadian Association for Environmental Analytical Laboratories (CAEAL) and accredited by the Standards Council of Canada (SCC). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods.
- Operation by Licensed Operators. Your water treatment plant is operated and maintained by the Ontario Clean Water Agency's competent and licensed staff. The mandatory licensing program for operators of drinking water facilities is regulated under the *Ontario Water Resources Act (OWRA)* Regulation 435/93. Licensing means that an individual meets the education and experience requirements and has successfully passed the certificate exam.
- Sampling and Analytical requirements. OCWA follows a sampling and analysis schedule required by *OWRA* Regulation 459/00, the Ontario Drinking Water Standards. More information on sampling and analysis including results are available in this report and from your municipal office.
- Adherence to Ministry Guidelines and Procedures. To ensure the protection of the health and operational excellence, the OCWA adheres to the guidelines and procedures developed by the Ministry of the Environment and the Ministry of Health.

## **Annual Compliance Report**

The Annual Compliance Report covers the period from January 1, 2002 to December 31, 2002. Copies of the report will be made available for inspection by any member of the public during normal business hours without charge at the Township Office. The Annual Compliance Report for 2002 will be completed and made available not later than March 31, 2003.

# **QUARTERLY REPORT ON DRINKING WATER QUALITY**

*October - December 2002, Finch Water Plant - Serving the Village of Finch*

The Compliance Report will include, at a minimum, the following:

- A statement as to compliance with all of the terms and conditions of the certificate and a detailed description of all of the measures taken to ensure compliance with the certificate, including and supporting data or other information;
- In the event of any non-compliance during the reporting period, details of the non-compliance as well as details of how and when any non-compliance was corrected;
- A summary and discussion of the quantity of water supplied during the reporting period compared to the rated capacity specified in the Certificate of Approval, including monthly average and maximum daily flows;
- A summary of records related to flow rate exceedences, and a summary of analytical results of sampling required by the certificate, including raw water and in-process parameters as specified in the operations manual in accordance with the Certificate of Approval;
- A summary listing treatment chemicals used, including average dosage rates with special reference to any abnormal usages

## **Did We Exceed the Standards?**

With respect to Operational Parameters, between October 23 and November 1, 2002, the pressure filters that service the Finch water treatment plant were being removed and replaced with new ones. As a result, turbidity exceeded 1.0 NTU for this time frame. The Ministry of Environment and the Ministry of Health were immediately notified as per Regulation 459.

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*October - December 2002, Finch Water Plant - Serving the Village of Finch*

## Definitions & Terms

<b>m<sup>3</sup></b>	- Cubic Meter, 1 m <sup>3</sup> = 1000 litres
<b>TCU</b>	- True Colour Units
<b>CaCO<sub>3</sub></b>	- Calcium Carbonate
<b>mg</b>	- milligram
<b>mg/L</b>	- milligrams per litre.
<b>ug/L</b>	- micrograms per litre.
<b>ng/L</b>	- nanograms per litre.
<b>NTU</b>	- Nephelometric Turbidity Units.
<b>MAC</b>	- Maximum Acceptable Concentration
<b>IMAC</b>	- Interim Maximum Acceptable Concentration

**Coliform Bacteria** - a group of commonly occurring rod shaped bacteria. Their presence in a water sample is indicative of inadequate filtration and/or disinfection.

**Fecal Coliform Bacteria** - refers to a subgroup of coliform bacteria present in the digestive system of warm blooded animals and humans

**Background Count** - a method of measuring bacterial content in water samples

**Heterotrophic Plate Count** - a method of measuring bacterial content in water samples. Also known as Standard Plate Count.

**Organic Parameter** - a group of chemical compounds containing carbon

**Inorganic Parameter** - a group of chemical compounds not containing carbon

**Raw Water** - Surface or ground water available as a source of drinking water that has not received any treatment.

## Required Testing

The Ontario Drinking Water Regulations and Certificates of Approval (C of A) set sampling requirements for the plant. All other sampling conforms to the Drinking Water Protection Regulation schedule for sampling and analysis. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases can pick up substances resulting from the presence of animals or from human activity. Your water is extensively tested for the presence of dozens of compounds. The results of all analytical tests are available at your municipal office. The following table lists all compounds analyzed.

# QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Finch Water Plant - Serving the Village of Finch

## Finch Water Quality Test Results

Microbiological Parameters	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates	Range	Exceedence?	Typical Source of Contaminant
Total Coliform, Raw (CFU/100mL)	n/a	13	0	10/07 - 12/30 weekly	n/a	n/a	Indicate possible presence of fecal matter
E. Coli, Raw (CFU/100 mL)	n/a	13	0	10/07 - 12/30 weekly	n/a	n/a	Definite indicator of fecal contamination
Background Count, Raw (CFU/100 mL)	n/a	13	8	10/07 - 12/30 weekly	3-98	n/a	Indicator of adverse water quality
Total Coliform, Treated (CFU/100mL)	0	13	0	10/07 - 12/30 weekly	n/a	no	Indicate possible presence of fecal matter
E. coli, Treated (CFU/100 mL)	0	13	0	10/07 - 12/30 weekly	n/a	no	Definite indicator of fecal contamination
Hetrotrophic Plate Count, Treated (CFU/1 mL)	500	13	2	10/07 - 12/30 weekly	2-60	no	Indicator of adverse water quality
Total Coliform, Dist. (CFU/100mL)	0	26	0	10/07 - 12/30 weekly	n/a	no	Indicate possible presence of fecal matter
E. Coli, Dist. (CFU/100 mL)	0	26	0	10/07 - 12/30 weekly	n/a	no	Definite indicator of fecal contamination
Hetrotrophic Plate Count, Dist. (CFU/1 mL)	500	13	1	10/07 - 12/30 weekly	4	no	Indicator of adverse water quality

Parameters related to Microbiological Quality	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d)	Range	Exceedence	Typical Source of Contaminant
Turbidity (NTU)	1	Continuous	Continuous	10/01-12/31	0.11-2.43	yes	Turbidity is a measure of particles in water
Free Chlorine - Plant Effluent (mg/l)	-	Continuous	Continuous	10/01-12/31	1.0-2.35	no	Chlorine added for Disinfection
Free Chlorine-Distribution (mg/l min 0.05 & max. 4.0)	-	Grab Sample weekly	weekly	10/07-12/30	0.70-1.99	no	Objective is 0.20 mg/l in the Distribution System (min. 0.05 mg/l required)

**Comments:** MAC/IMAC values do not apply to Raw Water results. MOE recommend a level of at least 0.2 mg/l free chlorine residual in system to maintain microbiological quality in system. Adverse water quality occurs when the free chlorine residual is less than 0.05mg/l.

Inorganic Parameters (mg/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence	Typical Source of Contaminant
Lead - Distribution (ug/l)	0.01	1	1	01/21/02	0.001	no	Leached from lead solder or brass plumbing fixtures
Nitrate	10	1	1	10/15/02	<0.10	no	Natural component of water
Nitrite	1	1	1	10/15/02	<0.10	no	
Arsenic	IMAC= 0.025	1	1	09/18/00	<0.001	no	
Barium	1	1	1	09/18/00	0.43	no	
Boron	IMAC= 5.0	1	1	09/18/00	0.17	no	
Cadmium	0.005	1	1	09/18/00	<0.0001	no	
Chromium (Total)	0.05	1	1	09/18/00	<0.01	no	
Copper	1	1	1	09/18/00	0.013	no	
Iron	0.3	1	1	09/18/00	<0.01	no	
Lead	0.01	1	1	09/18/00	<0.001	no	
Manganese	0.05	1	1	09/18/00	<0.01	no	
Mercury	0.001	1	1	09/18/00	<0.0001	no	
Selenium	0.01	1	1	09/18/00	<0.001	no	



# QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Finch Water Plant - Serving the Village of Finch

Inorganic Parameters (cont'd) (mg/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence	Typical Source of Contaminant
Uranium	0.1	1	1	09/18/00	<0.001	no	
Sodium (System)	200	2	2	01/21/02-02/13/02	82-77	no	
Fluoride	2.4	1	1	01/21/02	0.47	no	

Volatile Organics (ug/l)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence	Typical Source of Contaminant
Trihalomethanes - Plant	100	1	1	10/15/02	75.4	no	
Trihalomethanes - Dist.	100	1	1	10/15/02	91.7	no	
Benzene	5	1	1	10/15/02	<0.5	no	
Carbon Tetrachloride	5	1	1	10/15/02	<0.9	no	
Dichloromethane	50	1	1	10/15/02	<4.0	no	
1,2 - Dichlorobenzene	200	1	1	10/15/02	<0.4	no	
1, 4 - Dichlorobenzene	5	1	1	10/15/02	<0.4	no	
1,2 - Dichloroethane	IMAC=5	1	1	10/15/02	<0.7	no	
1,1 - Dichloroethylene	14	1	1	10/15/02	<0.5	no	
Ethylbenzene	24	1	1	10/15/02	<0.5	no	
Monochlorobenzene	80	1	1	10/15/02	<0.2	no	
Tetrachloroethylene	30	1	1	10/15/02	<0.3	no	
Toluene	24	1	1	10/15/02	<0.5	no	
Trichloroethylene	50	1	1	10/15/02	<0.3	no	
Vinyl chloride	2	1	1	10/15/02	<0.5	no	
Xylene	300	1	1	10/15/02	<2	no	
Bromodichloromethane	n/a	1	1	10/15/02	23.8	no	
Bromoform	n/a	1	1	10/15/02	4.1	no	
Chloroform	n/a	1	1	10/15/02	23.3	no	
Dibromochloromethane	n/a	1	1	10/15/02	24.2	no	

Pesticides & PCB (ug/L)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence	Typical Source of Contaminant
Alachlor	IMAC=5	1	1	10/15/02	<0.5	no	
Aldicarb	9	1	1	10/15/02	<5.0	no	
Aldrin+Dieldrin	0.7	1	1	10/15/02	<0.012	no	
Atrazine	IMAC=5	1	1	10/15/02	<0.5	no	
Azinphos-methyl	20	1	1	10/15/02	<2.0	no	
Bendiocarb	40	1	1	10/15/02	<2.0	no	
Bromoxynil	IMAC=5	1	1	10/15/02	<0.5	no	
Carbaryl	90	1	1	10/15/02	<5.0	no	
Carbofuran	90	1	1	10/15/02	<5.0	no	
Chlordane	7	1	1	10/15/02	<0.012	no	
Chorpyrifus	90	1	1	10/15/02	<1.0	no	
Cyanazine	IMAC=10	1	1	10/15/02	<1.0	no	
Diaznon	20	1	1	10/15/02	<1.0	no	

# QUARTERLY REPORT ON DRINKING WATER QUALITY

October - December 2002, Finch Water Plant - Serving the Village of Finch

Pesticides & PCB (cont'd) (ug/L)	MAC or IMAC	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence	Typical Source of Contaminant
Dicamba	120	1	1	10/15/02	<1.0	no	
2,4 Dichlorophenol	900	1	1	10/15/02	<0.5	no	
DDT + Metabolites	30	1	1	10/15/02	<0.024	no	
2,4 - Dichlorophenoxy acid (2,4 -D)	IMAC=100	1	1	10/15/02	<1.0	no	
Diclofop-methyl	9	1	1	10/15/02	<0.9	no	
Dimethoate	IMAC=20	1	1	10/15/02	<2.5	no	
Dinoseb	10	1	1	10/15/02	<1.0	no	
Diquat	70	1	1	10/15/02	<7.0	no	
Diuron	150	1	1	10/15/02	<10.0	no	
Glyphosate	IMAC=280	1	1	10/15/02	<10.0	no	
Heprachlor + Heptachlor epoxide	3	1	1	10/15/02	<0.012	no	
Lindane	4	1	1	10/15/02	<0.006	no	
Malathion	190	1	1	10/15/02	<5.0	no	
Methoxychlor	900	1	1	10/15/02	<0.024	no	
Metolachlor	IMAC=50	1	1	10/15/02	<0.5	no	
Metribuzin	80	1	1	10/15/02	<5.0	no	
Paraquat	IMAC=10	1	1	10/15/02	<1.0	no	
Parathion	50	1	1	10/15/02	<1.0	no	
Pentachlorophenol	60	1	1	10/15/02	<0.5	no	
Phorate	IMAC=2	1	1	10/15/02	<0.5	no	
Picloram	IMAC=190	1	1	10/15/02	<5.0	no	
Polychlorinated Biphenyls	IMAC=3	1	1	10/15/02	<0.05	no	
Prometryne	IMAC=1	1	1	10/15/02	<0.25	no	
Simazine	IMAC=10	1	1	10/15/02	<1.0	no	
Temephos	IMAC=280	1	1	10/15/02	<10	no	
Terbufos	IMAC=1	1	1	10/15/02	<0.7	no	
2,3,4,6 Tetrachlorophenol	100	1	1	10/15/02	<0.5	no	
Triallate	230	1	1	10/15/02	<1.0	no	
2,4,6-Trichlorophenol	5	1	1	10/15/02	<0.5	no	
2,4,5 - trichlorophenoxy acetic acid	IMAC=280	1	1	10/15/02	<1.0	no	
Trifluralin	45	1	1	10/15/02	<1.0	no	

Additional Parameters Non-Health Related (mg/L)	AO or GG	# of Samples	# of Detectable Results	Sampling Dates (m/d/y)	Range	Exceedence	Typical Source of Contaminant
Calcium	---	1	1	01/21/02	66	no	
Magnesium	---	1	1	01/21/02	29	no	
Potassium	---	1	1	01/21/02	6	no	

# QUARTERLY REPORT ON DRINKING WATER QUALITY

*October - December 2002, Finch Water Plant - Serving the Village of Finch*

## Questions & Answers

*Q. What is an Accredited Laboratory?*

A. Accredited labs must have undergone an on-site assessment and performance review of their methods by the Canadian Association of Environmental and Analytical Laboratories. The Standards Council of Canada grants accreditation to the lab based on the recommendation of the CAEAL. The accreditation requirements are repeated every two years.

*Q. What had to be done to meet the new regulations?*

A. The Finch Water Treatment Plant was following the Ontario Drinking Water Objectives (ODWO) before they became law, so little change was required to meet the new regulations. Our chlorine residual in the water leaving the plant was raised to slightly to achieve the (0.20 mg/L free chlorine) required level in the distribution system, and some changes were required in the way results are reported. This report to the public is also the result of the new regulations.

*Q. What parameters did you test for?*

A. Microbiological parameters, volatile organic, inorganic and pesticides & PCBs have been tested. The results are included in this report.

*Q. Sometimes my water looks rusty or coloured. Why is that, and what should I do about it?*

A. This is quite often caused when the tanks in older water heaters start to decay. If the colour is seen only in your hot water, this may be the problem. If the colour is also noticed in your cold water it could be coming from the water main. Various maintenance procedures in the distribution system - such as fire hydrant and valve maintenance, or main break repairs - require flushing of the water mains. Flushing can cause small particles of sediment to break off adding colour to the water. Please note that there is no health risk associated with this problem. This is usually only temporary, and opening your taps for a while to flush out your service line (the pipe from the water main to your house) should take care of the problem. Let the water run until the colour disappears.

# FINCH WATER

## REQUIRED SAMPLES

**OCTOBER, NOVEMBER, DECEMBER 2002**

## Chemical Parameters

**Table B & D**  
**NO2&NO3**

Treated	✓
Treated	✓

System THM
Flouride
Sodium
B.O.D.
S.S
T.Phos
ph
E.Coli
T.Coli

annual  
annual

[illegible]

Date Samples Collected	Initials	Date Results Received	Initials
------------------------------	----------	-----------------------------	----------

[illegible]

## Bacti Parameters

Oct.6	Bacti's	✓
Oct.13	Bacti's	✓
Oct.20	Bacti's	✓
Oct.27	Bacti's	✓

Nov.3	Bacti's
Nov.10	Bacti's
Nov.17	Bacti's
Nov.24	Bacti's

Dec.1	Bacti's	
Dec.8	Bacti's	
Dec.15	Bacti's	
Dec.22	Bacti's	
Dec.29	Bacti's	

Flouride Treated Water (Annual) ✓  
Lead Distribution System (Annual) ✓  
Table C Treated Water (Jan. 2003)  
Sodium Treated Water (Jan. 2007)

Raw			
Well#1or2	E.Coli	Total Coli.	Background
Treated			
	E.Coli	Total Coli.	HPC
System			
2 Sites	E.Coli	Total Coli.	HPC 25%

[illegible][illegible][illegible][illegible]

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220010887**  
Project: Finch WTP  
Date Sampled: October 7, 2002  
Date Received: October 8, 2002  
Date Printed: October 10, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well Raw	WTP Treated	MacEwen's Gas Bar	62 Main St.
Total Chlorine	mg/L	0.05		2.00	1.60	0.80
Free Chlorine	mg/L	0.05		1.80	1.40	0.70
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (813)526-0123, Fax: (813)526-1244

  
Michael Ziebell, General Manager

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

**Client:**

Ontario Clean Water Agency

Industrial Dr.

Chesterville, ON

K0C 1H0

**Report:**

**220011202**

**Project:**

Finch WTP

**Date Sampled:**

October 15, 2002

**Date Received:**

October 16, 2002

**Date Printed:**

October 18, 2002

**Attention:** Dave Markell

**Matrix:**

Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Senior's Residence	Dist. SPS #1
Total Chlorine	mg/L	0.05		2.00	1.60	1.10
Free Chlorine	mg/L	0.05		1.90	1.40	0.90
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Attention: Dave Markell

Report: **220011480**  
Project: Finch WTP  
Date Sampled: October 21, 2002  
Date Received: October 22, 2002  
Date Printed: October 24, 2002  
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. St. Bernards School	Dist. MAQ Sonar
Total Chlorine	mg/L	0.05		2.20	1.50	1.40
Free Chlorine	mg/L	0.05		2.00	1.30	1.20
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Attention: Dave Markell

Report: 220011846  
Project: Finch WTP  
Date Sampled: October 28, 2002  
Date Received: October 29, 2002  
Date Printed: October 31, 2002  
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Smith Cartage	Dist. Senior's Res
Total Chlorine	mg/L	0.05		2.70	2.10	2.00
Free Chlorine	mg/L	0.05		2.40	1.90	1.80
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent



# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220012030**  
Project: Finch WTP  
Date Sampled: October 30, 2002  
Date Received: October 31, 2002  
Date Printed: November 04, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification	
			Finch Filter A Contents	Finch Filter B Contents
Total Chlorine	mg/L	0.05	2.50	2.50
Free Chlorine	mg/L	0.05	2.20	2.20
E. coli	/100mL	1	absent	absent
Heterotrophic Plate Count	/mL	2	absent	absent
Background bacteria	/100mL	1	absent	absent
Total Coliforms	/100mL	1	absent	absent

**ACCUTEST LABORATORIES LTD.****REPORT OF ANALYSIS**Client: **FINCH WELL SUPPLY**
 Report Number: 2214337  
 Date: 2002-10-21  
 Date Submitted: 2002-10-16

ATT: Mr. Blair Henderson

Project: Finch Quarterly Chemicals

P.O. Number:


Matrix: Supply Water

LAB ID:			210870				
Sample Date:			2002-10-15				
Sample ID:			FW-01				
PARAMETER	UNITS	MDL					
<b>BTEX / 624 / PURGEABLE HYDROCARBONS</b>							
Benzene	ug/L	0.5	<0.5 ✓				
Toluene	ug/L	0.5	<0.5 ✓				
Ethylbenzene	ug/L	0.5	<0.5 ✓				
m/p-xylene	ug/L	1.0	<1.0				
o-xylene	ug/L	0.5	<0.5				
Bromodichloromethane	ug/L	0.3	23.8 ✓				
Bromoform	ug/L	0.4	4.1 ✓				
Carbon Tetrachloride	ug/L	0.9	<0.9 ✓				
Monochlorobenzene	ug/L	0.2	<0.2 ✓				
Chloroform	ug/L	0.5	23.3 ✓				
bromochloromethane	ug/L	0.3	24.2 ✓				
1,2-dichlorobenzene	ug/L	0.4	<0.4 ✓				
1,4-dichlorobenzene	ug/L	0.4	<0.4 ✓				
1,2-dichloroethane	ug/L	0.7	<0.7 ✓				
1,1-dichloroethylene	ug/L	0.5	<0.5 ✓				
Dichloromethane	ug/L	4.0	<4.0 ✓				
Tetrachloroethylene	ug/L	0.3	<0.3 ✓				
Trichloroethylene	ug/L	0.3	<0.3 ✓				
Vinyl Chloride	ug/L	0.5	<0.5 ✓				
<b>TOTALS</b>							
Trihalomethanes (total)	ug/L	2.0	75.4 ✓				
Xylene; total	ug/L	2.0	<2.0 ✓				
<b>BTEX / 624 Surrogate Recoveries</b>							
Toluene-d8	%		97				
1,2-dichloroethane-d4	%		99				
4-bromofluorobenzene	%		100				

MDL = Method Detection Limit  
Comment:

INC = Incomplete

APPROVAL:



8-146 Colonnade Road, Ottawa, ON, K2E 7Y1

608 Norris Court, Kingston, ON, K7P 2R9



# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

**Client:** FINCH WELL SUPPLY

**Report Number:** 2214337  
**Date:** 2002-10-31  
**Date Submitted:** 2002-10-16

**ATT:** Mr. Blair Henderson

**Project:** Finch Quarterly Chemicals  
**Sample Matrix:** Supply Water

<b>LAB ID:</b>			210870				
<b>Sample Date:</b>			2002-10-15				
<b>Sample ID:</b>			FW-01				
PARAMETER	UNITS	MDL					
<b>PESTICIDES &amp; PCB's</b>							
Alachlor	ug/L	0.5	✓ <0.5 ✓				
Aldicarb	ug/L	5	✓ <5 ✓				
Aldrin	ug/L	0.006	<0.006				
Aldrin + Dieldrin	ug/L	0.012	✓ <0.012 ✓				
Atrazine	ug/L	0.5	✓ <0.5 ✓				
Desethyl-atrazine	ug/L	0.5	<0.5				
Atrazine+Desethyl-atrazine	ug/L	1	<1				
Azinphos-methyl	ug/L	2	✓ <2 ✓				
Bendiocarb	ug/L	2	✓ <2 ✓				
Imoxynil	ug/L	0.5	✓ <0.5 ✓				
Carbaryl	ug/L	5	✓ <5 ✓				
Carbofuran	ug/L	5	✓ <5 ✓				
Chlordane (Total)	ug/L	0.012	✓ <0.012 ✓				
α-Chlorodane	ug/L	0.006	<0.006				
γ-Chlorodane	ug/L	0.006	<0.006				
Oxychlorodane	ug/L	0.006	<0.006				
Chloropyrifos	ug/L	1	✓ <1 ✓				
Cyanazine	ug/L	1	✓ <1 ✓				
Diazinon	ug/L	1	✓ <1 ✓				
Dicamba	ug/L	1	✓ <1 ✓				
Dieldrin	ug/L	0.006	<0.006				
Diquat	ug/L	7	✓ <7 ✓				
2,4-Dichlorophenol	ug/L	0.5	✓ <0.5 ✓				
DDT + Metabolites	ug/L	0.024	✓ <0.024 ✓				
o,p'-DDT	ug/L	0.006	<0.006				
p,p'-DDT	ug/L	0.006	<0.006				
2,4-D	ug/L	1	✓ <1 ✓				
p,p'-DDE	ug/L	0.006	<0.006				

NOTE: mg/L (ppm)=1000ug/L (ppb)

MDL = Method Detection Limit

Comment:

APPROVAL:



# ACCUTEST LABORATORIES LTD.

## REPORT OF ANALYSIS

Client: FINCH WELL SUPPLY

Report Number: 2214337  
Date: 2002-10-31  
Date Submitted: 2002-10-16

ATT: Mr. Blair Henderson

Project: Finch Quarterly  
Chemicals  
Sample Matrix: Supply Water

LAB ID: 210870  
Sample Date: 2002-10-15  
Sample ID: FW-01

PARAMETER	UNITS	MDL				
p,p'-DDD	ug/L	0.006	<0.006			
Diclofop-methyl	ug/L	0.9	<0.9			
Dimethoate	ug/L	2.5	<2.5			
Dinoseb	ug/L	1	<1			
Diuron	ug/L	10	<10			
Glyphosate	ug/L	10	<10			
Heptachlor	ug/L	0.006	<0.006			
Heptachlor epoxide	ug/L	0.006	<0.006			
Heptachlor + Hept. Epoxide	ug/L	0.012	<0.012			
Lindane	ug/L	0.006	<0.006			
Malathion	ug/L	5	<5			
Methoxychlor	ug/L	0.024	<0.024			
Metolachlor	ug/L	0.5	<0.5			
Metribuzin	ug/L	5	<5			
Paraquat	ug/L	1	<1			
Parathion	ug/L	1	<1			
Pentachlorophenol	ug/L	0.5	<0.5			
Phorate	ug/L	0.5	<0.5			
Picloram	ug/L	5	<5			
PCB's (total)	ug/L	0.05	<0.05			
Prometryne	ug/L	0.25	<0.25			
Simazine	ug/L	1	<1			
Temephos	ug/L	10	<10			
Terbufos	ug/L	0.7	<0.7			
2,3,4,6-Tetrachlorophenol	ug/L	0.5	<0.5			
Triallate	ug/L	1	<1			
2,4,6-Trichlorophenol	ug/L	0.5	<0.5			
Trifluralin	ug/L	1	<1			
2,4,5-T	ug/L	1	<1			

NOTE: mg/L (ppm)=1000ug/L (ppb)

MDL = Method Detection Limit

Comment:

APPROVAL: 



# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220012189**  
Project: Finch WTP  
Date Sampled: November 4, 2002  
Date Received: November 5, 2002  
Date Printed: November 07, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated - 20 William St., Finch	Dist. MAQ Sonar	Smith Cartage
Total Chlorine	mg/L	0.05		2.19	1.6	1.54
Free Chlorine	mg/L	0.05		1.84	1.34	1.41
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	4			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220012679**  
Project: Finch WTP  
Date Sampled: November 12, 2002  
Date Received: November 13, 2002  
Date Printed: November 15, 2002  
Matrix: Drinking Water

Attention: Dave Markell

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. SPS	Dist. Barb's Diner
Total Chlorine	mg/L	0.05		1.61	1.01	1.63
Free Chlorine	mg/L	0.05		1.46	0.84	1.42
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		60	absent	
Background bacteria	/100mL	1	98			
Total Coliforms	/100mL	1	absent	absent	absent	absent



# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Attention: Dave Markell

Report: 220012906  
Project: Finch WTP  
Date Sampled: November 18, 2002  
Date Received: November 19, 2002  
Date Printed: November 21, 2002

Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	Well - Treated	Dist. Finch Arena	Dist. McEwen Fuel
Total Chlorine	mg/L	0.05		2.40	1.70	1.40
Free Chlorine	mg/L	0.05		2.10	1.40	1.20
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	4	
Background bacteria	/100mL	1	75			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: **220013265**  
Project: Finch WTP  
Date Sampled: November 25, 2002  
Date Received: November 26, 2002  
Date Printed: November 28, 2002

Attention: **Dave Markell**

Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. St. Bernard's School	Dist. SPS #1
Total Chlorine	mg/L	0.05		2.40	1.70	1.00
Free Chlorine	mg/L	0.05		2.10	1.40	0.80
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	49			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

**Client:**

Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

**Report:**

**220013597**

**Project:**

Finch WTP

**Date Sampled:**

December 2, 2002

**Date Received:**

December 3, 2002

**Date Printed:**

December 05, 2002

**Attention:** Dave Markell

**Matrix:**

Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Arena	Dist. Barb's Diner
Total Chlorine	mg/L	0.05		2.30	2.18	1.79
Free Chlorine	mg/L	0.05		1.97	1.99	1.51
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		2	absent	
Background bacteria	/100mL	1	10			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Oario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Report: 220013983  
Project: Finch WTP  
Date Sampled: December 9, 2002  
Date Received: December 10, 2002  
Date Printed: December 12, 2002

Attention: Dave Markell

Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Mad Sonar	Dist. St. Bernard School
Total Chlorine	mg/L	0.05		2.35	2.11	2.19
Free Chlorine	mg/L	0.05		1.99	1.83	1.96
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	27			
Total Coliforms	/100mL	1	absent	absent	absent	absent

Caduceon Environmental Laboratories

2378 Holly Lane, Ottawa, Ontario, K1V 7P1, Canada

Tel: (613)526-0123, Fax: (613)526-1244

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
5 Industrial Dr.  
Chesterville, ON  
K0C 1H0

Attention: Dave Markell

Report: **220014328**  
Project: Finch WTP  
Date Sampled: December 16, 2002  
Date Received: December 17, 2002  
Date Printed: December 19, 2002

Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Community Centre	Dist. Bank of Montreal
Total Chlorine	mg/L	0.05		2.02	1.74	1.44
Free Chlorine	mg/L	0.05		1.67	1.55	1.36
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	3			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

Client:  
Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

Attention: Dave Markell

Report: 220014626  
Project: Finch WTP  
Date Sampled: December 23, 2002  
Date Received: December 23, 2002  
Date Printed: December 27, 2002  
Matrix: Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP Treated	Dist. Maq Sonar	Dist. Finch Diner
Total Chlorine	mg/L	0.05		1.77	1.54	1.66
Free Chlorine	mg/L	0.05		1.57	1.32	1.39
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	6			
Total Coliforms	/100mL	1	absent	absent	absent	absent

# Caduceon Environmental Laboratories

Division of Caduceon Enterprises Inc.

## Certificate of Analysis

**Client:**

Ontario Clean Water Agency  
Industrial Dr.  
Chesterville, ON  
K0C 1H0

**Report:**

**220014784**

**Project:**

Finch WTP

**Date Sampled:**

December 30, 2002

**Date Received:**

December 30, 2002

**Date Printed:**

January 02, 2003

**Attention:** Dave Markell

**Matrix:**

Drinking Water

Parameter	Unit	MDL	Sample Identification			
			Well - Raw	WTP - Treated	Dist. Sewage pumping Station	Dist. Arena
Total Chlorine	mg/L	0.05		1.77	1.17	1.39
Free Chlorine	mg/L	0.05		1.55	0.96	1.08
E. coli	/100mL	1	absent	absent	absent	absent
Heterotrophic Plate Count	/mL	2		absent	absent	
Background bacteria	/100mL	1	absent			
Total Coliforms	/100mL	1	absent	absent	absent	absent